

2021 ASHRAE Handbook - Fundamentals (SI)																	
RIO GALLEGOS, ARGENTINA (WMO: 879250)																	
Lat: 51.6117S			Long: 69.3081W			Elev: 19		StdP: 101.10			Time zone: -3.00 (W03)			Period: 94-19		WBAN: 99999	
Annual Heating, Humidification, and Ventilation Design Conditions																	
Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF		
			99.6%			99%			0.4%		1%						
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD			
7	-7.0	-5.0	-10.2	1.6	1.9	-8.8	1.8	4.3	16.9	4.1	14.9	4.3	2.5	270	0.847		
Annual Cooling, Dehumidification, and Enthalpy Design Conditions																	
Hottest Month	Hottest Month DB Range	Cooling DB/MCWB							Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
		0.4%		1%		2%		0.4%		1%		2%					
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD		
1	11.1	24.2	13.7	22.2	12.6	20.8	11.8	14.7	22.1	13.6	20.5	12.6	18.8	8.3	250		
Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB		
0.4%			1%			2%			0.4%		1%		2%				
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB			
11.2	8.3	15.6	10.2	7.8	14.9	9.2	7.3	14.1	41.3	22.0	38.4	20.6	35.7	18.9	19.4		
Extreme Annual Design Conditions																	
Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
				Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
18.2	15.7	14.0	DB	-10.7	29.1	3.2	1.9	-13.0	30.5	-14.8	31.6	-16.6	32.7	-18.9	34.1		
			WB	-11.1	17.2	3.2	1.1	-13.4	18.0	-15.3	18.6	-17.0	19.3	-19.3	20.0		
Monthly Climatic Design Conditions																	
			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	13.5	13.1	11.3	8.1	4.6	1.7	1.8	3.4	6.0	8.5	10.6	12.5			
	DBStd	5.09	2.80	3.29	3.16	2.93	2.92	3.20	2.98	2.60	2.67	2.71	2.87	2.78			
	HDD10.0	1199	3	7	22	72	169	248	256	204	123	63	26	8			
	HDD18.3	3818	151	148	219	308	427	498	513	463	370	306	232	183			
	CDD10.0	430	112	94	62	14	1	0	0	0	3	16	44	84			
	CDD18.3	7	2	3	1	0	0	0	0	0	0	0	0	1			
	CDH23.3	113	31	51	10	1	0	0	0	0	0	0	4	16			
	CDH26.7	17	3	10	2	0	0	0	0	0	0	0	1	2			
Wind		WSAvg	6.3	7.5	6.9	6.4	6.0	5.2	5.2	5.3	5.7	6.0	6.9	7.5	7.6		
Precipitation	PrecAvg	257	29	25	22	23	22	21	19	15	13	16	21	28			
	PrecMax	416	91	72	75	95	80	93	63	41	38	56	98	78			
	PrecMin	127	4	1	1	2	0	0	1	1	0	0	0	2			
	PrecStd	66	18	16	18	18	15	19	13	11	9	15	18	19			
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.3	28.1	24.4	19.2	14.7	12.0	11.2	13.0	17.3	20.9	23.5	25.2			
		MCWB	14.4	15.9	14.3	11.4	9.2	6.9	6.7	7.0	9.0	10.9	12.5	14.0			
	2%	DB	23.8	24.8	21.2	17.0	12.2	9.2	8.7	10.7	15.0	18.2	20.9	22.2			
		MCWB	13.2	14.6	12.4	10.2	7.8	5.9	5.1	5.7	7.8	9.4	11.3	12.2			
	5%	DB	21.8	21.9	19.1	15.1	10.8	7.3	7.1	9.1	13.0	16.2	18.8	20.2			
		MCWB	12.2	13.0	11.2	9.3	7.0	4.8	4.2	4.9	6.7	8.4	10.1	11.2			
	10%	DB	19.8	19.6	17.1	13.2	9.2	6.1	5.9	7.8	11.1	14.8	16.9	18.4			
		MCWB	11.1	11.7	10.3	8.3	6.2	4.1	3.4	4.2	5.9	7.6	9.2	10.3			
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.8	15.0	12.7	10.1	7.7	7.0	7.7	9.7	11.5	13.3	15.0			
		MCDB	24.3	26.1	22.4	17.8	13.3	10.6	9.7	11.7	16.1	19.1	21.3	22.8			
	2%	WB	14.1	15.1	13.2	10.9	8.7	6.3	5.5	6.2	8.3	10.2	11.9	13.4			
		MCDB	21.8	22.7	19.2	15.3	11.0	8.2	7.7	9.4	13.5	17.0	19.1	20.3			
	5%	WB	12.9	13.8	12.2	10.0	7.6	5.2	4.6	5.3	7.3	9.1	10.8	12.2			
		MCDB	19.6	20.5	17.6	13.8	9.6	6.9	6.5	8.1	11.8	15.3	17.2	18.5			
	10%	WB	11.9	12.5	11.1	9.1	6.6	4.3	3.7	4.5	6.3	8.1	9.8	11.1			
		MCDB	18.1	18.1	16.0	12.7	8.7	6.0	5.5	6.9	10.1	13.5	15.6	17.3			

Mean Daily Temperature Range		MDBR	11.1	11.2	10.5	9.5	7.7	6.4	6.5	7.4	9.5	11.4	11.3	11.0
	5% DB	MCDBR	14.0	14.7	13.1	11.7	9.5	7.0	7.2	9.1	12.1	14.1	14.2	13.7
		MCWBR	6.6	7.2	6.6	7.0	6.3	5.1	5.1	5.7	6.7	7.5	7.0	6.6
	5% WB	MCDBR	12.6	14.1	12.0	10.9	8.2	6.4	6.8	8.2	11.2	13.4	12.8	12.5
		MCWBR	6.7	7.3	6.6	7.0	6.2	5.1	5.3	5.7	6.7	7.5	7.0	6.6
Clear Sky Solar Irradiance	taub		0.321	0.317	0.307	0.299	0.280	0.274	0.280	0.295	0.305	0.313	0.313	0.317
	taud		2.544	2.561	2.586	2.578	2.553	2.476	2.515	2.543	2.528	2.517	2.537	2.544
	Ebn at noon		988	956	909	818	727	660	712	808	893	950	990	1000
	Edn at noon		101	93	79	64	49	44	49	64	82	96	102	103
All-Sky Solar Radiation	RadAvg		5.94	4.99	3.47	2.08	1.13	0.77	0.96	1.74	3.04	4.61	5.69	6.17
	RadStd		0.37	0.25	0.21	0.10	0.08	0.07	0.06	0.10	0.19	0.15	0.32	0.40
Historical Trends														
	DBAvg	Heating		Cooling			Degree-Days							
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3				
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-88	N/A	N/A	N/A				
Regional (0 neighbors)	N/A	+0.75	N/A	N/A	N/A	-0.40	-84	N/A	N/A	N/A				

CDDn	Cooling degree-days base n°C, °C-day	Lat	Latitude, °	Period	Years used to calculate the design conditions
CDHn	Cooling degree-hours base n°C, °C-hour	Long	Longitude, °	Sd	Standard deviation of daily average temperature, °C
DB	Dry bulb temperature, °C	MCDB	Mean coincident dry bulb temperature, °C	StdP	Standard pressure at station elevation, kPa
DP	Dew point temperature, °C	MCDBR	Mean coincident dry bulb temp. range, °C	taub	Clear sky optical depth for beam irradiance
Ebn,noon	Clear sky beam normal and diffuse horizontal irradiances at solar noon, W/m2	MCDP	Mean coincident dew point temperature, °C	taud	Clear sky optical depth for diffuse irradiance
Edh,noon		MCWB	Mean coincident wet bulb temperature, °C	Tavg	Average temperature, °C
Elev	Elevation, m	MCWBR	Mean coincident wet bulb temp. range, °C	Time Zone	Hours ahead or behind UTC
Enth	Enthalpy, kJ/kg	MCWS	Mean coincident wind speed, m/s	WB	Wet bulb temperature, °C
HDDn	Heating degree-days base n°C, °C-day	MDBR	Mean dry bulb temp. range, °C	Hours 8/4 & 12.8/20.6	Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C
PCWD	Prevailing coincident wind direction, °, 0 = North, 90 = East	WS	Wind speed, m/s	HR	Humidity ratio, g of moisture per kg of dry air