

# Emission Test Certificate

Monday May 10<sup>th</sup>, 2010

Supplier: Sekisui Pilon Pty Ltd (1 – 5 Parraweena Road, Taren Point NSW 2229)

Sample Description: Thermobreak Thermaloc pipe supports (chemically cross linked polyolefin insulation with foil tape facing)

Date Tested: May 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Thermobreak Thermaloc</b>	<b>Total Volatile Organic Compound Specific Area Emission Rate mg/m<sup>2</sup>/hr</b>
24 hours	<0.06
This product can be classed as low VOC-emitting. The material emissions are less than the recognised threshold of 0.5 mg/m <sup>2</sup> /hr; e.g. “Green Star”.	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV100509