

SECTION 4

AIR DISTRIBUTION SYSTEMS

DUCT SIZING METHODS

General

The objective is to size the ductwork so that the total pressure loss along each flow path provides the correct air quantity through the network at each terminal without generating unacceptable noise.

A number of methods are used to size air conditioning ductwork and include:-

1. Velocity reduction method.
2. Constant pressure gradient method.
3. Balanced pressure drop method.
4. Static regain method.

Velocity reduction method

Each duct segment is sized on a specified velocity. The velocity is selected on the basis of experience and is reduced along the duct run.

Constant pressure gradient method

Each segment of the ductwork system is sized on the basis of a selected fixed pressure gradient. The pressure gradient is expressed in terms of unit length of straight duct, a value of 1.00 Pa/m is typical. This method is often termed the equal friction method.

Balanced pressure drop method

This is essentially a resizing method. Duct sizes initially sized by some other method or combination of methods are adjusted such that there is an equal pressure drop along all air flow paths, from the fan to each terminal. This will minimise the amount of pressure required to be taken up by balancing devices in the network. From the initial sizing calculations the path with the greatest pressure loss (the index run) is determined. The size of the segments in all other paths are then adjusted such that all paths have the same pressure drop as the index run.

Static regain method

This method is applicable to supply air duct systems only.

The static regain method sizes the ductwork system so that the pressure recovery due to decrease in velocity at each branch or velocity fitting just offsets the friction loss in the succeeding section of duct. The static pressure will then in theory be the same at each terminal and at each branch throughout the system.

Note: -

For full and detailed information on the design of duct systems including the calculation of system total pressure and fan selection, reference should be made to:-

AIRAH Application Manual DA3 - Ductwork for Air Conditioning and

AIRAH Application Manual DA13 - Fans - Selection and Application.

DUCT SYSTEM PRESSURE LOSSES

The total system resistance loss in a duct system is a combination of friction and dynamic losses.

Straight Ducts - In straight parallel ducts, dynamic loss is insignificant so the total loss is assumed as all friction. This value may be obtained from the following duct friction chart or if using the Constant Pressure Gradient Method of sizing a value for friction loss is assumed, e.g., 1.00 Pa/m.

Duct Fittings - For duct fittings both dynamic and friction losses are significant. Data for fittings are given in the following tables in terms of total loss, expressed as a Loss Coefficient K_f . The total pressure loss for a duct fitting is an expression of pressure loss in terms of velocity pressure or velocity pressure difference multiplied by the loss coefficient. Values of velocity pressure may be obtained from the following chart.

Total pressure loss of a fitting is given by:-

$$P_T = K_f P_v$$

where:-

P_T = total pressure loss through fitting (Pa)

K_f = loss coefficient

P_v = velocity pressure (Pa)

Velocity pressure is given by:-

$$P_v = 0.50 \rho V^2 \\ = 0.60 V^2 \text{ for air at } 20^\circ\text{C.}$$

where:-

V = velocity of the air stream (m/s)

For a circular duct,

$$V = 1273 \times (\text{Flow, L/s}) / (\text{diameter, mm})^2 \quad (\text{m/s})$$

ρ = density of air (kg/m^3)

Values of velocity pressure may be read from the following table.

VELOCITY PRESSURE - AIR (P_v)


Velocity (m/s)	Velocity pressure (Pa)
1.00	0.60
1.25	0.94
1.50	1.35
1.75	1.84
2.00	2.40
2.25	3.04
2.50	3.75
2.75	4.54
3.00	5.40
3.25	6.34
3.50	7.35
3.75	8.44
4.00	9.6
4.25	10.8
4.50	12.2
4.75	13.5
5.00	15.0
5.25	16.5
5.50	18.2
5.75	19.8
6.00	21.6
6.25	23.4
6.50	25.4
6.75	27.3
7.00	29.4

Velocity (m/s)	Velocity pressure (Pa)
7.25	32
7.50	34
7.75	36
8.00	38
8.25	41
8.50	43
8.75	46
9.00	49
9.25	51
9.50	54
9.75	57
10.0	60
12.5	94
15.0	135
17.5	184
20.0	240
22.5	304
25.0	375
27.5	454
30.0	540
35.0	735
40.0	960
45.0	1215
50.0	1500

$$P_v = 0.5 \rho V^2 = 0.60 V^2 \text{ Pa for air at } 20^\circ\text{C}$$

PRESSURE LOSS - CIRCULAR METAL DUCT

DRY AIR at 20°C and 101.325kPa




CIRCULAR EQUIVALENT OF RECTANGULAR DUCTS FOR EQUAL PRESSURE DROP

		Rectangular Duct Side, mm																														
		100	125	150	175	200	225	250	275	300	350	400	450	500	550	600	650	700	750	800	900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	
100	109																															
125	122	137																														
150	133	150	164																													
175	143	161	177	191																												
200	152	172	189	204	219																											
225	161	181	200	216	232																											
250	169	190	210	228	244																											
275	179	199	220	238	256																											
300	183	207	229	248	266																											
350	195	222	245	267	286																											
400	207	235	260	283	305																											
450	217	247	274	299	321																											
500	227	258	287	313	337																											
550	236	269	299	326	352																											
600	245	279	310	339	365																											
650	253	289	321	351	378																											
700	261	298	331	362	391																											
750	268	306	341	373	402																											
800	275	314	350	383	414																											
900	289	330	367	402	435																											
1000	301	344	384	420	454																											
1100	313	358	399	437	473																											
1200	324	370	413	453	490																											
1300	334	382	426	468	506																											
1400	344	394	439	482	522																											
1500	353	404	452	495	536																											
1600	362	415	463	508	551																											
1700	371	425	475	521	564																											
1800	379	434	485	533	577																											
1900	387	442	495	544	590																											
2000	395	450	505	554	602																											
2100	403	458	515	566	614																											
2200	411	466	525	578	623																											
2300	419	474	535	589	632																											
2400	427	482	545	600	641																											
2500	435	490	555	612	653																											
2600	443	500	565	625	666																											
2700	451	508	575	638	679																											
2800	459	516	585	651	692																											
2900	467	524	595	664	705																											

Refer: Eqn. 3-110e of AIRAH DA3

BENDS

FITTING No. 001 RECTANGULAR RADIUS BEND



R = throat radius

ASPECT RATIO H/W	RADIUS RATIO R/W			
	0.25	0.5	1.0	1.5
0.25	0.57	0.27	0.22	0.20
0.5	0.52	0.25	0.20	0.18
0.75	0.48	0.23	0.19	0.16
1.0	0.44	0.21	0.17	0.15
1.5	0.40	0.19	0.15	0.14
2.0	0.36	0.18	0.14	0.13
3.0	0.33	0.18	0.14	0.13
4.0	0.40	0.19	0.15	0.14
5.0	0.42	0.20	0.16	0.14
6.0	0.43	0.21	0.17	0.15
8.0	0.44	0.21	0.17	0.15


BEND ANGLE θ	BEND ANGLE CORRECTION
10	0.31
30	0.45
45	0.60
60	0.78
75	0.90
90	1.00
110	1.13
130	1.20
150	1.28
180	1.40

ENVE-HVRA

$k_t = k'_t = k_{Re}$ k_{Re} = Reynolds No. correction.

$k_t \times 10^{-4}$	1.0	2.0	3.0	4.0	6.0	8.0	10.0	14.0	>20.0
k_{Re}	2.0	1.77	1.64	1.56	1.46	1.38	1.30	1.15	1.0

FITTING No. 002 RECTANGULAR RADIUS BEND WITH 1 SPLITTER



RADIUS RATIO R/W	ASPECT RATIO H/W										
	0.25	0.5	1.0	1.5	2.0	3.0	4.0	5.0	6.0	7.0	8.0
0.05	0.52	0.40	0.43	0.49	0.55	0.66	0.75	0.84	0.93	1.0	1.1
0.10	0.36	0.27	0.25	0.28	0.30	0.35	0.39	0.42	0.46	0.49	0.52
0.15	0.28	0.21	0.18	0.19	0.20	0.22	0.25	0.26	0.28	0.30	0.32
0.20	0.22	0.16	0.14	0.14	0.15	0.16	0.17	0.18	0.19	0.20	0.21
0.25	0.18	0.13	0.11	0.11	0.11	0.12	0.13	0.14	0.14	0.15	0.15
0.30	0.15	0.11	0.09	0.09	0.09	0.09	0.10	0.10	0.11	0.11	0.12
0.35	0.13	0.09	0.08	0.07	0.07	0.08	0.08	0.08	0.08	0.09	0.09
0.40	0.11	0.08	0.07	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07
0.45	0.10	0.07	0.06	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06
0.50	0.09	0.06	0.05	0.05	0.04	0.04	0.04	0.05	0.05	0.05	0.05


R = throat radius

R_1 = splitter vane radius = R/CR

Bend Angle correction as for Fitting No. 001

ASHRAES

FITTING No. 004 RECTANGULAR RADIUS BEND WITH 2 SPLITTERS




RADIUS RATIO R/W	ASPECT RATIO H/W										
	0.25	0.5	1.0	1.5	2.0	3.0	4.0	5.0	6.0	7.0	8.0
0.05	0.26	0.20	0.22	0.25	0.28	0.33	0.37	0.41	0.45	0.48	0.51
0.10	0.17	0.13	0.11	0.12	0.13	0.15	0.16	0.17	0.19	0.20	0.21
0.15	0.12	0.09	0.08	0.08	0.08	0.09	0.10	0.10	0.11	0.11	0.11
0.20	0.09	0.07	0.06	0.05	0.06	0.06	0.06	0.06	0.07	0.07	0.07
0.25	0.08	0.05	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05
0.30	0.06	0.04	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04

R = throat radius

R_1 = splitter #1 radius = R/CR R_2 = splitter #2 radius = R/CR²

Bend Angle correction as for Fitting No. 001

FITTING No. 006 RECTANGULAR RADIUS BEND WITH 3 SPLITTERS



RADIUS RATIO R/W	ASPECT RATIO H/W										
	0.25	0.5	1.0	1.5	2.0	3.0	4.0	5.0	6.0	7.0	8.0
0.05	0.11	0.10	0.12	0.13	0.14	0.16	0.18	0.19	0.21	0.22	0.23
0.10	0.07	0.05	0.06	0.06	0.06	0.07	0.07	0.08	0.08	0.08	0.09

R = throat radius

R_1 = splitter #1 radius = R/CR, R_2 = splitter #2 radius = R/CR²,


R_3 = splitter #3 radius = R/CR³,

Bend Angle correction as for Fitting No. 001

Total Loss Coefficients for Duct Fittings (k_t based on V_u)

BENDS (cont.)


FITTING No. 003 RECTANGULAR MITRE BEND WITH SINGLE SKIN TURNING VANES



SPACING (mm)	k_T
40	0.12
60	0.15
80	0.18
100	0.25
> 100	0.30

ASHRAES/NVKA

FITTING No. 011 CIRCULAR RADIUS BEND



RADIUS RATIO R/D	k_T
0.25	0.45
0.50	0.34
1.0	0.24
1.5	0.23
2.5	0.22

Bend Angle correction as for Fitting No. 001

IRVE


FITTING No. 005 RECTANGULAR MITRE BEND WITH SINGLE SKIN TURNING VANE PLUS TRAILING EDGE EXTENSION

Pressure drop as for Fitting No. 003 but no interaction on next fitting

FITTING No. 007 RECTANGULAR MITRE BEND WITH DOUBLE SKIN TURNING VANES (EMBOSSED VANE RUNNER)

Pressure drop as for Fitting No. 003 but no interaction on next fitting

FITTING No. 012 CIRCULAR THREE PIECE BEND




RADIUS RATIO R/D	k_T
0.25	0.58
0.50	0.46
1.0	0.40
1.5	0.42
2.5	0.46

Bend Angle correction as for Fitting No. 001

IRVE

FITTING No. 013 CIRCULAR FOUR PIECE BEND




RADIUS RATIO R/D	k_T
0.25	0.56
0.5	0.42
1.0	0.34
1.5	0.32
2.5	0.34

Bend Angle correction as for Fitting No. 001

IRVE

FITTING No. 014 CIRCULAR FIVE PIECE BEND




RADIUS RATIO R/D	k_T
0.25	0.50
0.5	0.36
1.0	0.30
1.5	0.26
2.5	0.26

Bend Angle correction as for Fitting No. 001

IRVE

FITTING No. 021 RECTANGULAR MITRE BEND WITHOUT BUFFERS




ASPECT RATIO H/W	k_T	BEND ANGLE	CORRECTION
0.25	1.30	90	1.0
0.5	1.27	75	0.67
1.0	1.19	60	0.46
2.0	1.07	45	0.28
4.0	0.92	30	0.13
6.0	0.85	20	0.06
8.0	0.81		

ASHRAES

U.S.A.E.C.

FITTING No. 022 RECTANGULAR MITRE BEND WITH BUFFERS



ASPECT RATIO H/W	k_T
0.25	1.57
0.5	1.52
1.0	1.43
2.0	1.29
4.0	1.10
6.0	1.02
8.0	0.98

U.S.A.E.C.

Fitting Angle connection as for Fitting No. 021

$k_T = k_T + k_{Re}$ k_{Re} = Reynolds No. correction

$k_{Re} \times 10^{-4}$	1.0	2.0	3.0	4.0	6.0	8.0	10.0	≥ 14.0
k_{Re}	1.40	1.26	1.19	1.14	1.09	1.06	1.04	1.0


$k_T = k_T + k_{Re}$ k_{Re} = Reynolds No. correction

$k_{Re} \times 10^{-4}$	1.0	2.0	3.0	4.0	6.0	8.0	10.0	≥ 14.0
k_{Re}	1.40	1.26	1.19	1.14	1.09	1.06	1.04	1.0


Total Loss Coefficients for Duct Fittings (k_T based on V_0)

BENDS AND TEES


FITTING No. 023 CIRCULAR MITRE BEND



FITTING No. 024 CIRCULAR MITRE BEND WITH THROAT CORNER




FITTING No. 025 CIRCULAR MITRE BEND WITH REEL CORNER




FITTING No. 1ab TEES OR 2ab TEES WITH SPLITTER DAMPERS

'ab' denotes bend number in flow path being considered. Loss coefficient k_T is as for single bend when $V_U = V_D$. If splitter damper included, add loss coefficient for single blade damper fully open ($k_{TD} = 0.08$).


e.g. No. 201 In both flow paths



No. 203 In both flow paths




FITTING No. 100 CIRCULAR WYE



EXPANSIONS & CONTRACTIONS

FITTING No. 301 ABRUPT EXPANSION




Note: For short length of downstream duct $k_T = 1.0$

k_T based on V_U

AREA RATIO A_U/A_D	k_T
0.2	0.54
0.25	0.56
0.3	0.49
0.35	0.43
0.4	0.36
0.45	0.30
0.5	0.25
0.55	0.20
0.6	0.16
0.65	0.12
0.7	0.09
0.75	0.06

ASHRAE


FITTING No. 302 ABRUPT CONTRACTION



AREA RATIO A_U/A_D	k_T
1.0	0
1.25	0.05
1.5	0.12
1.75	0.18
2.0	0.22
2.5	0.28
3.0	0.32
3.5	0.34
4.0	0.37
6.0	0.42
10.0	0.46

HVAC

FITTING No. 303 GRADUAL RECTANGULAR EXPANSION AND FITTING No. 304 GRADUAL ECCENTRIC (ONE SIDED) RECTANGULAR EXPANSION



k_T based on V_U

θ°	V_D/V_U				
	0.2	0.3	0.4	0.5	0.6
10	0.20	0.15	0.12	0.08	0.06
20	0.39	0.30	0.22	0.15	0.10
30	0.52	0.40	0.29	0.20	0.13
40	0.67	0.51	0.38	0.26	0.17
50	0.70	0.54	0.40	0.29	0.18

Values assume long downstream duct.
For asymmetrical configurations take θ as the mean angle.
For 1 in 7 expansion $\theta = 18^\circ$ for concentric expansion and 8° for eccentric expansion.


θ°	CORRECTION MULTIPLIER FOR ECC. EXPANSION
5	1.23
10	1.69
15	2.23
20	2.00
25	1.61
30	1.31
35	1.25
40	1.20
45	1.10

HVAC-HVAC

Total Loss Coefficients for Duct Fittings (k_T based on V_D except for expansions where k_T based on V_U)

EXPANSIONS & CONTRACTIONS

FITTING No. 305 GRADUAL CIRCULAR EXPANSION AND FITTING No. 306 GRADUAL ECCENTRIC CIRCULAR EXPANSION



K_T based on V_D

θ°	0.2	0.3	0.4	0.5	0.6
10	0.18	0.13	0.11	0.08	0.06
20	0.31	0.25	0.18	0.13	0.09
30	0.41	0.31	0.23	0.16	0.10
40	0.52	0.40	0.33	0.23	0.15
50	0.70	0.52	0.39	0.27	0.18


Values assume long downstream duct.
For 1 in 7 expansion $\theta = 10^\circ$ for concentric expansion and θ° for eccentric expansion.

θ°	CONTRACTION MULTIPLIER FOR ECC. EXPANSION
5	1.23
10	1.69
15	2.23
20	2.00
25	1.61
30	1.31
35	1.25
40	1.20
45	1.10

HYA-111E

FITTING No. 307 GRADUAL RECTANGULAR CONTRACTION AND

FITTING No. 309 GRADUAL CIRCULAR CONTRACTION




θ°	k_T
15	0.008
30	0.02
45	0.04
60	0.07

For asymmetrical configurations take θ as the mean angle.
For 1 in 4 contraction $\theta = 28^\circ$

HYA

FITTING No. 308 GRADUAL RECTANGULAR ECCENTRIC (ONE SIDED)

CONTRACTION AND FITTING No. 310 GRADUAL CIRCULAR ECCENTRIC CONTRACTION




θ°	k_T
15	0.014
30	0.07
45	0.20
60	0.40

For 1 in 4 contraction $\theta = 14^\circ$

HYA

AREA TRANSITIONS

FITTING No. 311 CONSTANT VELOCITY AREA TRANSITION




$k_T = 0.15$

Conditions: $V_D = V_u$, $\theta = 15^\circ$

ASHRAE

FITTING No. 312 BEND WITH EXPANDING OR CONTRACTING FLOW



H_u/W_u	W_D/W_u					
	0.6	0.8	1.2	1.4	1.6	2.0
0.25	1.8	1.4	1.1	1.1	1.1	1.1
1.0	1.7	1.4	1.0	0.95	0.90	0.84
4.0	1.5	1.1	0.81	0.76	0.72	0.66
6.0	1.5	1.0	0.69	0.63	0.60	0.55


$k_T = k_T + k_{sa}$

k_{sa} as for Fitting No. 021

DAMPERS

FITTING No. 321 SINGLE BLADE BUTTERFLY DAMPER

FITTING No. 324 SINGLE BLADE FIRE DAMPER



APPROXIMATE ANGLE OF BLADE	k_T
0	0.08
10	0.26
15	0.54
20	0.90
30	2.8
40	7.0
50	20.0

FITTING No. 322 OPPOSED MULTI-BLADE DAMPER

FITTING No. 323 PARALLEL MULTI-BLADE DAMPERS

FITTING No. 325 MULTI-BLADE FIRE DAMPERS


APPROXIMATE ANGLE OF BLADE	k_T (No. 323)	k_T (No. 322 & 325)
0	0.25	0.25
10	0.52	0.66
15	0.75	1.1
20	1.2	1.85
30	1.75	4.7
40	3.2	11.6
50	5.0	33.0

HYA

Total Loss Coefficients for Duct Fittings (k_T based on V_D except for expansions where K_T based on V_u)

FAN DISCHARGES


FITTING No. 331 PLANE SYMMETRIC DIFFUSER AT FAN DISCHARGE



θ deg	AREA RATIO A_D/A_U					
	1.5	2.0	2.5	3.0	3.5	4.0
10	0.05	0.07	0.09	0.10	0.11	0.11
15	0.06	0.09	0.11	0.13	0.13	0.14
20	0.07	0.10	0.13	0.15	0.16	0.16
25	0.08	0.13	0.16	0.19	0.21	0.23
30	0.16	0.24	0.29	0.32	0.34	0.35
35	0.24	0.34	0.39	0.44	0.48	0.50

ASHRAES


FITTING No. 332 PLANE ASYMMETRIC DIFFUSER AT FAN DISCHARGE



θ deg	AREA RATIO A_D/A_U					
	1.5	2.0	2.5	3.0	3.5	4.0
10	0.08	0.09	0.10	0.10	0.11	0.11
15	0.10	0.11	0.12	0.13	0.14	0.15
20	0.12	0.14	0.15	0.16	0.17	0.18
25	0.15	0.18	0.21	0.23	0.25	0.26
30	0.18	0.25	0.30	0.33	0.35	0.35
35	0.21	0.31	0.38	0.41	0.43	0.44

ASHRAES


FITTING No. 333 ECCENTRIC PLANE ASYMMETRIC DIFFUSER AT FAN DISCHARGE



θ deg	AREA RATIO A_D/A_U					
	1.5	2.0	2.5	3.0	3.5	4.0
10	0.05	0.08	0.11	0.13	0.13	0.14
15	0.06	0.10	0.12	0.14	0.15	0.15
20	0.07	0.11	0.14	0.15	0.16	0.16
25	0.09	0.14	0.18	0.20	0.21	0.22
30	0.13	0.18	0.23	0.26	0.28	0.29
35	0.15	0.23	0.28	0.33	0.35	0.36

ASHRAES


FITTING No. 334 OFFSET PLANE DIFFUSER AT FAN DISCHARGE



θ deg	AREA RATIO A_D/A_U					
	1.5	2.0	2.5	3.0	3.5	4.0
10	0.25	0.52	0.14	0.14	0.14	0.14
15	0.29	0.60	0.16	0.17	0.18	0.18
20	0.43	0.88	0.24	0.26	0.28	0.30
25	0.65	1.28	0.35	0.37	0.39	0.40
30	0.81	1.68	0.46	0.49	0.51	0.51
35	1.00	2.16	0.61	0.64	0.66	0.66

ASHRAES

FITTING No. 335 PYRAMIDAL DIFFUSER AT FAN DISCHARGE




θ deg	AREA RATIO A_D/A_U					
	1.5	2.0	2.5	3.0	3.5	4.0
10	0.10	0.18	0.21	0.23	0.24	0.25
15	0.23	0.33	0.38	0.40	0.42	0.44
20	0.31	0.43	0.48	0.53	0.56	0.58
25	0.36	0.49	0.55	0.58	0.62	0.64
30	0.42	0.53	0.59	0.64	0.67	0.69

ASHRAES

Total Loss Coefficients for Duct Fittings (k_f based on V_D)


DIVIDED FLOW FITTINGS

FITTING NO. 401 RECTANGULAR 90° TAKE-OFF OR FITTING NO. 411 CIRCULAR 90° TAKE-OFF




VELOCITY RATIO V_B/V_D	BRANCH PATH				
	AREA RATIO A_B/A_D				
	0.2	0.3	0.5	0.7	1.0
0.4	9.69	8.75	5.88	5.94	5.31
0.6	4.56	4.31	3.33	2.64	2.5
0.8	3.13	2.81	2.03	1.72	1.72
1.0	2.40	2.00	1.40	1.25	1.25
1.2	1.86	1.74	1.11	0.97	-
1.5	1.56	1.56	0.84	-	-
2.0	1.50	1.50	0.88	-	-
2.5	1.28	1.44	-	-	-

STRAIGHT THROUGH	
VELOCITY RATIO V_D/V_D	k_T
0.4	0.12
0.5	0.09
0.6	0.06
0.7	0.03
0.8-1.0	0




FITTING NO. 402 RECTANGULAR SWEEP TAKE-OFF



BRANCH PATH	
VELOCITY RATIO V_B/V_D	k_T
0.6	1.70
0.7	0.90
0.8	0.50
0.9	0.35
1.0	0.26
1.1	0.25
1.2	0.30

STRAIGHT THROUGH	
VELOCITY RATIO V_D/V_D	k_T
0.6	0.78
0.7	0.41
0.8	0.20
0.9	0.12
1.0	0.06
1.1	0.05
1.2	0.05

FITTING NO. 403 RECTANGULAR RADIUS 90° TAKE-OFF WITH SPLITTER DAMPER




BRANCH: Take as equivalent to 90° rectangular take-off with 45° branch.

STRAIGHT THROUGH: As for Fitting No. 405 & 406


ASHRAE 91

FITTING NO. 404 RECTANGULAR SWEEP WITH SPLITTER DAMPER



For both the branch and the straight through path take as equivalent to loss coefficient of sweep take-off (fitting no. 402) plus loss coefficient of single blade damper fully open (0.60). If the splitter damper is used for balancing (not recommended) then the pressure drop absorbed by the splitter is added to the fitting loss in the path in which the damper restricts the flow.


FITTING NO. 405 RECTANGULAR 90° TAKE-OFF WITH SCOOP DAMPER



VELOCITY RATIO V_B/V_U	AREA RATIO A_B/A_D		
	0.2	0.3	0.5
0.4	3.75	3.94	4.30
0.6	2.08	2.19	2.28
0.8	1.86	1.63	1.41
1.0	1.12	1.41	1.21
1.2	0.93	1.03	1.14
1.4	0.87	1.03	1.26
1.6	0.96	0.92	1.27
1.8	0.93	0.93	1.27

Note that for this fitting the velocity ratio is V_B/V_U

FITTING NO. 406 RECTANGULAR 90° TAKE-OFF WITH PIVOTED SCOOP DAMPER




STRAIGHT THROUGH	
VELOCITY RATIO V_D/V_U	k_T
0.2	0.03
0.4	0.04
0.6	0.07
0.8	0.12
1.0	0.13
1.2	0.14
1.4	0.27
1.6	0.30
1.8	0.25

ASHRAE 91

Total Loss Coefficients for Duct Fittings (Branch path k_T based on V_B , straight through on V_D)

DIVIDED FLOW FITTINGS (cont.)

FITTING No. 407 90° RECTANGULAR TAKE-OFF WITH 45° HAUNCH



BRANCH PATH


VELOCITY RATIO V_D/V_U	k_T
0.4	4.4
0.5	2.5
0.6	1.6
0.7	1.0
0.8	0.78
0.9	0.62
1.0	0.55

STRAIGHT THROUGH

VELOCITY RATIO V_D/V_U	k_T
0.4	2.30
0.5	1.00
0.6	0.44
0.7	0.20
0.8	0.09
0.9	0.06
1.0	0.04

ASHRAE

FITTING No. 408 90° RECTANGULAR TAKE-OFF WITH 45° HAUNCH AND SPLITTER DAMPER




BRANCH : Take as equivalent to 45° circular take-off.

STRAIGHT THROUGH : As for Fitting Nos. 405 & 406.

ASHRAE

FITTING No. 409 RECTANGULAR DIVERGING WYE OR FITTING No. 419 CIRCULAR DIVERGING WYE



30° TAKE-OFF

VELOCITY RATIO V_D/V_U	AREA RATIO A_D/A_U				
	0.2	0.3	0.5	0.7	0.8
0.4	-	3.10	2.56	2.44	2.35
0.5	1.60	1.66	1.34	1.22	1.12
0.6	1.03	0.93	0.72	1.64	0.62
0.7	0.70	0.56	0.46	0.38	0.37
0.8	0.49	0.41	0.30	0.28	0.24
0.9	0.36	0.31	0.23	0.19	0.19
1.0	0.26	0.24	0.18	0.16	0.16
1.5	0.26	0.25	0.18	-	-
2.0	0.33	0.33	-	-	-

45° TAKE-OFF

VELOCITY RATIO V_D/V_U	AREA RATIO A_D/A_U				
	0.2	0.3	0.5	0.7	0.8
0.4	-	3.80	3.23	3.09	2.95
0.5	2.24	2.28	1.86	1.70	1.60
0.6	1.56	1.43	1.14	1.03	0.98
0.7	1.14	0.99	0.81	0.70	0.66
0.8	0.88	0.78	0.59	0.51	0.49
0.9	0.69	0.63	0.48	0.41	0.40
1.0	0.56	0.52	0.40	0.35	0.35
1.5	0.44	0.30	-	-	-
2.0	0.45	0.45	-	-	-

60° TAKE-OFF

VELOCITY RATIO V_D/V_U	AREA RATIO A_D/A_U				
	0.2	0.3	0.5	0.7	0.8
0.4	-	4.94	4.13	3.90	3.80
0.5	3.08	3.10	2.54	2.34	2.24
0.6	2.24	2.11	1.69	1.54	1.47
0.7	1.73	1.56	1.26	1.11	1.04
0.8	1.38	1.24	0.97	0.84	0.85
0.9	1.14	1.05	0.80	0.69	0.67
1.0	0.96	0.89	0.68	0.60	0.60
1.5	0.71	0.67	0.44	-	-
2.0	0.83	0.65	-	-	-

90° TAKE-OFF

VELOCITY RATIO V_D/V_U	AREA RATIO A_D/A_U				
	0.2	0.3	0.5	0.7	0.8
0.4	-	7.25	6.23	5.93	5.76
0.5	8.13	4.60	4.20	3.86	3.72
0.6	3.94	3.72	3.00	2.73	2.61
0.7	3.14	2.94	2.35	2.04	1.93
0.8	2.59	2.44	1.88	1.66	1.52
0.9	2.20	2.12	1.60	1.40	1.38
1.0	1.90	1.80	1.40	1.20	1.20
1.5	1.28	-	-	-	-
2.0	-	-	-	-	-

STRAIGHT THROUGH


VELOCITY RATIO V_D/V_U	0.1	0.4	0.5	0.6	0.8	1.0
k_T	1.89	0.81	0.36	0.17	0.03	0.0

ASHRAE

total Loss Coefficients for Duct Fittings (Branch path k_T based on V_B , straight through on V_D)

DIVIDED FLOW FITTINGS (cont.)

FITTING No. 412 CIRCULAR LONG CONE TAKE-OFF



BRANCH PATH		STRAIGHT THROUGH	
VELOCITY RATIO V_b/V_u	k_T	VELOCITY RATIO V_b/V_u	k_T
0.4	5.2	0.4	0.12
0.5	3.1	0.5	0.09
0.6	1.9	0.6	0.06
0.7	1.3	0.7	0.03
0.8	0.89	0.8-1.0	0
0.9	0.64		
1.0	0.48		
1.2	0.32		
1.4	0.25		
2.0	0.25		


ASHRAE

FITTING No. 413 CIRCULAR SHORT CONE TAKE-OFF

BRANCH PATH		STRAIGHT THROUGH	
VELOCITY RATIO V_b/V_u	k_T	VELOCITY RATIO V_b/V_u	k_T
0.4	5.0	0.4	0.12
0.5	3.0	0.5	0.09
0.6	2.0	0.6	0.06
0.7	1.5	0.7	0.03
0.8	1.2	0.8-1.0	0
0.9	1.0		
1.0	0.8		
1.2	0.6		
1.4	0.5		
2.0	0.3		

HYRA-ASHRAE

FITTING No. 414 ANGLED CIRCULAR BRANCH TAKE-OFF



45° TAKE-OFF

BRANCH PATH		STRAIGHT THROUGH	
VELOCITY RATIO V_b/V_u	k_T	VELOCITY RATIO V_b/V_u	k_T
0.4	4.0	0.4	0.12
0.5	2.2	0.5	0.09
0.6	1.5	0.6	0.06
0.7	1.0	0.7	0.03
0.8	0.7	0.8-1.0	0
0.9	0.55		
1.0	0.4		


HYRA

60° TAKE-OFF

BRANCH PATH		STRAIGHT THROUGH	
VELOCITY RATIO V_b/V_u	k_T	VELOCITY RATIO V_b/V_u	k_T
0.4	4.2	0.4	0.12
0.5	2.6	0.5	0.09
0.6	1.9	0.6	0.06
0.7	1.4	0.7	0.03
0.8	1.1	0.8-1.0	0
0.9	0.82		
1.0	0.65		
1.2	0.56		
1.4	0.50		
2.0	0.49		

ASHRAE

FITTING No. 421 90° RECTANGULAR MAIN AND TAP




VELOCITY RATIO V_b/V_u	AREA RATIO A_b/A_D			
	0.2	0.3	0.4	0.5
0.4	6.60	6.46	6.39	6.31
0.6	3.03	2.92	2.89	2.92
0.8	1.86	1.86	1.81	1.75
1.0	1.80	1.30	1.36	1.27
1.2	1.14	1.26	1.09	1.15
1.4	0.98	1.18	1.14	0.99
1.6	0.88	1.14	0.98	0.86
1.8	0.90	1.12	0.89	0.79

ASHRAE85

STRAIGHT THROUGH :

As for Fitting Nos. 401 & 411 HYRA

FITTING No. 422 90° RECTANGULAR MAIN WITH CIRCULAR TAP



VELOCITY RATIO V_b/V_u	AREA RATIO A_b/A_D			
	0.2	0.3	0.4	0.5
0.4	6.24	6.39	6.54	6.69
0.6	3.14	3.08	3.03	3.00
0.8	1.97	1.93	1.75	1.77
1.0	1.38	1.20	1.23	1.26
1.2	1.05	0.95	0.95	1.03
1.4	0.83	0.76	0.82	0.87
1.6	0.77	0.68	0.69	0.73
1.8	0.67	0.63	0.61	0.64

STRAIGHT THROUGH :


As for Fitting Nos. 401 & 411

HYRA

Total Loss Coefficients for Duct Fittings (Branch path k_T based on V_b , straight through on V_u)

DIVIDED FLOW FITTINGS (cont.)

FITTING No. 423 90° RECTANGULAR MAIN AND TAP WITH DAMPER




BRANCH PATH

VELOCITY RATIO V_b/V_u	AREA RATIO A_b/A_o			
	0.2	0.3	0.4	0.5
0.4	2.69	3.06	3.44	3.81
0.6	1.23	1.35	1.43	1.50
0.8	0.65	0.79	0.94	0.83
1.0	0.57	0.77	0.73	0.68
1.2	0.50	0.64	0.73	0.58
1.4	0.35	0.43	0.73	0.60
1.6	0.50	0.43	0.77	0.57
1.8	0.88	0.65	0.82	0.59

STRAIGHT THROUGH :

As for Fitting Nos. 405 & 406
ASHRAES

FITTING No. 427 90° RECTANGULAR MAIN AND TAP WITH 45° RAINCH



BRANCH PATH


VELOCITY RATIO V_b/V_u	AREA RATIO A_b/A_o			
	0.2	0.3	0.4	0.5
0.4	5.08	5.04	5.03	4.94
0.6	2.12	2.03	1.97	1.94
0.8	1.17	1.12	1.07	1.03
1.0	0.98	0.85	0.79	0.74
1.2	0.78	0.84	0.74	0.60
1.4	0.84	0.68	0.70	0.47
1.6	0.61	0.63	0.56	0.43
1.8	0.54	0.47	0.49	0.36

ASHRAES

STRAIGHT THROUGH :

As for Fitting Nos. 401 & 411
HVAC

FITTING No. 428 90° RECTANGULAR MAIN AND TAP WITH 45° RAINCH PLUS DAMPER



BRANCH PATH

VELOCITY RATIO V_b/V_u	AREA RATIO A_b/A_o			
	0.2	0.3	0.4	0.5
0.4	2.69	3.06	3.44	3.81
0.6	1.23	1.35	1.43	1.50
0.8	0.65	0.79	0.94	0.83
1.0	0.57	0.77	0.73	0.68
1.2	0.50	0.64	0.73	0.58
1.4	0.50	0.63	0.73	0.60
1.6	0.50	0.63	0.77	0.57
1.8	0.58	0.65	0.82	0.59

ASHRAES

STRAIGHT THROUGH :

As for Fitting Nos. 405 & 406
ASHRAES

PLENUM FITTINGS

PLENUM ENTRIES

$k_T = k_1$ is loss coefficient for abrupt expansion with velocity ratio V_T/V_U where k_1 = loss coefficient of equivalent duct discharge k_T based on V_U .

FITTING No. 501 RECTANGULAR OR CIRCULAR ABRUPT ENTRY




$k_1 = 1.0$

FITTING No. 502 RECTANGULAR FLARED ENTRY



k_1 = value for rectangular flared duct discharge

FITTING No. 503 CIRCULAR FLARED ENTRY



k_1 = value for circular flared duct discharge

PLENUM EXITS

$k_T = (k_1/0.5)$ is loss coefficient for abrupt contraction with velocity ratio V_D/V_P where k_1 = loss coefficient of equivalent duct entry

FITTING No. 511 RECTANGULAR OR CIRCULAR ABRUPT EXIT




$k_1 = 0.5$

FITTING No. 512 RECTANGULAR FLARED EXIT




k_1 = value for rectangular flared duct entry

FITTING No. 513 CIRCULAR FLARED EXIT



k_1 = value for circular flared duct entry

FITTING No. 514 BELLMOUTH EXIT




k_1 = value for bellmouth duct entry

Total Loss Coefficients for Duct Fittings (Branch path k_T based on V_b , straight through on V_D)

COMBINED FLOW FITTINGS

FITTING No. 601 RECTANGULAR COMBINED FLOW



BRANCH PATH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C				
	0.2	0.3	0.5	0.7	1.0
0.4	0.15	0.2	0.27	0.35	0.45
0.5	0.20	0.27	0.40	0.48	0.52
0.6	0.25	0.35	0.50	0.56	0.54
1.0	0.30	0.42	0.60	0.63	0.55
1.2	0.35	0.50	0.67	0.67	-
1.5	0.45	0.60	0.77	-	-
2.0	0.60	0.75	0.90	-	-
2.5	0.70	0.90	-	-	-


NVRA

STRAIGHT THROUGH

VELOCITY RATIO V_u/V_C	K_T
0.4	0.12
0.5	0.09
0.6	0.06
0.7	0.03
0.8-1.0	0

NVRA

FITTING No. 602 RADIUSED RECTANGULAR COMBINED FLOW



BRANCH PATH


VELOCITY RATIO V_B/V_C	AREA RATIOS								
	A_B/A_u	0.25	0.33	0.50	0.67	1.0	1.0	1.33	2.0
	A_B/A_C	0.25	0.25	0.50	0.50	0.50	1.0	1.0	1.0
0.2	-	-	-	-0.50	-1.0	-2.2	-0.30	-0.80	-1.40
0.4	-	-0.50	-1.20	-0.20	-0.60	-1.5	-0.40	-0.20	-0.10
0.6	-	-0.25	-0.80	0	-0.20	-0.95	0.21	0.16	0
0.8	-	0	-0.40	0.25	-0.10	-0.50	0.36	0.32	0.25
1.0	-	0.25	0	0.45	0.30	0	0.48	0.44	0.35
1.4	-	0.85	1.00	1.00	1.00	0.80	-	-	-
1.8	-	1.70	2.30	2.00	2.00	1.90	-	-	-
2.0	-	2.20	3.00	-	-	-	-	-	-
2.4	-	3.70	4.80	-	-	-	-	-	-

STRAIGHT THROUGH

VELOCITY RATIO V_B/V_C	AREA RATIOS							
	A_u/A_C	0.75	1.0	0.75	0.5	1.0	0.75	0.5
	A_B/A_C	0.25	0.5	0.5	0.5	1.0	1.0	1.0
0.2		0.22	0.13	0.27	1.10	0.24	0.36	0.87
0.4		0.30	0.16	0.35	1.10	0.26	0.35	0.68
0.6		0.33	0.10	0.32	0.90	0.18	0.18	0.40
0.8		0.30	0	0.25	0.65	0	-0.08	0.08
1.0		0.26	-0.08	0.12	0.35	-0.24	-0.36	-0.17
1.4		0.06	-0.27	-0.23	-0.40			
1.8		-0.28	-0.48	-0.58	-1.30			
2.0		-0.45						
2.4		-0.92						

ASHRAES

FITTING No. 611 CIRCULAR 90° COMBINED FLOW WITH NO AREA CHANGE



BRANCH PATH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C						
	0.1	0.2	0.3	0.4	0.6	0.8	1.0
0.4	-0.04	-0.5	-0.37	-0.20	0	0.17	0.37
0.5	-0.03	-0.37	-0.17	-0.02	0.25	0.40	0.42
0.6	-0.02	-0.15	0.03	0.16	0.41	0.47	0.57
0.7	0	0.07	0.25	0.35	0.56	0.61	0.72
0.8	0.12	0.28	0.50	0.54	0.64	0.77	0.86
0.9	0.26	0.50	0.75	0.74	0.78	0.92	0.99
1.0	0.40	0.72	1.0	0.94	0.92	1.1	1.1
1.5	1.1	2.3	2.7	1.6	1.8	-	-
2.0	3.8	4.3	4.7	2.7	-	-	-
2.5	6.5	6.8	7.1	4.0	-	-	-
3.0	9.3	9.7	9.7	-	-	-	-
4.0	16.0	17.0	-	-	-	-	-
5.0	26.0	26.0	-	-	-	-	-

STRAIGHT THROUGH


VELOCITY RATIO V_u/V_C	K_T
0.1	0.39
0.2	0.60
0.3	0.59
0.4	0.57
0.5	0.53
0.6	0.46
0.7	0.38
0.8	0.27
0.9	0.19

ASHRAES

Total Loss Coefficients for Duct Fittings (K_T based on V_C for both paths)

COMBINED FLOW FITTINGS (cont.)

FITTING No. 612 ANGLED CIRCULAR COMBINED FLOW



$\theta = 30^\circ$

AREA RATIOS A_u/A_c A_b/A_c		AIR FLOW RATIO Q_b/Q_u																			
		BRANCH PATH										STRAIGHT THROUGH									
		0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0
0.3	0.2	-2.4	-1.1	1.8	3.4	4.8	6.0	7.1	8.0	8.9	9.7	4.5	2.8	1.5	0.56	-0.17	-0.74	-1.2	-1.6	-1.9	-2.1
	0.3	-2.8	-1.3	0.14	0.72	1.4	2.0	2.4	2.8	3.2	3.5	4.6	3.1	2.0	1.2	0.57	0.08	-0.30	-0.82	-1.1	-1.4
	0.4	-1.4	-0.61	2.3	3.8	5.2	6.3	7.3	8.3	9.1	9.8	1.6	0.85	0.16	-0.43	-0.92	-1.3	-1.7	-2.1	-2.4	
	0.5	-1.8	-0.54	0.42	1.2	1.8	2.3	2.7	3.1	3.4	3.7	1.7	1.1	0.58	0.13	-0.24	-0.56	-0.82	-1.1	-1.3	-1.4
0.4	0.2	-1.9	-0.89	-0.17	0.56	0.76	1.1	1.3	1.5	1.7	1.9	1.8	1.3	0.80	0.42	0.11	-0.15	-0.37	-0.55	-0.72	-0.86
	0.3	-0.82	0.97	2.6	4.0	5.3	6.4	7.4	8.3	9.1	9.9	0.67	0.18	-0.33	-0.79	-1.2	-1.5	-1.8	-2.1	-2.3	-2.5
	0.4	-1.2	-0.19	0.71	1.4	2.0	2.5	2.9	3.3	3.6	3.9	0.75	0.42	0.07	-0.25	-0.54	-0.80	-1.0	-1.2	-1.4	-1.5
	0.5	-1.4	-0.54	0.06	0.50	0.85	1.1	1.3	1.5	1.7	1.8	0.80	0.55	0.28	0.03	-0.20	-0.40	-0.57	-0.73	-0.86	-0.98
0.5	0.2	-1.4	-0.66	-0.15	0.21	0.48	0.68	0.84	0.97	1.1	1.2	0.82	0.62	0.41	0.20	0.02	-0.15	-0.29	-0.42	-0.53	-0.63
	0.3	-0.32	1.2	2.7	4.1	5.3	6.4	7.4	8.3	9.1	9.9	0.26	-0.11	-0.54	-0.95	-1.3	-1.6	-1.9	-2.1	-2.4	-2.5
	0.4	-0.93	0.06	0.85	1.5	2.1	2.6	3.0	3.4	3.7	4.0	0.34	0.13	-0.14	-0.42	-0.67	-0.90	-1.1	-1.3	-1.4	-1.6
	0.5	-1.1	-0.37	0.16	0.55	0.86	1.1	1.3	1.5	1.6	1.8	0.39	0.25	0.06	-0.14	-0.33	-0.51	-0.66	-0.80	-0.93	-1.0
0.6	0.2	-1.1	-0.49	-0.06	0.25	0.48	0.66	0.79	0.90	1.0	1.1	0.41	0.32	0.18	0.03	-0.12	-0.26	-0.38	-0.50	-0.60	-0.69
	0.3	-1.2	-0.55	-0.15	0.12	0.31	0.45	0.56	0.65	0.71	0.77	0.43	0.37	0.26	0.14	0.02	-0.09	-0.19	-0.29	-0.37	-0.45
	0.4	-0.27	1.3	2.7	4.0	5.2	6.3	7.3	8.2	9.0	9.7	-0.01	-0.30	-0.67	-1.1	-1.4	-1.7	-2.0	-2.2	-2.4	-2.6
	0.5	-0.67	0.18	0.90	1.5	2.0	2.5	2.9	3.3	3.6	4.0	0.07	-0.07	-0.29	-0.58	-0.76	-0.97	-1.2	-1.3	-1.5	-1.6
0.8	0.2	-0.85	-0.27	0.16	0.49	0.75	0.97	1.2	1.3	1.4	1.6	0.11	0.05	-0.09	-0.26	-0.42	-0.58	-0.72	-0.85	-0.97	-1.1
	0.3	-0.90	-0.40	-0.07	0.18	0.36	0.50	0.61	0.70	0.78	0.84	0.14	0.12	0.03	-0.09	-0.21	-0.34	-0.45	-0.55	-0.64	-0.73
	0.4	-0.92	-0.46	-0.16	0.04	0.18	0.29	0.37	0.44	0.49	0.53	0.15	0.17	0.11	0.02	-0.07	-0.17	-0.26	-0.34	-0.42	-0.48
	0.5	-0.91	-0.49	-0.21	-0.03	0.10	0.19	0.25	0.30	0.34	0.37	0.17	0.21	0.17	0.11	0.03	-0.05	-0.12	-0.19	-0.26	-0.32
1.0	0.2	-0.93	-0.50	-0.24	-0.07	0.05	0.13	0.19	0.23	0.27	0.29	0.17	0.23	0.22	0.17	0.11	0.05	-0.02	-0.07	-0.13	-0.18
	0.3	-0.26	1.2	2.6	3.9	5.1	6.1	7.1	8.0	8.8	9.5	-0.05	-0.33	-0.70	-1.1	-1.4	-1.7	-2.0	-2.2	-2.4	-2.6
	0.4	-0.65	0.12	0.79	1.4	1.9	2.4	2.8	3.1	3.5	3.8	0.03	-0.10	-0.31	-0.55	-0.78	-0.98	-1.2	-1.3	-1.5	-1.6
	0.5	-0.83	-0.34	0.04	0.33	0.58	0.78	0.95	1.1	1.2	1.3	0.07	0.02	-0.12	-0.28	-0.44	-0.59	-0.73	-0.86	-0.98	-1.1
1.0	0.2	-0.89	-0.48	-0.20	0	0.15	0.27	0.37	0.45	0.51	0.57	0.09	0.09	0.01	-0.11	-0.23	-0.35	-0.46	-0.56	-0.65	-0.74
	0.3	-0.91	-0.54	-0.31	-0.14	-0.03	0.06	0.12	0.18	0.22	0.25	0.11	0.14	0.09	0	-0.09	-0.18	-0.27	-0.35	-0.43	-0.50
	0.4	-0.93	-0.59	-0.38	-0.25	-0.16	-0.10	-0.06	-0.03	-0.01	0.01	0.13	0.20	0.19	0.15	0.09	0.03	-0.03	-0.08	-0.14	-0.19
	0.5	-0.93	-0.60	-0.40	-0.28	-0.20	-0.14	-0.11	-0.08	-0.07	-0.06	0.14	0.24	0.25	0.24	0.20	0.16	0.12	0.08	0.04	0

$\theta = 45^\circ$


AREA RATIOS A_u/A_c A_b/A_c		AIR FLOW RATIO Q_b/Q_u																			
		BRANCH PATH										STRAIGHT THROUGH									
		0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0
0.3	0.2	-2.4	-0.01	2.0	3.8	5.3	6.6	7.8	8.9	9.8	11.0	5.3	-0.01	2.0	1.1	0.34	-0.20	-0.61	-0.93	-1.2	-1.4
	0.3	-2.8	-1.2	0.12	1.1	1.9	2.6	3.2	3.7	4.2	4.6	5.4	3.7	2.5	1.6	1.0	0.53	0.16	-0.14	-0.38	-0.58
	0.4	-1.2	0.93	2.8	4.5	5.9	7.2	8.4	9.5	10.0	11.0	1.9	1.1	0.46	-0.07	-0.49	-0.83	-1.1	-1.3	-1.5	-1.7
0.4	0.3	-1.6	-0.27	0.81	1.7	2.4	3.0	3.6	4.1	4.5	4.9	2.0	1.4	0.81	0.42	0.08	-0.20	-0.43	-0.62	-0.78	-0.92
	0.4	-1.8	-0.72	0.07	0.66	1.1	1.5	1.8	2.1	2.3	2.5	2.0	1.5	1.0	0.68	0.39	0.16	-0.04	-0.21	-0.35	-0.47
	0.5	-0.46	1.5	3.3	4.9	6.4	7.7	8.8	9.9	11.0	12.0	0.77	0.34	-0.09	-0.48	-0.81	-1.1	-1.3	-1.5	-1.7	-1.8
0.5	0.3	-0.94	0.25	1.2	2.0	2.7	3.3	3.8	4.2	4.7	5.0	0.85	0.56	0.25	-0.05	-0.27	-0.48	-0.67	-0.82	-0.96	-1.1
	0.4	-1.1	-0.24	0.42	0.92	1.3	1.6	1.9	2.1	2.3	2.5	0.88	0.66	0.43	0.21	0.02	-0.15	-0.30	-0.42	-0.54	-0.64
	0.5	-1.2	-0.38	0.18	0.58	0.88	1.1	1.3	1.5	1.6	1.7	0.91	0.73	0.54	0.36	0.21	0.06	-0.06	-0.17	-0.26	-0.35
0.6	0.2	-0.55	1.3	3.1	4.7	6.1	7.4	8.6	9.6	11.0	12.0	0.30	0	-0.34	-0.67	-0.96	-1.2	-1.4	-1.6	-1.8	-1.9
	0.3	-1.1	0	0.88	1.6	2.3	2.8	3.3	3.7	4.1	4.5	0.37	0.21	-0.02	-0.24	-0.44	-0.63	-0.79	-0.93	-1.1	-1.2
	0.4	-1.2	-0.48	0.10	0.54	0.89	1.2	1.4	1.6	1.8	2.0	0.40	0.31	0.16	-0.1	-0.16	-0.30	-0.43	-0.54	-0.64	-0.73
0.6	0.5	-1.3	-0.62	-0.14	0.21	0.47	0.68	0.85	0.99	1.1	1.2	0.43	0.37	0.26	0.14	0.02	-0.09	-0.20	-0.29	-0.37	-0.45
	0.6	-1.3	-0.69	-0.26	0.06	0.26	0.42	0.57	0.66	0.75	0.82	0.44	0.41	0.33	0.24	0.14	0.03	-0.03	-0.11	-0.18	-0.25
	0.8	0.2	0.06	1.8	3.5	5.1	6.5	7.8	8.9	10.0	11.0	12.0	-0.06	-0.27	-0.66	-1.1	-1.4	-1.6	-1.7	-1.9	-2.0
0.8	0.3	-0.52	0.35	1.1	1.7	2.3	2.8	3.2	3.6	3.9	4.2	0	-0.08	-0.25	-0.43	-0.62	-0.78	-0.93	-1.1	-1.2	-1.3
	0.4	-0.67	-0.05	0.43	0.80	1.1	1.4	1.6	1.8	1.9	2.1	0.04	0.02	-0.08	-0.21	-0.34	-0.46	-0.57	-0.67	-0.77	-0.85
	0.5	-0.75	-0.27	0.05	0.28	0.45	0.58	0.68	0.76	0.83	0.88	0.07	0.12	0.09	0.03	-0.04	-0.11	-0.18	-0.25	-0.31	-0.37
0.8	0.6	-0.77	-0.31	-0.03	0.18	0.32	0.43	0.50	0.56	0.61	0.65	0.08	0.13	0.14	0.10	0.05	-0.01	-0.07	-0.12	-0.17	-0.22
	0.8	-0.78	-0.34	-0.07	0.12	0.24	0.33	0.39	0.44	0.47	0.50	0.09	0.17	0.18	0.16	0.11	0.07	0.02	-0.02	-0.07	-0.11
	1.0	0.2	0.40	2.1	3.7	5.2	6.6	7.8	9.0	11.0	12.0	-0.19	-0.39	-0.67	-0.96	-1.2	-1.5	-1.6	-1.8	-2.0	-2.1
1.0	0.3	-0.21	0.34	1.2	1.8	2.3	2.7	3.1	3.7	4.0	-0.12	-0.19	-0.35	-0.54	-0.71	-0.87	-1.0	-1.2	-1.3	-1.4	-1.5
	0.4	-0.33	0.21	0.62	0.96	1.2	1.5	1.7	2.0	2.1	-0.09	-0.10	-0.19	-0.31	-0.43	-0.53	-0.64	-0.77	-0.86	-0.94	-1.0
	0.5	-0.38	0.05	0.37	0.60	0.79	0.93	1.1	1.2	1.3	-0.07	-0.04	-0.09	-0.17	-0.26	-0.35	-0.44	-0.52	-0.59	-0.66	-0.73
1.0	0.6	-0.41	-0.02	0.21	0.42	0.55	0.66	0.73	0.80	0.85	0.89	-0.06	0	-0.07	-0.14	-0.21	-0.28	-0.34	-0.40	-0.46	-0.51
	0.8	-0.44	-0.10	0.11	0.24	0.33	0.39	0.43	0.48	0.47	0.48	-0.04	0.06	0.07	0.05	0.02	-0.03	-0.07	-0.12	-0.16	-0.20
	1.0	-0.46	-0.14	0.05	0.16	0.23	0.27	0.29	0.30	0.30	0.29	-0.03	0.09	0.13	0.13	0.11	0.08	0.06	0.03	-0.01	-0.05

ASHRAE 95

Total Loss Coefficients for Duct Fittings (K_T based on V_c for both paths)

COMBINED FLOW FITTINGS (cont.)

FITTING No. 613 ANGLED CIRCULAR COMBINED FLOW WITH NO AREA CHANGE



All values based on downstream (or combined) Velocity V_C

$\theta = 30^\circ$ BRANCH PATH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C						
	0.1	0.2	0.3	0.4	0.5	0.6	1.0
0.4	-0.52	-0.57	-0.68	-0.64	-0.19	-0.03	0.16
0.5	-0.41	-0.46	-0.35	-0.20	-0.05	0.18	0.27
0.6	-0.27	-0.29	-0.19	-0.04	0.14	0.32	0.31
0.7	-0.15	-0.13	-0.02	0.12	0.30	0.42	0.40
0.8	-0.03	0.04	0.12	0.28	0.40	0.48	0.45
0.9	0.10	0.20	0.33	0.43	0.52	0.51	0.40
1.0	0.21	0.37	0.50	0.59	0.64	0.53	0.27
1.5	1.1	1.5	1.5	1.4	0.89	-	-
2.0	3.1	3.0	2.6	2.1	-	-	-
2.5	5.4	4.8	3.8	2.9	-	-	-
3.0	7.8	6.4	5.3	-	-	-	-
4.0	14.0	12.0	-	-	-	-	-
5.0	21.0	17.0	-	-	-	-	-

$\theta = 30^\circ$ STRAIGHT THROUGH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C						
	0.1	0.2	0.3	0.4	0.5	0.6	1.0
0.4	0.01	0.09	0.13	0.17	0.22	0.29	0.36
0.5	0.01	0.11	0.15	0.19	0.22	0.26	0.32
0.6	0.01	0.09	0.13	0.15	0.19	0.22	0.25
0.7	0.01	0.07	0.12	0.12	0.14	0.12	0.10
0.8	0.02	0.05	0.07	0.07	0.03	-0.02	-0.15
0.9	0.02	0.03	0.03	0.01	-0.10	-0.09	-0.45
1.0	0.02	0.01	-0.01	-0.05	-0.20	-0.43	-0.75
1.5	-0.16	-0.25	-0.50	-0.70	-1.4	-	-
2.0	-0.33	-0.75	-1.1	-1.8	-	-	-
2.5	-0.72	-1.4	-2.4	-3.4	-	-	-
3.0	-1.1	-2.4	-3.7	-	-	-	-
4.0	-2.2	-4.8	-	-	-	-	-
5.0	-3.6	-7.7	-	-	-	-	-

$\theta = 45^\circ$ BRANCH PATH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C						
	0.1	0.2	0.3	0.4	0.5	0.6	1.0
0.4	-0.56	-0.44	-0.35	-0.28	-0.15	-0.04	0.05
0.5	-0.48	-0.37	-0.28	-0.21	-0.09	0.02	0.11
0.6	-0.38	-0.27	-0.19	-0.12	0	0.10	0.18
0.7	-0.26	-0.16	-0.08	-0.01	0.10	0.20	0.28
0.8	-0.21	-0.02	0.05	0.12	0.23	0.32	0.40
0.9	0.09	0.13	0.21	0.27	0.37	0.44	0.52
1.0	0.22	0.31	0.38	0.44	0.53	0.62	0.69
1.5	1.4	1.5	1.5	1.6	1.7	1.7	1.8
2.0	3.1	3.2	3.2	3.2	3.3	3.3	3.3
2.5	5.3	5.3	5.3	5.4	5.4	5.4	5.4
3.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0


$\theta = 45^\circ$ STRAIGHT THROUGH

VELOCITY RATIO V_B/V_C	AREA RATIO A_B/A_C						
	0.1	0.2	0.3	0.4	0.5	0.6	1.0
0.1	-8.6	-4.1	-2.5	-1.7	-0.97	-0.58	-0.34
0.2	-6.7	-3.1	-1.9	-1.3	-0.67	-0.36	-0.18
0.3	-5.0	-2.2	-1.3	-0.88	-0.42	-0.19	-0.05
0.4	-3.5	-1.5	-0.88	-0.55	-0.21	-0.05	0.05
0.5	-2.3	-0.95	-0.51	-0.28	-0.06	0.04	0.13
0.6	-1.3	-0.50	-0.22	-0.09	0.05	0.12	0.17
0.7	-0.63	-0.18	-0.03	0.04	0.12	0.16	0.18
0.8	-0.18	0.01	0.02	0.10	0.13	0.15	0.17
0.9	0.03	0.07	0.08	0.09	0.10	0.11	0.12
1.0	-0.01	0	0	0.10	0.02	0.04	0.05


ASHKAEZ

DUCT PENETRATIONS & ELIMINATORS

PIPE THROUGH CIRCULAR OR RECTANGULAR DUCT



ELIMINATORS




Total Loss Coefficients for Duct Fittings (K_f based on V_C for both paths)

DISCHARGES

RECT. NOZ. DISCHARGE


k_f based on V_1



HYRA

RECTANGULAR FLARED NOZ. DISCHARGE

k_f based on V_1




θ°	L:D				
	1	2	3	4	5
10	0.75	0.59	0.48	0.41	0.32
20	0.58	0.42	0.36	0.32	0.30
30	0.52	0.42	0.40	0.40	0.44
40	0.51	0.50	0.54	0.50	0.65

SYRA

CIRCULAR FLARED NOZ. DISCHARGE

k_f based on V_1




θ°	L:D				
	1	2	3	4	5
10	1.00	0.83	0.62	0.51	0.38
20	0.84	0.57	0.47	0.40	0.35
30	0.74	0.57	0.52	0.50	0.55
40	0.74	0.57	0.70	0.72	0.77

SYRA

TRIANGULAR NOZ. DISCHARGE

k_f based on V_1




$\frac{L}{H}$	$\frac{W}{H}$		
	1.0	1.4	2.0
0	3.0	2.5	1.5
1.0	2.0	2.0	1.6
10.0	1.5	1.4	1.1

HYRA

CIRCULAR NOZ. DISCHARGE

k_f based on V_1




$\frac{L}{D}$	L:D		
	0	2	10
0	3.0	2.7	2.0
0.2	2.2	1.7	1.5
0.5	1.8	1.3	1.2
1.0	1.5	1.1	1.1

SYRA

CHIMNEY ROOF

k_f based on V_1



$\frac{H}{D}$	k_f
0.1	4.0
0.2	2.5
0.4	1.4
0.6	1.1
1.0	1.0


SYRA



$\frac{H}{D}$	k_f
0.25	3.4
0.3	2.6
0.4	1.7
0.6	1.2
1.0	1.0

SYRA

TRIANGULAR PLANE EXPANDING DISCHARGE



k_f based on V_1


θ°	L:D				
	1	2	3	4	5
10	1.00	0.83	0.62	0.51	0.38
20	0.84	0.57	0.47	0.40	0.35
30	0.74	0.57	0.52	0.50	0.55
40	0.74	0.57	0.70	0.72	0.77

SYRA

Total Loss Coefficients for Duct Fittings (K_f based on V_1)


INTAKES

ANGLED DUCT ENTRY CIRCULAR OR RECTANGULAR



HYRA

RECTANGULAR FLARED DUCT ENTRY



Take θ° as the mean of θ_1° and θ_2°

$$D_0 = \frac{2(B_0 \times V_0)}{B_0 + V_0}$$


$$D_1 = \frac{2(B_1 \times V_1)}{B_1 + V_1}$$

$\frac{D_0}{D_1}$	K_T		
	θ°		
	60	90	120
1.1	0.25	0.32	0.40
1.2	0.17	0.23	0.35
1.4	0.12	0.21	0.31
1.6	0.12	0.20	0.30

ASHRAE


HYRA

CIRCULAR FLARED DUCT ENTRY




HYRA

CIRCULAR BELLOUS DUCT ENTRY




ASHRAE

PROJECTING RECTANGULAR OR CIRCULAR DUCT ENTRY



HYRA

FLARED RECTANGULAR OR CIRCULAR DUCT ENTRY



$$D = \frac{2(B \times V)}{B + V}$$

$$K_T = 0.5 \text{ for } t/D = 0.25$$

HYRA

LOUVERED DUCT ENTRY



$$JL = \frac{\text{Number of louvers } L \times L}{V \times Z}$$


JL	Without Louvre	Louvre vane angle 30°	Louvre vane angle 45°
0.4	13.7	19.5	-
0.6	7.5	12.5	21.0
0.8	4.5	7.5	14.0
1.0	3.0	4.5	8.5
1.2	2.0	3.5	5.5
1.4	1.5	3.0	4.5
1.6	1.2	2.5	4.0
1.8	1.2	2.5	4.0

HYRA

Total Loss Coefficients for Duct Fittings (K_T based on V_0)


INTAKES (cont.)

ROOFED DUCT ENTRY




SYRA

INLET LOUVERS




SYRA

OPEN DUCT ENTRIES



SYRA

SCREENS



SYRA

Total Loss Coefficients for Duct Fittings (k_T based on V_0)

WEIGHTS & AREAS OF RECTANGULAR GALVANISED STEEL DUCT

Width plus Height (mm)	Metal Thickness (mm)							Area (m ²) per lin m
	0.5	0.6	0.8	1.0	1.2	1.6	2.0	
250	2.28	2.90	3.66	4.59	5.80	7.32	9.20	0.50
275	2.53	3.19	4.03	5.05	6.38	8.06	10.11	0.55
300	2.76	3.48	4.39	5.51	6.96	8.79	11.03	0.60
325	2.99	3.77	4.76	5.97	7.54	9.52	11.96	0.65
350	3.22	4.06	5.13	6.43	8.12	10.25	12.88	0.70
375	3.45	4.35	5.49	6.89	8.70	10.99	13.80	0.75
400	3.68	4.64	5.86	7.35	9.28	11.72	14.71	0.80
425	3.91	4.93	6.23	7.81	9.80	12.45	15.63	0.85
450	4.14	5.22	6.59	8.27	10.44	13.18	16.56	0.90
475	4.37	5.51	6.96	8.79	11.02	13.91	17.48	0.95
500	4.60	5.80	7.32	9.19	11.60	14.65	18.40	1.00
525	4.83	6.09	7.69	9.65	12.18	15.38	19.31	1.05
550	5.06	6.38	8.06	10.11	12.76	16.11	20.23	1.10
575	5.29	6.67	8.42	10.56	13.34	16.84	21.16	1.15
600	5.51	6.96	8.79	11.02	13.92	17.58	22.08	1.20
650	5.97	7.54	9.52	11.94	15.08	19.04	23.92	1.30
700	6.43	8.12	10.25	12.86	16.24	20.51	25.76	1.40
750	6.89	8.70	10.99	13.78	17.40	21.27	27.60	1.50
800	7.35	9.28	11.72	14.70	18.56	23.43	29.44	1.60
850	7.81	9.86	12.45	15.62	19.72	24.90	31.27	1.70
900	8.27	10.44	13.18	16.54	20.88	26.37	33.11	1.80
950	8.73	11.03	13.91	17.45	22.04	27.83	34.95	1.90
1000	9.19	11.61	14.65	18.37	23.20	29.29	36.79	2.00
1050	9.95	12.19	15.38	19.29	24.36	30.76	38.63	2.10
1100	10.11	12.77	16.11	20.21	25.52	32.22	40.47	2.20
1150	10.57	13.35	16.84	21.18	26.68	33.69	42.31	2.30
1200	11.03	13.93	17.58	22.05	27.84	35.15	44.15	2.40
1250	11.49	14.51	18.31	22.97	29.00	36.62	45.99	2.50
1300	11.95	15.09	19.04	23.89	30.16	38.08	47.83	2.60
1350	12.41	15.67	19.77	24.80	31.32	39.55	49.67	2.70
1400	12.87	16.25	20.51	25.72	32.48	41.01	51.51	2.80
1450	13.33	16.83	21.24	26.64	33.64	42.48	53.35	2.90
1500	13.79	17.41	21.97	27.56	34.80	43.94	55.19	3.00
1550	14.25	17.99	22.70	28.48	35.96	45.51	57.03	3.10
1600	14.71	18.57	23.44	29.40	37.12	46.87	58.87	3.20
1650	15.17	19.15	24.17	30.32	38.28	48.34	60.71	3.30
1700	15.68	19.73	24.90	31.24	39.44	49.80	62.55	3.40
1750	16.09	20.31	25.63	32.15	40.60	51.27	64.39	3.50
1800	16.54	20.89	26.37	33.07	41.76	52.73	66.23	3.60
1850	17.00	21.47	27.10	33.99	42.92	54.20	68.07	3.70
1900	17.46	22.05	27.83	34.91	44.08	55.66	69.91	3.80
1950	17.92	22.63	28.56	35.83	45.24	57.12	71.75	3.90
2000	18.38	23.21	29.29	36.75	46.40	58.59	73.59	4.00

kg per linear metre

Weights include 20% allowance for bracing, hangers, waste and seams.

WEIGHTS & AREAS OF CIRCULAR GALVANISED STEEL DUCT

Diameter (mm)	Metal Thickness (mm)							Area (m ²) per lin m
	0.5	0.6	0.8	1.0	1.2	1.6	2.0	
100	1.44	1.82	2.30	2.89	3.64	4.60	5.78	0.31
125	1.80	2.28	2.88	3.61	4.56	5.75	7.22	0.39
150	2.17	2.73	3.45	4.38	5.47	6.90	8.67	0.47
175	2.53	3.19	4.03	5.05	6.38	8.05	10.11	0.55
200	2.89	3.65	4.60	5.77	7.29	9.20	11.56	0.63
225	3.25	4.10	5.18	6.49	8.20	10.35	13.00	0.71
250	3.61	4.56	5.75	7.22	9.11	11.50	14.45	0.79
275	3.97	5.01	6.33	7.94	10.02	12.65	15.89	0.86
300	4.33	5.47	6.90	8.66	10.93	13.80	17.34	0.94
325	4.69	5.92	7.48	9.38	11.84	14.95	18.78	1.02
350	5.05	6.38	8.05	10.10	12.76	16.11	20.23	1.10
375	5.41	6.84	8.63	10.82	13.67	17.26	21.67	1.18
400	5.78	7.29	9.20	11.54	14.58	18.41	23.12	1.26
425	6.14	7.75	9.78	12.27	15.49	19.56	24.56	1.33
450	6.50	8.20	10.35	12.99	16.40	20.71	26.01	1.40
475	6.86	8.66	10.92	13.71	17.31	21.86	27.45	1.49
500	7.22	9.11	11.50	14.43	18.22	23.01	28.90	1.57
525	7.58	9.57	12.08	15.15	19.13	24.16	30.34	1.65
550	7.94	10.08	12.65	15.87	20.04	25.31	31.79	1.73
575	8.30	10.48	13.28	16.59	20.96	26.46	33.23	1.80
600	8.66	10.94	13.80	17.32	21.87	27.61	34.68	1.88
625	9.02	11.39	14.38	18.04	22.78	28.76	36.12	1.96
650	9.38	11.85	14.96	18.76	23.69	29.91	37.57	2.04
675	9.75	12.30	15.53	19.48	24.60	31.06	39.01	2.12
700	10.11	12.76	16.11	20.20	25.51	32.31	40.46	2.20
725	10.47	13.22	16.68	20.92	26.42	33.36	41.90	2.28
750	10.83	13.67	17.26	21.65	27.33	34.51	43.35	2.36
775	11.19	14.13	17.83	22.37	28.24	35.66	44.79	2.43
800	11.55	14.58	18.41	23.09	29.15	36.81	46.24	2.51
825	11.91	15.04	18.98	23.81	30.07	37.96	47.68	2.59
850	12.27	15.49	19.56	24.53	30.98	39.11	49.13	2.67
875	12.63	15.95	20.13	25.25	31.89	40.26	50.57	2.75
900	12.99	16.41	20.71	25.97	32.80	41.41	52.01	2.83
925	13.35	16.86	21.28	26.70	33.71	42.56	53.46	2.91
950	13.72	17.32	21.86	27.42	34.62	43.71	54.90	2.98
975	14.08	17.77	22.43	28.14	35.53	44.85	56.36	3.06
1000	14.44	18.23	23.01	28.86	36.44	46.01	57.79	3.14
kg per linear metre								

Weights include 20% allowance for bracing, hangers, waste and seams.