

## Extinguishing Values Class A & C Fires

	ISO	NFPA
Design conc.	31%	31.6%
Safety factor	30%	20%
Minimum design conc.	40,3%	37.9%
<b>Propellant factor</b>	<b>10%</b>	<b>10%</b>
<b>Required design conc.</b>	<b>44,3%</b>	<b>40,17%</b>

## Extinguishing Values Class B Fires

	ISO	NFPA
Design conc.	36,5%	36,5%
Safety factor	30%	30%
Minimum design conc.	47,5%	47,5%
<b>Propellant factor</b>	<b>10%</b>	<b>10%</b>
<b>Required design conc.</b>	<b>52,2%</b>	<b>52,2%</b>