

| 2021 ASHRAE Handbook - Fundamentals (SI) | | | | | | | | | | | | | | | | |
|---|------------------------|-----------------|-------------------------------|----------|--------------------|-------------|--|-----------------------|-----------------------|------|--------------|------|-----------------------|----------------------|----------------|--|
| ORAN, ARGENTINA (WMO: 870160) | | | | | | | | | | | | | | | | |
| Lat:23.1547S | | Long:64.3281W | | Elev:357 | | StdP: 97.11 | | Time zone:-3.00 (W03) | | | Period:82-19 | | WBAN:99999 | | | |
| Annual Heating, Humidification, and Ventilation Design Conditions | | | | | | | | | | | | | | | | |
| Coldest Month | Heating DB | | Humidification DP/MCDB and HR | | | | | | Coldest month WS/MCDB | | | | MCWS/PCWD to 99.6% DB | | WSF | |
| | | | 99.6% | | | 99% | | | 0.4% | | 1% | | | | | |
| | 99.6% | 99% | DP | HR | MCDB | DP | HR | MCDB | WS | MCDB | WS | MCDB | MCWS | PCWD | | |
| 7 | 5.5 | 7.2 | 1.1 | 4.3 | 14.2 | 3.0 | 4.9 | 12.6 | 7.0 | 16.3 | 5.3 | 16.4 | 1.3 | 0 | 0.289 | |
| Annual Cooling, Dehumidification, and Enthalpy Design Conditions | | | | | | | | | | | | | | | | |
| Hottest Month | Hottest Month DB Range | Cooling DB/MCWB | | | | | | Evaporation WB/MCDB | | | | | | MCWS/PCWD to 0.4% DB | | |
| | | 0.4% | | 1% | | 2% | | 0.4% | | 1% | | 2% | | | | |
| | | DB | MCWB | DB | MCWB | DB | MCWB | WB | MCDB | WB | MCDB | WB | MCDB | MCWS | PCWD | |
| 12 | 9.7 | 37.0 | 24.1 | 35.5 | 24.1 | 34.1 | 24.1 | 27.0 | 32.5 | 26.4 | 31.8 | 25.9 | 31.1 | 2.7 | 180 | |
| Dehumidification DP/MCDB and HR | | | | | | | | | Enthalpy/MCDB | | | | | | Extreme Max WB | |
| 0.4% | | | 1% | | | 2% | | | 0.4% | | 1% | | 2% | | | |
| DP | HR | MCDB | DP | HR | MCDB | DP | HR | MCDB | Enth | MCDB | Enth | MCDB | Enth | MCDB | | |
| 25.7 | 21.9 | 29.9 | 25.0 | 21.0 | 29.3 | 24.5 | 20.3 | 28.7 | 88.0 | 32.4 | 85.2 | 32.0 | 82.8 | 31.2 | 30.7 | |
| Extreme Annual Design Conditions | | | | | | | | | | | | | | | | |
| Extreme Annual WS | | | Extreme Annual Temperature | | | | n-Year Return Period Values of Extreme Temperature | | | | | | | | | |
| | | | Mean | | Standard deviation | | n=5 years | | n=10 years | | n=20 years | | n=50 years | | | |
| 1% | 2.5% | 5% | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | | |
| 7.5 | 5.4 | 4.6 | DB | 3.9 | 40.6 | 2.1 | 1.7 | 2.4 | 41.8 | 1.2 | 42.8 | 0.0 | 43.7 | -1.6 | 44.9 | |
| | | | WB | 3.2 | 28.6 | 1.9 | 1.1 | 1.8 | 29.4 | 0.7 | 30.0 | -0.4 | 30.6 | -1.8 | 31.4 | |
| Monthly Climatic Design Conditions | | | | | | | | | | | | | | | | |
| | | Annual | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | |
| Temperatures, Degree-Days and Degree-Hours | DBAvg | 22.4 | 26.9 | 26.3 | 24.3 | 22.2 | 18.9 | 16.1 | 15.7 | 18.9 | 21.3 | 24.8 | 26.2 | 27.0 | | |
| | DBStd | 5.22 | 2.53 | 2.64 | 2.92 | 3.27 | 3.38 | 3.35 | 3.43 | 4.15 | 4.00 | 3.93 | 3.24 | 2.98 | | |
| | HDD10.0 | 3 | 0 | 0 | 0 | 0 | 0 | 1 | 2 | 0 | 0 | 0 | 0 | 0 | | |
| | HDD18.3 | 284 | 0 | 0 | 1 | 8 | 34 | 83 | 96 | 45 | 15 | 2 | 0 | 0 | | |
| | CDD10.0 | 4513 | 526 | 455 | 444 | 366 | 275 | 184 | 179 | 276 | 339 | 458 | 485 | 526 | | |
| | CDD18.3 | 1750 | 267 | 222 | 187 | 123 | 51 | 16 | 14 | 62 | 104 | 202 | 235 | 268 | | |
| | CDH23.3 | 14936 | 2536 | 1935 | 1266 | 618 | 163 | 44 | 83 | 476 | 873 | 1933 | 2322 | 2685 | | |
| | CDH26.7 | 6233 | 1067 | 771 | 412 | 148 | 23 | 3 | 12 | 164 | 352 | 923 | 1104 | 1254 | | |
| Wind | WSAvg | 1.7 | 1.9 | 1.8 | 1.6 | 1.4 | 1.2 | 1.3 | 1.4 | 1.6 | 1.9 | 2.1 | 2.1 | 1.9 | | |
| Precipitation | PrecAvg | 955 | 197 | 166 | 153 | 80 | 19 | 9 | 6 | 4 | 11 | 51 | 97 | 156 | | |
| | PrecMax | 1374 | 460 | 374 | 344 | 201 | 76 | 33 | 22 | 28 | 40 | 170 | 242 | 302 | | |
| | PrecMin | 655 | 35 | 49 | 41 | 7 | 1 | 0 | 0 | 0 | 0 | 1 | 5 | 52 | | |
| | PrecStd | 209 | 98 | 91 | 77 | 50 | 17 | 10 | 5 | 7 | 11 | 39 | 53 | 67 | | |
| Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | 0.4% | DB | 36.5 | 36.4 | 34.4 | 31.7 | 28.9 | 27.0 | 28.6 | 33.4 | 35.8 | 38.9 | 38.7 | 38.7 | | |
| | | MCWB | 25.9 | 25.1 | 25.9 | 24.5 | 22.2 | 20.2 | 19.9 | 21.3 | 21.4 | 23.5 | 23.3 | 24.7 | | |
| | 2% | DB | 34.7 | 34.2 | 32.4 | 30.0 | 26.9 | 24.7 | 25.9 | 30.8 | 33.1 | 36.2 | 36.5 | 36.4 | | |
| | | MCWB | 25.9 | 25.6 | 25.2 | 23.9 | 21.6 | 19.1 | 18.7 | 20.6 | 20.8 | 23.3 | 23.5 | 24.9 | | |
| | 5% | DB | 33.4 | 32.6 | 30.8 | 28.3 | 25.1 | 22.8 | 23.7 | 28.1 | 30.8 | 34.1 | 34.5 | 34.5 | | |
| | | MCWB | 25.7 | 25.2 | 25.0 | 23.3 | 20.9 | 18.3 | 17.1 | 19.3 | 19.9 | 22.4 | 23.1 | 24.7 | | |
| 10% | DB | 32.0 | 31.2 | 29.1 | 26.7 | 23.5 | 21.1 | 21.7 | 25.8 | 28.5 | 32.0 | 32.6 | 32.7 | | | |
| | MCWB | 25.2 | 25.0 | 24.1 | 22.7 | 20.2 | 17.4 | 16.2 | 17.8 | 18.9 | 21.7 | 22.7 | 24.6 | | | |
| Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | 0.4% | WB | 28.1 | 27.8 | 26.9 | 26.1 | 23.7 | 21.3 | 20.8 | 22.8 | 23.2 | 25.2 | 26.6 | 27.2 | | |
| | | MCDB | 32.7 | 32.5 | 31.5 | 30.2 | 26.9 | 25.4 | 26.9 | 30.6 | 32.1 | 34.9 | 34.4 | 33.3 | | |
| | 2% | WB | 27.1 | 26.7 | 26.1 | 25.1 | 22.6 | 20.0 | 19.4 | 21.3 | 22.0 | 24.3 | 25.5 | 26.3 | | |
| | | MCDB | 32.5 | 31.5 | 30.7 | 28.5 | 25.6 | 23.1 | 24.6 | 29.1 | 30.6 | 33.8 | 32.4 | 32.9 | | |
| | 5% | WB | 26.5 | 26.0 | 25.4 | 24.3 | 21.7 | 19.1 | 18.1 | 20.0 | 20.9 | 23.4 | 24.5 | 25.7 | | |
| | | MCDB | 31.7 | 30.9 | 29.5 | 27.1 | 24.3 | 21.8 | 22.5 | 26.1 | 28.3 | 31.9 | 31.1 | 32.1 | | |
| 10% | WB | 25.8 | 25.4 | 24.7 | 23.5 | 20.7 | 18.1 | 17.0 | 18.9 | 19.7 | 22.5 | 23.8 | 25.1 | | | |
| | MCDB | 30.7 | 29.9 | 28.3 | 25.8 | 22.8 | 20.6 | 20.4 | 24.8 | 27.0 | 29.9 | 29.8 | 31.1 | | | |

| | | | | | | | | | | | | | | |
|-------------------------------------|-------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Mean Daily Temperature Range | | MDBR | 8.9 | 8.7 | 7.6 | 7.0 | 7.0 | 8.6 | 10.5 | 12.0 | 11.7 | 11.0 | 10.4 | 9.7 |
| | 5% DB | MCDBR | 11.2 | 10.9 | 10.0 | 9.5 | 9.0 | 11.3 | 13.8 | 15.1 | 15.5 | 14.8 | 14.2 | 13.0 |
| | | MCWBR | 3.9 | 3.9 | 3.9 | 3.9 | 3.9 | 5.8 | 6.5 | 5.8 | 5.5 | 4.7 | 4.4 | 4.2 |
| | 5% WB | MCDBR | 10.1 | 9.9 | 8.9 | 7.9 | 7.6 | 9.1 | 12.3 | 13.7 | 13.6 | 13.2 | 11.5 | 11.3 |
| MCWBR | | 4.4 | 4.2 | 3.9 | 3.9 | 3.6 | 5.0 | 6.0 | 5.5 | 5.5 | 4.7 | 4.4 | 4.2 | |
| Clear Sky Solar Irradiance | taub | | 0.426 | 0.424 | 0.417 | 0.400 | 0.364 | 0.331 | 0.334 | 0.398 | 0.487 | 0.494 | 0.441 | 0.435 |
| | taud | | 2.355 | 2.371 | 2.392 | 2.406 | 2.435 | 2.506 | 2.474 | 2.276 | 2.036 | 2.084 | 2.268 | 2.317 |
| | Ebn at noon | | 920 | 909 | 887 | 859 | 850 | 865 | 875 | 846 | 810 | 836 | 901 | 914 |
| | Edn at noon | | 134 | 129 | 121 | 110 | 98 | 87 | 93 | 123 | 170 | 170 | 145 | 139 |
| All-Sky Solar Radiation | RadAvg | | 5.96 | 5.48 | 4.53 | 3.76 | 3.22 | 3.13 | 3.67 | 4.51 | 5.13 | 5.29 | 5.74 | 5.76 |
| | RadStd | | 0.49 | 0.35 | 0.42 | 0.39 | 0.35 | 0.28 | 0.28 | 0.36 | 0.47 | 0.46 | 0.56 | 0.41 |

Historical Trends

| | DBAvg | Heating | | Cooling | | | Degree-Days | | | | | | |
|-------------------------------|-------|---------|--------|---------|-------|-------|-------------|---------|---------|---------|-----|-----|-----|
| | | 99% DB | 99% DP | 1% DB | 1% WB | 1% DP | HDD10.0 | HDD18.3 | CDD10.0 | CDD18.3 | | | |
| Station Only | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Regional (0 neighbors) | N/A | N/A | N/A | N/A | N/A | N/A | -14 | N/A | N/A | N/A | N/A | N/A | N/A |

| | | | | | |
|----------|--|-------|---|-----------------------|---|
| CDDn | Cooling degree-days base n°C, °C-day | Lat | Latitude, ° | Period | Years used to calculate the design conditions |
| CDHn | Cooling degree-hours base n°C, °C-hour | Long | Longitude, ° | Sd | Standard deviation of daily average temperature, °C |
| DB | Dry bulb temperature, °C | MCDB | Mean coincident dry bulb temperature, °C | StdP | Standard pressure at station elevation, kPa |
| DP | Dew point temperature, °C | MCDBR | Mean coincident dry bulb temp. range, °C | taub | Clear sky optical depth for beam irradiance |
| Ebn,noon | Clear sky beam normal and diffuse horizontal irradiances at solar noon, W/m2 | MCDP | Mean coincident dew point temperature, °C | taud | Clear sky optical depth for diffuse irradiance |
| Edh,noon | | MCWB | Mean coincident wet bulb temperature, °C | Tavg | Average temperature, °C |
| Elev | Elevation, m | MCWBR | Mean coincident wet bulb temp. range, °C | Time Zone | Hours ahead or behind UTC |
| Enth | Enthalpy, kJ/kg | MCWS | Mean coincident wind speed, m/s | WB | Wet bulb temperature, °C |
| HDDn | Heating degree-days base n°C, °C-day | MDBR | Mean dry bulb temp. range, °C | Hours 8/4 & 12.8/20.6 | Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C |
| PCWD | Prevailing coincident wind direction, °, 0 = North, 90 = East | WS | Wind speed, m/s | HR | Humidity ratio, g of moisture per kg of dry air |