

## CHAPTER 21

# DUCT DESIGN

<i>BERNOULLI EQUATION</i>	21.1	<i>FAN/SYSTEM INTERFACE</i>	21.11
<i>Head and Pressure</i>	21.2	<i>DUCT SYSTEM DESIGN</i>	21.13
<i>SYSTEM ANALYSIS</i>	21.2	<i>Design Considerations</i>	21.13
<i>Pressure Changes in System</i>	21.5	<i>Duct Design Methods</i>	21.16
<i>FLUID RESISTANCE</i>	21.6	<i>Balancing Dampers</i>	21.17
<i>Friction Losses</i>	21.6	<i>HVAC Duct Design Procedures</i>	21.18
<i>Dynamic Losses</i>	21.9	<i>Industrial Exhaust System Duct Design</i>	21.18
<i>Ductwork Sectional Losses</i>	21.11	<i>FITTING LOSS COEFFICIENTS</i>	21.26

**C**OMMERCIAL, industrial, and residential air duct system design must consider (1) space availability, (2) space air diffusion, (3) noise levels, (4) air distribution system (duct and equipment), (5) duct heat gains and losses, (6) balancing, (7) fire and smoke control, (8) initial investment cost, and (9) system operating cost.

Deficiencies in duct design can result in systems that operate incorrectly or are expensive to own and operate. Poor design or lack of system sealing can produce inadequate airflow rates at the terminals, leading to discomfort, loss of productivity, and even adverse health effects. Lack of sound attenuation may lead to objectionable noise levels. Proper duct insulation eliminates excessive heat gain or loss.

In this chapter, system design and calculation of a system's frictional and dynamic resistance to airflow are considered. Chapter 18 of the 2008 *ASHRAE Handbook—HVAC Systems and Equipment* examines duct construction and presents construction standards for residential, commercial, and industrial HVAC and exhaust systems.

## BERNOULLI EQUATION

The Bernoulli equation can be developed by equating the forces on an element of a stream tube in a frictionless fluid flow to the rate of momentum change. On integrating this relationship for steady flow, the following expression (Osborne 1966) results:

$$\frac{v^2}{2} + \int \frac{dP}{\rho} + gz = \text{constant, N}\cdot\text{m/kg} \quad (1)$$

where

$v$  = streamline (local) velocity, m/s

$P$  = absolute pressure, Pa ( $\text{N}/\text{m}^2$ )

$\rho$  = density,  $\text{kg}/\text{m}^3$

$g$  = acceleration caused by gravity,  $\text{m}/\text{s}^2$

$z$  = elevation, m

Assuming constant fluid density in the system, Equation (1) reduces to

$$\frac{v^2}{2} + \frac{P}{\rho} + gz = \text{constant, N}\cdot\text{m/kg} \quad (2)$$

Although Equation (2) was derived for steady, ideal frictionless flow along a stream tube, it can be extended to analyze flow through ducts in real systems. In terms of pressure, the relationship for fluid resistance between two sections is

The preparation of this chapter is assigned to TC 5.2, Duct Design.

$$\frac{\rho_1 V_1^2}{2} + P_1 + g\rho_1 z_1 = \frac{\rho_2 V_2^2}{2} + P_2 + g\rho_2 z_2 + \Delta p_{t,1-2} \quad (3)$$

where

$V$  = average duct velocity, m/s

$\Delta p_{t,1-2}$  = total pressure loss caused by friction and dynamic losses between sections 1 and 2, Pa

In Equation (3),  $V$  (section average velocity) replaces  $v$  (streamline velocity) because experimentally determined loss coefficients allow for errors in calculating  $v^2/2$  (velocity pressure) across streamlines.

On the left side of Equation (3), add and subtract  $p_{z1}$ ; on the right side, add and subtract  $p_{z2}$ , where  $p_{z1}$  and  $p_{z2}$  are the values of atmospheric air at heights  $z_1$  and  $z_2$ . Thus,

$$\begin{aligned} \frac{\rho_1 V_1^2}{2} + P_1 + (p_{z1} - p_{z1}) + g\rho_1 z_1 \\ = \frac{\rho_2 V_2^2}{2} + P_2 + (p_{z2} - p_{z2}) + g\rho_2 z_2 + \Delta p_{t,1-2} \end{aligned} \quad (4)$$

Atmospheric pressure at any elevation ( $p_{z1}$  and  $p_{z2}$ ) expressed in terms of the atmospheric pressure  $p_a$  at the same datum elevation is given by

$$p_{z1} = p_a - g\rho_a z_1 \quad (5)$$

$$p_{z2} = p_a - g\rho_a z_2 \quad (6)$$

Substituting Equations (5) and (6) into Equation (4) and simplifying yields the total pressure change between sections 1 and 2. Assume no temperature change between sections 1 and 2 (no heat exchanger within the section); therefore,  $\rho_1 = \rho_2$ . When a heat exchanger is located in the section, the average of the inlet and outlet temperatures is generally used. Let  $\rho = \rho_1 = \rho_2$ .  $(P_1 - p_{z1})$  and  $(P_2 - p_{z2})$  are gage pressures at elevations  $z_1$  and  $z_2$ .

$$\Delta p_{t,1-2} = \left( P_{s,1} + \frac{\rho V_1^2}{2} \right) - \left( P_{s,2} + \frac{\rho V_2^2}{2} \right) + g(\rho_a - \rho)(z_2 - z_1) \quad (7a)$$

$$\Delta p_{t,1-2} = \Delta p_t + \Delta p_{se} \quad (7b)$$

$$\Delta p_t = \Delta p_{t,1-2} + \Delta p_{se} \quad (7c)$$

where

$P_{s,1}$  = static pressure, gage at elevation  $z_1$ , Pa

$p_{s,2}$  = static pressure, gage at elevation  $z_2$ , Pa

$V_1$  = average velocity at section 1, m/s

$V_2$  = average velocity at section 2, m/s

$\rho_a$  = density of ambient air, kg/m<sup>3</sup>

$\rho$  = density of air or gas in duct, kg/m<sup>3</sup>

$\Delta p_{se}$  = thermal gravity effect, Pa

$\Delta p_t$  = total pressure change between sections 1 and 2, Pa

$\Delta p_{t,1-2}$  = total pressure loss caused by friction and dynamic losses between sections 1 and 2, Pa

## HEAD AND PRESSURE

The terms **head** and **pressure** are often used interchangeably; however, head is the height of a fluid column supported by fluid flow, whereas pressure is the normal force per unit area. For liquids, it is convenient to measure head in terms of the flowing fluid. With a gas or air, however, it is customary to measure pressure on a column of liquid.

### Static Pressure

The term  $p/\rho g$  is static head;  $p$  is static pressure.

### Velocity Pressure

The term  $V^2/2g$  refers to velocity head, and  $\rho V^2/2$  refers to velocity pressure. Although velocity head is independent of fluid density, velocity pressure [Equation (8)] is not.

$$p_v = \rho V^2/2 \quad (8)$$

where

$p_v$  = velocity pressure, Pa

$V$  = fluid mean velocity, m/s

For air at standard conditions (1.204 kg/m<sup>3</sup>), Equation (8) becomes

$$p_v = 0.602 V^2 \quad (9)$$

Velocity is calculated by

$$V = Q/A \quad (10)$$

where

$Q$  = airflow rate, L/s

$A$  = cross-sectional area of duct, m<sup>2</sup>

### Total Pressure

Total pressure is the sum of static pressure and velocity pressure:

$$p_t = p_s + \rho V^2/2 \quad (11)$$

or

$$p_t = p_s + p_v \quad (12)$$

where

$p_t$  = total pressure, Pa

$p_s$  = static pressure, Pa

### Pressure Measurement

The range, precision, and limitations of instruments for measuring pressure and velocity are discussed in Chapter 36. The manometer is a simple and useful means for measuring partial vacuum and low pressure. Static, velocity, and total pressures in a duct system relative to atmospheric pressure can be measured with a pitot tube connected to a manometer. Pitot tube construction and locations for traversing round and rectangular ducts are presented in Chapter 36.

## SYSTEM ANALYSIS

The total pressure change caused by friction, fittings, equipment, and net **thermal gravity effect (stack effect)** for each section of a duct system is calculated by the following equation:

$$\Delta p_{t_i} = \Delta p_{f_i} + \sum_{j=1}^m \Delta p_{ij} + \sum_{k=1}^n \Delta p_{ik} - \sum_{r=1}^{\lambda} \Delta p_{se_ir} \quad (13)$$

$$\text{for } i = 1, 2, \dots, n_{up} + n_{dn}$$

where

$\Delta p_{t_i}$  = net total pressure change for  $i$ -section, Pa

$\Delta p_{f_i}$  = pressure loss due to friction for  $i$ -section, Pa

$\Delta p_{ij}$  = total pressure loss due to  $j$ -fittings, including fan system effect (FSE), for  $i$ -section, Pa

$\Delta p_{ik}$  = pressure loss due to  $k$ -equipment for  $i$ -section, Pa

$\Delta p_{se_ir}$  = thermal gravity effect due to  $r$ -stacks for  $i$ -section, Pa

$m$  = number of fittings within  $i$ -section

$n$  = number of equipment within  $i$ -section

$\lambda$  = number of stacks within  $i$ -section

$n_{up}$  = number of duct sections upstream of fan (exhaust/return air subsystems)

$n_{dn}$  = number of duct sections downstream of fan (supply air subsystems)

From Equation (7), the thermal gravity effect for each nonhorizontal duct with a density other than that of ambient air is determined by the following equation:

$$\Delta p_{se} = g(\rho_a - \rho)(z_2 - z_1) \quad (14)$$

where

$\Delta p_{se}$  = thermal gravity effect, Pa

$z_1$  and  $z_2$  = elevation from datum in direction of airflow (Figure 1), m

$\rho_a$  = density of ambient air, kg/m<sup>3</sup>

$\rho$  = density of air or gas within duct, kg/m<sup>3</sup>

$g = 9.81$  = gravitational acceleration, m/s<sup>2</sup>

**Example 1.** For Figure 1, calculate the thermal gravity effect for two cases:

(a) air cooled to  $-34^{\circ}\text{C}$ , and (b) air heated to  $540^{\circ}\text{C}$ . Density of air at  $34^{\circ}\text{C}$  is 1.477 kg/m<sup>3</sup> and at  $540^{\circ}\text{C}$  is 434 kg/m<sup>3</sup>. Density of ambient air is 1.204 kg/m<sup>3</sup>. Stack height is 15 m.

**Solution:**

$$\Delta p_{se} = 9.81(\rho_a - \rho)z$$

(a) For  $\rho > \rho_a$  (Figure 1A),

$$\Delta p_{se} = 9.81(1.204 - 1.477)15 = -40 \text{ Pa}$$

(b) For  $\rho < \rho_a$  (Figure 1B),

$$\Delta p_{se} = 9.81(1.204 - 0.434)15 = +113 \text{ Pa}$$

**Example 2.** Calculate the thermal gravity effect for the two-stack system shown in Figure 2, where the air is  $120^{\circ}\text{C}$  and stack heights are 15 and 30 m. Density of  $120^{\circ}\text{C}$  air is 0.898 kg/m<sup>3</sup>; ambient air is 1.204 kg/m<sup>3</sup>.

**Solution:**

$$\Delta p_{se} = 9.81(\rho_a - \rho)(z_2 - z_1) = 9.81(1.204 - 0.898)(30 - 15) = 45 \text{ Pa}$$

For the system shown in Figure 3, the direction of air movement created by the thermal gravity effect depends on the initiating force (e.g., fans, wind, opening and closing doors, turning equipment on and off). If for any reason air starts to enter the left stack (Figure 3A), it creates a buoyancy effect in the right stack. On the other hand, if flow starts to enter the right stack (Figure 3B), it creates a buoyancy effect in the left stack. In both cases, the produced thermal gravity effect is stable and depends on stack height and magnitude




Fig. 1 Thermal Gravity Effect for Example 1




Fig. 2 Multiple Stacks for Example 2

of heating. The starting direction of flow is important when using natural convection for ventilation.

To determine the fan total pressure requirement for a system, use the following equation:

$$P_t = \sum_{i \in F_{up}} \Delta p_{t_i} + \sum_{i \in F_{dn}} \Delta p_{t_i} \quad \text{for } i = 1, 2, \dots, n_{up} + n_{dn} \quad (15)$$

where

$F_{up}$  and  $F_{dn}$  = sets of duct sections upstream and downstream of fan  
 $P_t$  = fan total pressure, Pa

$\epsilon$  = symbol that ties duct sections into system paths from exhaust/return air terminals to supply terminals

Figure 4 illustrates the use of Equation (15). This system has three supply and two return terminals consisting of nine sections connected in six paths: 1-3-4-9-7-5, 1-3-4-9-7-6, 1-3-4-9-8, 2-4-9-7-5, 2-4-9-7-6, and 2-4-9-8. Sections 1 and 3 are unequal area; thus, they are assigned separate numbers in accordance with the rules for identifying sections (see step 4 in the section on HVAC Duct Design Procedures). To determine the fan pressure requirement, apply the following six equations, derived from Equation (15). These equations must be satisfied to attain pressure balancing for




Fig. 3 Multiple Stack Analysis




Fig. 4 Illustrative 6-Path, 9-Section System

design airflow. Relying entirely on dampers is not economical and may create objectionable flow-generated noise.

$$\begin{cases} P_t = \Delta p_1 + \Delta p_3 + \Delta p_4 + \Delta p_9 + \Delta p_7 + \Delta p_5 \\ P_t = \Delta p_1 + \Delta p_3 + \Delta p_4 + \Delta p_9 + \Delta p_7 + \Delta p_6 \\ P_t = \Delta p_1 + \Delta p_3 + \Delta p_4 + \Delta p_9 + \Delta p_8 \\ P_t = \Delta p_2 + \Delta p_4 + \Delta p_9 + \Delta p_7 + \Delta p_5 \\ P_t = \Delta p_2 + \Delta p_4 + \Delta p_9 + \Delta p_7 + \Delta p_6 \\ P_t = \Delta p_2 + \Delta p_4 + \Delta p_9 + \Delta p_8 \end{cases} \quad (16)$$

**Example 3.** For Figures 5A and 5C, calculate the thermal gravity effect and fan total pressure required when the air is cooled to  $-34^\circ\text{C}$ . The heat exchanger and ductwork (section 1 to 2) total pressure losses are 170

and 70 Pa respectively. The density of  $-34^{\circ}\text{C}$  air is  $1.477 \text{ kg/m}^3$ ; ambient air is  $1.204 \text{ kg/m}^3$ . Elevations are 21 and 3 m.

**Solution:**

(a) For Figure 5A (downward flow),


$$\begin{aligned}\Delta p_{se} &= 9.81(\rho_a - \rho)(z_2 - z_1) \\ &= 9.81(1.204 - 1.477)(3 - 21) \\ &= 48 \text{ Pa}\end{aligned}$$

$$\begin{aligned}P_t &= \Delta p_{t,3-2} - \Delta p_{se} \\ &= (170 + 70) - (48) \\ &= 192 \text{ Pa}\end{aligned}$$


(b) For Figure 5C (upward flow),

$$\begin{aligned}\Delta p_{se} &= 9.81(\rho_a - \rho)(z_2 - z_1) \\ &= 9.81(1.204 - 1.477)(21 - 3) \\ &= -48 \text{ Pa}\end{aligned}$$


$$\begin{aligned}P_t &= \Delta p_{t,3-2} - \Delta p_{se} \\ &= (170 + 70) - (-48) \\ &= 288 \text{ Pa}\end{aligned}$$




A.  $\rho > \rho_a$



B.  $\rho < \rho_a$



C.  $\rho > \rho_a$



D.  $\rho < \rho_a$

Fig. 5 Single Stack with Fan for Examples 3 and 4

**Example 4.** For Figures 5B and 5D, calculate the thermal gravity effect and fan total pressure required when air is heated to  $120^{\circ}\text{C}$ . Heat exchanger and ductwork (section 1 to 2) total pressure losses are 170 and 70 Pa respectively. Density of  $120^{\circ}\text{C}$  air is  $0.898 \text{ kg/m}^3$ ; ambient air is  $1.204 \text{ kg/m}^3$ . Elevations are 21 and 3 m.

**Solution:**

(a) For Figure 5B (downward flow),

$$\begin{aligned}\Delta p_{se} &= 9.81(\rho_a - \rho)(z_2 - z_1) \\ &= 9.81(1.204 - 0.898)(3 - 21) \\ &= -54 \text{ Pa}\end{aligned}$$

$$\begin{aligned}P_t &= \Delta p_{t,3-2} - \Delta p_{se} \\ &= (170 + 70) - (-54) \\ &= 294 \text{ Pa}\end{aligned}$$


(b) For Figure 5D (upward flow),

$$\begin{aligned}\Delta p_{se} &= 9.81(\rho_a - \rho)(z_2 - z_1) \\ &= 9.81(1.204 - 0.898)(21 - 3) \\ &= 54 \text{ Pa}\end{aligned}$$

$$\begin{aligned}
 P_t &= \Delta p_{t,3-2} - \Delta p_{se} \\
 &= (170 + 70) - (54) \\
 &= 186 \text{ Pa}
 \end{aligned}$$

**Example 5.** Calculate the thermal gravity effect for each section of the system shown in **Figure 6**, and the systems' net thermal gravity effect. Density of ambient air is  $1.204 \text{ kg/m}^3$ , and the lengths are as follows:  $z_1 = 15 \text{ m}$ ,  $z_2 = 27 \text{ m}$ ,  $z_4 = 30 \text{ m}$ ,  $z_5 = 8 \text{ m}$ , and  $z_9 = 60 \text{ m}$ . Pressure required at section 3 is  $-25 \text{ Pa}$ . Write the equation to determine the fan total pressure requirement.

**Solution:** The following table summarizes the thermal gravity effect for each section of the system as calculated by Equation (14). The net



**Fig. 6 Triple Stack System for Example 5**

thermal gravity effect for the system is  $118 \text{ Pa}$ . To select a fan, use the following equation:

$$\begin{aligned}
 P_t &= 25 + \Delta p_{t,1-7} + \Delta p_{t,8-9} - \Delta p_{se} = 25 + \Delta p_{t,1-7} \\
 &+ \Delta p_{t,8-9} - 118 = \Delta p_{t,1-7} + \Delta p_{t,8-9} - 93
 \end{aligned}$$

Path (x-x')	Temp., °C	$\rho$ , $\text{kg/m}^3$	$\Delta z$ , ( $z_{x'} - z_x$ ), m	$\Delta \rho$ , ( $\rho_a - \rho_{x-x'}$ ), $\text{kg/m}^3$	$\Delta p_{se}$ , Pa
				[Eq. (14)]	
1-2	815	0.324	(27 - 15)	+0.880	+104
3-4	540	0.434	0	+0.770	0
4-5	540	0.434	(8 - 30)	+0.770	-166
6-7	120	0.898	0	+0.306	0
8-9	120	0.898	(60 - 0)	+0.306	+180
Net Thermal Gravity Effect					118


### PRESSURE CHANGES IN SYSTEM

**Figure 7** shows total and static pressure changes in a fan/duct system consisting of a fan with both supply and return air ductwork. Also shown are total and static pressure gradients referenced to atmospheric pressure.

For all constant-area sections, total and static pressure losses are equal. At diverging transitions, velocity pressure decreases, absolute total pressure decreases, and absolute static pressure can increase. The static pressure increase at these sections is known as **static regain**.

At converging transitions, velocity pressure increases in the direction of airflow, and absolute total and absolute static pressures decrease.

At the exit, total pressure loss depends on the shape of the fitting and the flow characteristics. Exit loss coefficients  $C_o$  can be greater than, less than, or equal to one. Total and static pressure grade lines for the various coefficients are shown in **Figure 7**. Note that, for a loss coefficient less than one, static pressure upstream of the exit is less than atmospheric pressure (negative). Static pressure just upstream of the discharge fitting can be calculated by subtracting the upstream velocity pressure from the upstream total pressure.



**Fig. 7 Pressure Changes During Flow in Ducts**

At section 1, total pressure loss depends on the shape of the entry. Total pressure immediately downstream of the entrance equals the difference between the upstream pressure, which is zero (atmospheric pressure), and loss through the fitting. Static pressure of ambient air is zero; several diameters downstream, static pressure is negative, equal to the sum of the total pressure (negative) and the velocity pressure (always positive).

System resistance to airflow is noted by the total pressure grade line in [Figure 7](#). Sections 3 and 4 include fan system effect pressure losses. To obtain the fan static pressure requirement for fan selection where fan total pressure is known, use

$$P_s = P_t - P_{v,o} \quad (17)$$

where

$P_s$  = fan static pressure, Pa

$P_t$  = fan total pressure, Pa

$P_{v,o}$  = fan outlet velocity pressure, Pa

## FLUID RESISTANCE

Duct system losses are the irreversible transformation of mechanical energy into heat. The two types of losses are (1) friction losses and (2) dynamic losses.

### FRICITION LOSSES

Friction losses are due to fluid viscosity and result from momentum exchange between molecules (in laminar flow) or between individual particles of adjacent fluid layers moving at different velocities (in turbulent flow). Friction losses occur along the entire duct length.

#### Darcy and Colebrook Equations

For fluid flow in conduits, friction loss can be calculated by the Darcy equation:

$$\Delta p_f = \frac{1000 f L}{D_h} \times \frac{\rho V^2}{2} \quad (18)$$

where

$\Delta p_f$  = friction losses in terms of total pressure, Pa

$f$  = friction factor, dimensionless

$L$  = duct length, m

$D_h$  = hydraulic diameter [Equation (24)], mm

$V$  = velocity, m/s

$\rho$  = density, kg/m<sup>3</sup>

In the region of laminar flow (Reynolds numbers less than 2000), the friction factor is a function of Reynolds number only.

For completely turbulent flow, the friction factor depends on Reynolds number, duct surface roughness, and internal protuberances (e.g., joints). Between the bounding limits of hydraulically smooth behavior and fully rough behavior is a transitional roughness zone where the friction factor depends on both roughness and Reynolds number. In this transitionally rough, turbulent zone, the friction factor  $f$  is calculated by Colebrook's equation (Colebrook 1938-1939). This transition curve merges asymptotically into the curves representing laminar and completely turbulent flow. Because Colebrook's equation cannot be solved explicitly for  $f$ , use iterative techniques (Behls 1971).

$$\frac{1}{f} = -2 \log \left( \frac{\epsilon}{3.7 D_h} + \frac{2.51}{\text{Re} \sqrt{f}} \right) \quad (19)$$

where

$\epsilon$  = material absolute roughness factor, mm

Re = Reynolds number

Reynolds number (Re) may be calculated by using the following equation.

$$\text{Re} = \frac{D_h V}{1000 \nu} \quad (20)$$

where  $\nu$  = kinematic viscosity, m<sup>2</sup>/s.

For standard air and temperature between 4 and 38°C, Re can be calculated by

$$\text{Re} = 66.4 D_h V \quad (21)$$

### Roughness Factors


Roughness factors  $\epsilon$  listed in [Table 1](#) are recommended for use with Equation (19). These values include not only material, but also duct construction, joint type, and joint spacing (Griggs and Khodabakhsh-Sharifabad 1992). Idelchik et al. (1994) summarize roughness factors for 80 materials, including metal tubes; conduits made from concrete and cement; and wood, plywood, and glass tubes.

Swim (1978) conducted tests on duct liners of varying densities, surface treatments, transverse joints (workmanship), and methods of attachment to sheet metal ducts. Results suggested using  $\epsilon = 4.6$  mm for spray-coated liners and  $\epsilon = 1.5$  mm for liners with a facing material adhered onto the air side. In both cases, the roughness factor includes resistance offered by mechanical fasteners, and assumes good joints. Liner density does not significantly influence flow resistance.

[Figure 8](#) or Equation (22) (Abushakra et al. 2002, 2004; Culp and Cantrill 2009) provides pressure loss correction factors for compressed flexible ducts ranging in size from 150 to 400 mm. Flexible ducts exhibit considerable variation in pressure loss, which can be in the ±15 to 25% range, because of differences in manufacturing, materials, test setup (compression over the full length of duct), inner liner nonuniformities, installation, and draw-through or blow-through applications. Pressure drop correction factors should be

**Table 1 Duct Roughness Factors**

Duct Material	Roughness Category	Absolute Roughness $\epsilon$ , ft
Uncoated carbon steel, clean (Moody 1944) (0.05 mm)	Smooth	0.03
PVC plastic pipe (Swim 1982) (0.01 to 0.05 mm)		
Aluminum (Hutchinson 1953) 0.04 to 0.06 mm		
Galvanized steel, longitudinal seams, 200 mm joints (Griggs et al. 1987) (0.05 to 0.10 mm)	Medium-smooth	0.09
Galvanized steel, continuously rolled, spiral seams, 3000 mm joints (Jones 1979) (0.06 to 0.12 mm)		
Galvanized steel, spiral seam with 1, 2, and 3 ribs, 3600 mm joints (Griggs et al. 1987) (0.09 to 0.12 mm)		
Galvanized steel, longitudinal seams, 760 mm joints (Wright 1945) (0.15 mm)	Average	0.15
Galvanized steel, spiral, corrugated, 3600 mm joints (Kulkarni et al. 2009) (0.74 mm)	Medium-rough	0.9
Fibrous glass duct, rigid		
Fibrous glass duct liner, air side with facing material (Swim 1978) (1.5 mm)		
Flexible duct, fabric and wire, fully extended		
Fibrous glass duct liner, air side spray coated (Swim 1978) (4.6 mm)	Rough	3.0
Flexible duct, metallic (1.2 to 2.1 mm when fully extended)		
Concrete (Moody 1944) (1.3 to 3.0 mm)		



**Fig. 8 Pressure Loss Correction Factor for Flexible Duct Not Fully Extended**

applied to medium-rough ducts ( $\epsilon = 0.9 \text{ mm}$ ); they can be obtained by multiplying the values from the friction chart for galvanized ducts (Figure 9) by 1.55, where ( $\epsilon = 0.09 \text{ mm}$ ).

For commercial systems, flexible ducts should be

- Limited to connections between duct branches and diffusers or variable-air-volume (VAV) terminal units
- No more than 1.5 m in length, fully stretched
- Installed without any radial compression (kinks)
- Not used in lieu of fittings

For 150 to 400 mm ducts that are 70% extended, pressure losses can be three to nine times greater than those for a fully extended flexible duct of the same diameter.

$$\text{PDCF} = 1 + 58r_c e^{-0.00496D} \quad (22)$$

with

$$r_c = 1 - (L/L_{FE}) \quad (23)$$

where

- PDCF = pressure drop correction factor  
 $r_c$  = compression ratio, dimensionless  
 $D$  = flexible duct diameter, mm  
 $L$  = installed duct length, m  
 $L_{FE}$  = duct length fully extended, m

### Friction Chart

Fluid resistance caused by friction in round ducts can be determined by the friction chart (Figure 9). This chart is based on standard air flowing through round galvanized ducts with beaded slip couplings on 1220 mm centers, equivalent to an absolute roughness of 0.09 mm.

Changes in barometric pressure, temperature, and humidity affect air density, air viscosity, and Reynolds number. No corrections to Figure 9 are needed for (1) duct materials with a medium-smooth roughness factor, (2) temperature variations of  $\pm 15 \text{ K}$  from  $20^\circ\text{C}$ , (3) elevations to 500 m, and (4) duct pressures from  $-5$  to

$+5 \text{ kPa}$  relative to ambient pressure. These individual variations in temperature, elevation, and duct pressure result in duct losses within  $\pm 5\%$  of the standard air friction chart.

For duct materials not categorized as medium-smooth in Table 1, and for variations in temperature, barometric pressure (elevation), and duct pressures (outside the range listed), calculate friction loss in a duct by the Colebrook and Darcy equations [Equations (19) and (18), respectively].

### Noncircular Ducts

A momentum analysis can relate average wall shear stress to pressure drop per unit length for fully developed turbulent flow in a passage of arbitrary shape but uniform longitudinal cross-sectional area. This analysis leads to the definition of **hydraulic diameter**:

$$D_h = 4A/P \quad (24)$$

where

- $D_h$  = hydraulic diameter, mm  
 $A$  = duct area,  $\text{mm}^2$   
 $P$  = perimeter of cross section, mm

Although hydraulic diameter is often used to correlate noncircular data, exact solutions for laminar flow in noncircular passages show that this causes some inconsistencies. No exact solutions exist for turbulent flow. Tests over a limited range of turbulent flow indicated that fluid resistance is the same for equal lengths of duct for equal mean velocities of flow if the ducts have the same ratio of cross-sectional area to perimeter. From experiments using round, square, and rectangular ducts having essentially the same hydraulic diameter, Huebscher (1948) found that each, for most purposes, had the same flow resistance at equal mean velocities. Tests by Griggs and Khodabakhsh-Sharifabad (1992) also indicated that experimental rectangular duct data for airflow over the range typical of HVAC systems can be correlated satisfactorily using Equation (19) together with hydraulic diameter, particularly when a realistic experimental uncertainty is accepted. These tests support using hydraulic diameter to correlate noncircular duct data.

**Rectangular Ducts.** Huebscher (1948) developed the relationship between rectangular and round ducts that is used to determine size equivalency based on equal flow, resistance, and length. This relationship, Equation (25), is the basis for Table 2.

$$D_e = \frac{1.30(ab)^{0.625}}{(a+b)^{0.250}} \quad (25)$$

where

- $D_e$  = circular equivalent of rectangular duct for equal length, fluid resistance, and airflow, mm  
 $a$  = length one side of duct, mm  
 $b$  = length adjacent side of duct, mm

To determine equivalent round duct diameter, use Table 2. Equations (18) and (19) must be used to determine pressure loss.

**Flat Oval Ducts.** To convert round ducts to flat oval sizes, use Table 3, which is based on Equation (26) (Heyt and Diaz 1975), the circular equivalent of a flat oval duct for equal airflow, resistance, and length. Equations (18) and (19) must be used to determine friction loss.

$$D_e = \frac{1.55AR^{0.625}}{P^{0.250}} \quad (26)$$

where  $AR$  is the cross-sectional area of flat oval duct defined as

$$AR = (\pi a^2/4) + a(A - a) \quad (27)$$

and the perimeter  $P$  is calculated by




Fig. 9 Friction Chart for Round Duct ( $\rho = 1.20 \text{ kg/m}^3$  and  $\varepsilon = 0.09 \text{ mm}$ )

$$P = \pi a + 2(A - a) \quad (28)$$

where

- $P$  = perimeter of flat oval duct, mm
- $A$  = major axis of flat oval duct, mm
- $a$  = minor axis of flat oval duct, mm

## DYNAMIC LOSSES

Dynamic losses result from flow disturbances caused by duct-mounted equipment and fittings (e.g., entries, exits, elbows, transitions, and junctions) that change the airflow path's direction and/or area. Idelchik et al. (1994) discuss parameters affecting fluid resistance of fittings and presents local loss coefficients in three forms: tables, curves, and equations.

### Local Loss Coefficients

The dimensionless coefficient  $C$  is used for fluid resistance, because this coefficient has the same value in dynamically similar streams (i.e., streams with geometrically similar stretches, equal Reynolds numbers, and equal values of other criteria necessary for dynamic similarity). The fluid resistance coefficient represents the ratio of total pressure loss to velocity pressure at the referenced cross section:

$$C = \frac{\Delta p_j}{\rho(V^2/2)} = \frac{\Delta p_j}{p_v} \quad (29)$$

where

- $C$  = local loss coefficient, dimensionless
- $\Delta p_j$  = total pressure loss, Pa
- $\rho$  = density, kg/m<sup>3</sup>
- $V$  = velocity, m/s
- $p_v$  = velocity pressure, Pa

Dynamic losses occur along a duct length and cannot be separated from friction losses. For ease of calculation, dynamic losses are assumed to be concentrated at a section (local) and exclude friction. Frictional losses must be considered only for relatively long fittings. Generally, fitting friction losses are accounted for by measuring duct lengths from the centerline of one fitting to that of the next fitting. For fittings closely coupled (less than six hydraulic diameters apart), the flow pattern entering subsequent fittings differs from the flow pattern used to determine loss coefficients. Adequate data for these situations are unavailable.

For all fittings, except junctions, calculate the total pressure loss  $\Delta p_j$  at a section by

$$\Delta p_j = C_o p_{v,o} \quad (30)$$

where the subscript  $o$  is the cross section at which the velocity pressure is referenced. Dynamic loss is based on the actual velocity in the duct, not the velocity in an equivalent circular duct. For the cross section to reference a fitting loss coefficient, see step 4 in the section on HVAC Duct Design Procedures. Where necessary (e.g., unequal-area fittings), convert a loss coefficient from section  $o$  to section  $i$  using Equation (31), where  $V$  is the velocity at the respective sections.

$$C_i = \frac{C_o}{(V_i/V_o)^2} \quad (31)$$

For converging and diverging flow junctions, total pressure losses through the straight (main) section are calculated as

$$\Delta p_j = C_{c,s} p_{v,c} \quad (32)$$

For total pressure losses through the branch section,

$$\Delta p_j = C_{c,b} p_{v,c} \quad (33)$$

where  $p_{v,c}$  is the velocity pressure at the common section  $c$ , and  $C_{c,s}$  and  $C_{c,b}$  are loss coefficients for the straight (main) and branch flow paths, respectively, each referenced to the velocity pressure at section  $c$ . To convert junction local loss coefficients referenced to straight and branch velocity pressures, use the following equation:

$$C_i = \frac{C_{c,i}}{(V_i/V_c)^2} \quad (34)$$

where

- $C_i$  = local loss coefficient referenced to section being calculated (see subscripts), dimensionless

- $C_{c,i}$  = straight ( $C_{c,s}$ ) or branch ( $C_{c,b}$ ) local loss coefficient referenced to dynamic pressure at common section, dimensionless

- $V_i$  = velocity at section to which  $C_i$  is being referenced, m/s

- $V_c$  = velocity at common section, m/s

Subscripts:

- $b$  = branch

- $s$  = straight (main) section

- $c$  = common section

The junction of two parallel streams moving at different velocities is characterized by turbulent mixing of the streams, accompanied by pressure losses. In the course of this mixing, momentum is exchanged between particles moving at different velocities, resulting in equalization of the velocity distributions in the common stream. The jet with higher velocity loses part of its kinetic energy by transmitting it to the slower jet. The loss in total pressure before and after mixing is always large and positive for the higher-velocity jet, and increases with an increase in the amount of energy transmitted to the lower-velocity jet. Consequently, the local loss coefficient [Equation (29)] is always positive. Energy stored in the lower-velocity jet increases because of mixing. The loss in total pressure and the local loss coefficient can, therefore, also have negative values for the lower velocity jet (Idelchik et al. 1994).

### Duct Fitting Database

A duct fitting database that includes more than 220 round, flat oval, and rectangular fittings is available from ASHRAE (2009).

The fittings are numbered (coded) as shown in Table 4. Entries and converging junctions are only in the exhaust/return portion of systems. Exits and diverging junctions are only in supply systems. Equal-area elbows, obstructions, and duct-mounted equipment are common to both supply and exhaust systems. Transitions and unequal-area elbows can be either supply or exhaust fittings. Fitting ED5-1 (see the section on Fitting Loss Coefficients) is an Exhaust fitting with a round shape (Diameter). The number 5 indicates that the fitting is a junction, and 1 is its sequential number. Fittings SR31 and ER3-1 are Supply and Exhaust fittings, respectively. The R indicates that the fitting is Rectangular, and the 3 identifies the fitting as an elbow. Note that the cross-sectional areas at sections 0 and 1 are not equal (see the section on Fitting Loss Coefficients). Otherwise, the elbow would be a Common fitting such as CR3-6. Additional fittings are reproduced in the section on Fitting Loss Coefficients to support the example design problems (see Table 10 for Example 6; see Table 12 for Example 7).

### Bends in Flexible Duct

Abushakra et al. (2002) show that loss coefficients for bends in flexible ductwork vary widely from condition to condition, with no uniform or consistent trends. Loss coefficients range from a low of 0.87 to a high of 3.27. Flexible duct elbows should not be used in lieu of rigid elbows.

Table 2 Circular Equivalents of Rectangular Duct for Equal Friction and Capacity<sup>a</sup>

Lgth Adj. <sup>b</sup>	Length of One Side of Rectangular Duct <i>a</i> , mm																			
	100	125	150	175	200	225	250	275	300	350	400	450	500	550	600	650	700	750	800	900
100	109																			
125	122	137																		
150	133	150	164																	
175	143	161	177	191																
200	152	172	189	204	219															
225	161	181	200	216	232	246														
250	169	190	210	228	244	259	273													
275	176	199	220	238	256	272	287	301												
300	183	207	229	248	266	283	299	314	328											
350	195	222	245	267	286	305	322	339	354	383										
400	207	235	260	283	305	325	343	361	378	409	437									
450	217	247	274	299	321	343	363	382	400	433	464	492								
500	227	258	287	313	337	360	381	401	420	455	488	518	547							
550	236	269	299	326	352	375	398	419	439	477	511	543	573	601						
600	245	279	310	339	365	390	414	436	457	496	533	567	598	628	656					
650	253	289	321	351	378	404	429	452	474	515	553	589	622	653	683	711				
700	261	298	331	362	391	418	443	467	490	533	573	610	644	677	708	737	765			
750	268	306	341	373	402	430	457	482	506	550	592	630	666	700	732	763	792	820		
800	275	314	350	383	414	442	470	496	520	567	609	649	687	722	755	787	818	847	875	
900	289	330	367	402	435	465	494	522	548	597	643	686	726	763	799	833	866	897	927	984
1000	301	344	384	420	454	486	517	546	574	626	674	719	762	802	840	876	911	944	976	1037
1100	313	358	399	437	473	506	538	569	598	652	703	751	795	838	878	916	953	988	1022	1086
1200	324	370	413	453	490	525	558	590	620	677	731	780	827	872	914	954	993	1030	1066	1133
1300	334	382	426	468	506	543	577	610	642	701	757	808	857	904	948	990	1031	1069	1107	1177
1400	344	394	439	482	522	559	595	629	662	724	781	835	886	934	980	1024	1066	1107	1146	1220
1500	353	404	452	495	536	575	612	648	681	745	805	860	913	963	1011	1057	1100	1143	1183	1260
1600	362	415	463	508	551	591	629	665	700	766	827	885	939	991	1041	1088	1133	1177	1219	1298
1700	371	425	475	521	564	605	644	682	718	785	849	908	964	1018	1069	1118	1164	1209	1253	1335
1800	379	434	485	533	577	619	660	698	735	804	869	930	988	1043	1096	1146	1195	1241	1286	1371
1900	387	444	496	544	590	663	674	713	751	823	889	952	1012	1068	1122	1174	1224	1271	1318	1405
2000	395	453	506	555	602	646	688	728	767	840	908	973	1034	1092	1147	1200	1252	1301	1348	1438
2100	402	461	516	566	614	659	702	743	782	857	927	993	1055	1115	1172	1226	1279	1329	1378	1470
2200	410	470	525	577	625	671	715	757	797	874	945	1013	1076	1137	1195	1251	1305	1356	1406	1501
2300	417	478	534	587	636	683	728	771	812	890	963	1031	1097	1159	1218	1275	1330	1383	1434	1532
2400	424	486	543	597	647	695	740	784	826	905	980	1050	1116	1180	1241	1299	1355	1409	1461	1561
2500	430	494	552	606	658	706	753	797	840	920	996	1068	1136	1200	1262	1322	1379	1434	1488	1589
2600	437	501	560	616	668	717	764	810	853	935	1012	1085	1154	1220	1283	1344	1402	1459	1513	1617
2700	443	509	569	625	678	728	776	822	866	950	1028	1102	1173	1240	1304	1366	1425	1483	1538	1644
2800	450	516	577	634	688	738	787	834	879	964	1043	1119	1190	1259	1324	1387	1447	1506	1562	1670
2900	456	523	585	643	697	749	798	845	891	977	1058	1135	1208	1277	1344	1408	1469	1529	1586	1696

Length of One Side of Rectangular Duct *a*, mm

Lgth Adj. <sup>b</sup>	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400	2500	2600	2700	2800	2900
	Circular Duct Diameter, mm																			
1000	1093																			
1100	1146	1202																		
1200	1196	1256	1312																	
1300	1244	1306	1365	1421																
1400	1289	1354	1416	1475	1530															
1500	1332	1400	1464	1526	1584	1640														
1600	1373	1444	1511	1574	1635	1693	1749													
1700	1413	1486	1555	1621	1684	1745	1803	1858												
1800	1451	1527	1598	1667	1732	1794	1854	1912	1968											
1900	1488	1566	1640	1710	1778	1842	1904	1964	2021	2077										
2000	1523	1604	1680	1753	1822	1889	1952	2014	2073	2131	2186									
2100	1558	1640	1719	1793	1865	1933	1999	2063	2124	2183	2240	2296								
2200	1591	1676	1756	1833	1906	1977	2044	2110	2173	2233	2292	2350	2405							
2300	1623	1710	1793	1871	1947	2019	2088	2155	2220	2283	2343	2402	2459	2514						
2400	1655	1744	1828	1909	1986	2060	2131	2200	2266	2330	2393	2453	2511	2568	2624					
2500	1685	1776	1862	1945	2024	2100	2173	2243	2311	2377	2441	2502	2562	2621	2678	2733				
2600	1715	1808	1896	1980	2061	2139	2213	2285	2355	2422	2487	2551	2612	2672	2730	2787	2842			
2700	1744	1839	1929	2015	2097	2177	2253	2327	2398	2466	2533	2598	2661	2722	2782	2840	2896	2952		
2800	1772	1869	1961	2048	2133	2214	2292	2367	2439	2510	2578	2644	2708	2771	2832	2891	2949	3006	3061	
2900	1800	1898	1992	2081	2167	2250	2329	2406	2480	2552	2621	2689	2755	2819	2881	2941	3001	3058	3115	3170

<sup>a</sup>Table based on  $D_e = 1.30(ab)^{0.625}/(a+b)^{0.25}$ .<sup>b</sup>Length adjacent side of rectangular duct *b*, mm.

Table 3 Equivalent Flat Oval Duct Dimensions

Circular Duct Diameter, mm	Minor Axis <i>a</i> , mm															
	70	100	125	150	175	200	250	275	300	325	350	375	400	450	500	550
	Major Axis <i>A</i> , mm															
125	205															
140	265	180														
160	360	235	190													
180	475	300	235	200												
200		380	290	245	215											
224		490	375	305	—	240										
250		475	385	325	290											
280			485	410	360	—	285									
315			635	525	—	—	345	325								
355			840	—	580	460	425	395	375							
400			1115	—	760	—	530	490	460	435						
450			1490	—	995	—	675	—	570	535	505					
500					1275	—	845	—	700	655	615	580				
560					1680	—	1085	—	890	820	765	720				
630							1425	—	1150	1050	970	905	810			
710									1505	1370	1260	1165	1025			
800									1800	1645	1515	1315	1170	1065		
900										2165	1985	1705	1500	1350		
1000											2170	1895	1690			
1120												2455	2170	1950		
1250												2795	2495			

Table 4 Duct Fitting Codes

Fitting Function	Geometry	Category	Sequential Number
S: Supply	D: round (Diameter)	1. Entries 2. Exits	1,2,3...n
E: Exhaust/Return	R: Rectangular	3. Elbows 4. Transitions	
C: Common (supply and return)	F: Flat oval	5. Junctions 6. Obstructions 7. Fan and system interactions 8. Duct-mounted equipment 9. Dampers 10. Hoods	

## DUCTWORK SECTIONAL LOSSES

### Darcy-Weisbach Equation

Total pressure loss in a duct section is calculated by combining Equations (18) and (29) in terms of  $\Delta p$ , where  $\Sigma C$  is the summation of local loss coefficients in the duct section. Each fitting loss coefficient must be referenced to that section's velocity pressure.

$$\Delta p = \left( \frac{1000fL}{D_h} + \Sigma C \right) \left( \frac{\rho V^2}{2} \right) \quad (35)$$

## FAN/SYSTEM INTERFACE

### Fan Inlet and Outlet Conditions

Fan performance data measured in the field may show lower performance capacity than manufacturers' ratings. The most common causes of deficient performance of the fan/system combination are improper outlet connections, nonuniform inlet flow, and swirl at the fan inlet. These conditions alter the fan's aerodynamic

characteristics so that its full flow potential is not realized. One bad connection can reduce fan performance far below its rating. No data have been published that account for the effects of fan inlet and outlet flexible vibration connectors.

Normally, a fan is tested with open inlets and a section of straight duct attached to the outlet (ASHRAE Standard 51). This setup results in uniform flow into the fan and efficient static pressure recovery on the fan outlet. If good inlet and outlet conditions are not provided in the actual installation, the performance of the fan suffers. To select and apply the fan properly, these effects must be considered, and the pressure requirements of the fan, as calculated by standard duct design procedures, must be increased.

Figure 10 illustrates deficient fan/system performance. System pressure losses have been determined accurately, and a fan has been selected for operation at point 1. However, no allowance has been made for the effect of system connections to the fan on fan performance. To compensate, a fan system effect must be added to the calculated system pressure losses to determine the actual system curve. The point of intersection between the fan performance curve and the actual system curve is point 4. The actual flow volume is, therefore, deficient by the difference from 1 to 4. To achieve design flow volume, a fan system effect pressure loss equal to the pressure difference between points 1 and 2 should be added to the calculated system pressure losses, and the fan should be selected to operate at point 2.

### Fan System Effect Coefficients

The system effect concept was formulated by Farquhar (1973) and Meyer (1973); the magnitudes of the system effect, called **system effect factors**, were determined experimentally by the Air Movement and Control Association (AMCA 2007a; Brown 1973; Clarke et al. 1978). The system effect factors, converted to local loss coefficients, are in the *ASHRAE Duct Fitting Database* (2009) for both centrifugal and axial fans. Fan system effect coefficients are only an approximation. Fans of different types and even fans of the same type, but supplied by different manufacturers, do not

necessarily react to a system in the same way. Therefore, judgment based on experience must be applied to any design.

**Fan Outlet Conditions.** Fans intended primarily for duct systems are usually tested with an outlet duct in place (ASHRAE Standard 51). Figure 11 shows the changes in velocity profiles at various

distances from the fan outlet. For 100% recovery, the duct, including transition, must meet the requirements for 100% effective duct length [ $L_e$  (Figure 11)], which is calculated as follows:

For  $V_o > 13$  m/s,

$$L_e = \frac{V_o \sqrt{A_o}}{4500} \quad (36)$$

For  $V_o \leq 13$  m/s,

$$L_e = \frac{\sqrt{A_o}}{350} \quad (37)$$

where

$V_o$  = duct velocity, m/s

$L_e$  = effective duct length, m

$A_o$  = duct area, mm<sup>2</sup>

As illustrated by Fitting SR7-1 in the section on Fitting Loss Coefficients, centrifugal fans should not abruptly discharge to the atmosphere. A diffuser design should be selected from Fitting SR7-2 (see the section on Fitting Loss Coefficients) or SR7-3 [see ASHRAE (2009)].

**Fan Inlet Conditions.** For rated performance, air must enter the fan uniformly over the inlet area in an axial direction without prerotation. Nonuniform flow into the inlet is the most common cause of reduced fan performance. Such inlet conditions are not equivalent to a simple increase in system resistance; therefore, they cannot be treated as a percentage decrease in the flow and pressure from the fan. A poor inlet condition results in an entirely new fan performance. An elbow at the fan inlet, for example Fitting ED7-2 (see the




Fig. 10 Deficient System Performance with System Effect Ignored




Fig. 11 Establishment of Uniform Velocity Profile in Straight Fan Outlet Duct  
(Adapted by permission from AMCA Publication 201)

section on Fitting Loss Coefficients), causes turbulence and uneven flow into the fan impeller. Losses from the fan system effect can be eliminated by including an adequate length of straight duct between the elbow and the fan inlet.


The ideal inlet condition allows air to enter axially and uniformly without spin. A spin in the same direction as the impeller rotation reduces the pressure/volume curve by an amount dependent on the vortex's intensity. A counterrotating vortex at the inlet slightly increases the pressure/volume curve, but the power is increased substantially.

Inlet spin may arise from many different approach conditions, and sometimes the cause is not obvious. Inlet spin can be avoided by providing an adequate length of straight duct between the elbow and the fan inlet. **Figure 12** illustrates some common duct connections that cause inlet spin and includes recommendations for correcting spin.

Fans within plenums and cabinets or next to walls should be located so that air may flow unobstructed into the inlets. Fan performance is reduced if the space between the fan inlet and the enclosure is too restrictive. System effect coefficients for fans in an enclosure or adjacent to walls are listed under Fitting ED7-1 (see the section on Fitting Loss Coefficients). How the airstream enters an enclosure in relation to the fan inlets also affects fan performance. Plenum or enclosure inlets or walls that are not symmetrical with the fan inlets cause uneven flow and/or inlet spin.

### Testing, Adjusting, and Balancing Considerations

Fan system effects (FSEs) are not only to be used in conjunction with the system resistance characteristics in the fan selection process, but are also applied in the calculations of the results of testing, adjusting, and balancing (TAB) field tests to allow direct comparison to design calculations and/or fan performance data. Fan inlet swirl and the effect on system performance of poor fan inlet and outlet ductwork connections cannot be measured directly. Poor inlet flow patterns affect fan performance within the impeller wheel (centrifugal fan) or wheel rotor impeller (axial fan), while the fan outlet system effect is flow instability and turbulence within the fan discharge ductwork.



**Fig. 12 Inlet Duct Connections Causing Inlet Spin and Corrections for Inlet Spin**

(Adapted by permission from AMCA Publication 201)

The static pressure at the fan inlet and the static pressure at the fan outlet may be measured directly in some systems. In most cases, static pressure measurements for use in determining fan total (or static) pressure will not be made directly at the fan inlet and outlet, but at locations a relatively short distance from the fan inlet and downstream from the fan outlet. To calculate fan total pressure for this case from field measurements, use Equation (38), where  $\Delta p_{x-y}$  is the summation of calculated total pressure losses between the fan inlet and outlet sections noted. Plane 3 is used to determine airflow rate. If necessary, use Equation (17) to calculate fan static pressure knowing fan total pressure. For locating measurement planes and calculation procedures, consult AMCA Publication 203 (AMCA 2007b).

$$P_t = (p_{s,5} + p_{v,5}) + \Delta p_{2-5} + FSE_2 + (p_{s,4} + p_{v,4}) + \Delta p_{4-1} + FSE_1 + FSE_{1,sw} \quad (38)$$

where

$P_t$  = fan total pressure, Pa

$p_s$  = static pressure, Pa

$p_v$  = velocity pressure, Pa

FSE = fan system effect, Pa

$\Delta p_{x-y}$  = summarization of total pressure losses between planes  $x$  and  $y$ , Pa

Subscripts [numerical subscripts same as used by AMCA (2007b)]:

1 = fan inlet

2 = fan outlet

3 = plane of airflow measurement

4 = plane of static pressure measurement upstream of fan

5 = plane of static pressure measurement downstream of fan

$sw$  = swirl

## DUCT SYSTEM DESIGN

### DESIGN CONSIDERATIONS

#### Space Pressure Relationships

Space pressure is determined by fan location and duct system arrangement. For example, a supply fan that pumps air into a space increases space pressure; an exhaust fan reduces space pressure. If both supply and exhaust fans are used, space pressure depends on the relative capacity of the fans. Space pressure is positive if supply exceeds exhaust and negative if exhaust exceeds supply (Osborne 1966). System pressure variations caused by wind can be minimized or eliminated by careful selection of intake air and exhaust vent locations (see **Chapter 24**).

#### Fire and Smoke Management

Because duct systems can convey smoke, hot gases, and fire from one area to another and can accelerate a fire within the system, fire protection is an essential part of air-conditioning and ventilation system design. Generally, fire safety codes require compliance with the standards of national organizations. NFPA Standard 90A examines fire safety requirements for (1) ducts, connectors, and appurtenances; (2) plenums and corridors; (3) air outlets, air inlets, and fresh air intakes; (4) air filters; (5) fans; (6) electric wiring and equipment; (7) air-cooling and -heating equipment; (8) building construction, including protection of penetrations; and (9) controls, including smoke control.

Fire safety codes often refer to the testing and labeling practices of nationally recognized laboratories, such as Factory Mutual and Underwriters Laboratories (UL). UL's annual *Building Materials Directory* lists fire and smoke dampers that have been tested and meet the requirements of UL Standards 555 and 555S. This directory also summarizes maximum allowable sizes for individual dampers and assemblies of these dampers. Fire dampers are 1.5 h or 3 h fire-rated. Smoke dampers are classified by (1) temperature degradation [ambient air or high temperature (120°C minimum)] and

(2) leakage at 250 and 1000 Pa pressure difference (2 and 3 kPa classification optional). Smoke dampers are tested under conditions of maximum airflow. UL's annual *Fire Resistance Directory* lists fire resistances of floor/roof and ceiling assemblies with and without ceiling fire dampers.

For a more detailed presentation of fire protection, see the NFPA (2008) *Fire Protection Handbook*, Chapter 52 of the 2007 *ASHRAE Handbook—HVAC Applications*, and Klote and Milke (2002).

### Duct Insulation

In all new construction (except low-rise residential buildings), air-handling ducts and plenums that are part of an HVAC air distribution system should be thermally insulated in accordance with ASHRAE Standard 90.1. Duct insulation for new low-rise residential buildings should comply with ASHRAE Standard 90.2. Existing buildings should meet requirements of ASHRAE Standard 100. In all cases, thermal insulation should meet local code requirements. Insulation thicknesses in these standards are minimum values; economic and thermal considerations may justify higher insulation levels. Additional insulation, vapor retarders, or both may be required to limit vapor transmission and condensation.

Duct heat gains or losses must be known to calculate supply air quantities, supply air temperatures, and coil loads. To estimate duct heat transfer and entering or leaving air temperatures, refer to Chapter 23.

### Duct System Leakage

It is recommended that all transverse joints, longitudinal seams, and ductwork penetrations be sealed. **Longitudinal seams** are joints oriented in the direction of airflow. **Duct wall penetrations** are openings made by screws, non-self-sealing fasteners, pipe, tubing, rods, and wire. All other connections are considered **transverse joints**, which are connections of two duct or fitting elements oriented perpendicular to flow (e.g., spin-ins, taps, branch connections, duct connections to equipment). System (ductwork and equipment) leakage should be tested to verify the installing contractor's workmanship and sealing practices.

Leakage in all unsealed ducts varies considerably with the fabricating machinery used, material thickness, assembly methods, and installation workmanship. For sealed ducts, a wide variety of sealing methods and products exists. Sealed and unsealed duct leakage tests (AISI/SMACNA 1972; ASHRAE/SMACNA/TIMA 1985; Swim and Griggs 1995) confirmed that longitudinal seam, transverse joint, and assembled duct leakage can be represented by Equation (39) and that, for the same construction, leakage is not significantly different in negative and positive modes. Table 5 presents a range of leakage rates for longitudinal seams commonly used in metal duct construction. Longitudinal seam leakage for unsealed or unwelded metal ducts is about 10 to 15% of total duct leakage.

$$Q = C \Delta p_n^N \quad (39)$$

where

$Q$  = duct leakage rate,  $\text{L}/(\text{s} \cdot \text{m}^2)$

$C$  = constant reflecting area characteristics of leakage path

$\Delta p_s$  = static pressure differential from duct interior to exterior, Pa

$N$  = exponent relating turbulent or laminar flow in leakage path

The AISI/ASHRAE/SMACNA/TIMA data showed that duct leakage (equipment not included) is best predicted by duct surface area and pressure, because surface area highlights the effect of system size. Duct leakage were grouped into a geometric series of **leakage classes  $C_L$**  (Figure 13) based on Equation (40), where the exponent  $N$  is assumed to be 0.65. Table 6 shows leakage classes for commonly used duct construction and sealing practices (equipment leakage excluded).




Fig. 13 Duct Leakage Classifications

Table 5 Unsealed Longitudinal Seam Leakage, Metal Ducts

Type of Duct/Seam	Leakage, L per metre Seam Length*	
	Range	Average
Rectangular		
Pittsburgh lock		
26 gage	0.015 to 0.03	0.025
22 gage	0.0015 to 0.003	0.0025
Button punch snaplock		
26 gage	0.05 to 0.23	0.12
22 gage	NA (1 test)	0.005
Round		
Spiral (26 gage)	NA (1 test)	0.023
Snaplock	0.06 to 0.22	0.17
Grooved	0.17 to 0.28	0.19

\*Leakage rate is at 250 Pa static pressure.

$$C_L = Q / \Delta p_n^{0.65} \quad (40)$$

where

$Q$  = leakage rate,  $\text{L}/(\text{s} \cdot \text{m}^2)$  (surface area)

$C_L$  = leakage class,  $\text{L}/(\text{s} \cdot \text{m}^2)$  duct surface at 1 Pa static pressure

Effects of equipment leakage (e.g., through dampers, access doors, VAV boxes, diffusers) should be anticipated. Ductwork should not be expected to compensate for equipment leakage. Terminal units may leak 1 to 2% of their maximum flow. Use Table 6 to calculate allowable ductwork leakage for a system. Leakage classes listed in Table 6 are for a specific duct type, not a system with a variety of duct types. When several pressure classifications or shapes occur in a system, ductwork in each class or shape should be evaluated independently to find an aggregate leakage for the system. System leakage (ductwork plus equipment) values for use in specifications should be in terms of  $\text{L}/\text{s}$  at the pressure(s) leakage was determined. The estimated percent leakage for any section of ductwork can be determined from Table 7 (equipment leakage not included).

Limited performance standards for metal duct sealants and tapes exist. For guidance in their selection and use, refer to SMACNA's

**Table 6 Duct Leakage Classification<sup>a</sup>**

Duct Type	Sealed <sup>b,c</sup>		Unsealed <sup>c</sup>	
	Predicted Leakage Class $C_L$	Leakage Rate, L/(s·m <sup>2</sup> ) at 250 Pa	Predicted Leakage Class $C_L$	Leakage Rate, L/(s·m <sup>2</sup> ) at 250 Pa
Metal (flexible excluded)				
Round and flat oval	4	0.14	42 (8 to 99)	1.5 (0.3 to 3.6)
Rectangular	17	0.62	68 (17 to 155)	2.5 (0.6 to 5.6)
Flexible				
Metal, aluminum	11	0.40	42 (17 to 76)	1.5 (0.6 to 2.8)
Nonmetal	17	0.62	30 (6 to 76)	1.5 (0.2 to 2.8)
Fibrous glass				
Round	4	0.14	NA	NA
Rectangular	8	0.29	NA	NA

<sup>a</sup>Leakage classes here are averages based on tests conducted by AISI/SMACNA (1972), ASHRAE/SMACNA/TIMA (1985), and Swini and Griggs (1995).

<sup>b</sup>“Sealed” leakage classes assume that, for metal ducts, all transverse joints, seams, and openings in duct wall are sealed.

<sup>c</sup>Leakage classes anticipate about 0.82 joints per metre of duct. For systems with a high fitting-to-straight-duct ratio, greater leakage occurs in both sealed and unsealed conditions.

**Table 7 Leakage as Percentage of Airflow<sup>a,b</sup>**

Leakage Class	System Duct Surface <sup>c</sup> L/s per m <sup>2</sup>	Static Pressure, Pa					
		125	250	500	750	1000	1500
68	10	15	24	38	49	59	77
	12.7	12	19	30	39	47	62
	15	10	16	25	33	39	51
	20	7.7	12	19	25	30	38
	25	6.1	9.6	15	20	24	31
34	10	7.7	12	19	25	30	38
	12.7	6.1	9.6	15	20	24	31
	15	5.1	8.0	13	16	20	26
	20	3.8	6.0	9.4	12	15	19
	25	3.1	4.8	7.5	9.8	12	15
17	10	3.8	6	9.4	12	15	19
	12.7	3.1	4.8	7.5	9.8	12	15
	15	2.6	4.0	6.3	8.2	9.8	13
	20	1.9	3.0	4.7	6.1	7.4	9.6
	25	1.5	2.4	3.8	4.9	5.9	7.7
8	10	1.9	3	4.7	6.1	7.4	9.6
	12.7	1.5	2.4	3.8	4.9	5.9	7.7
	15	1.3	2.0	3.1	4.1	4.9	6.4
	20	1.0	1.5	2.4	3.1	3.7	4.8
	25	0.8	1.2	1.9	2.4	3.0	3.8
4	10	1.0	1.5	2.4	3.1	3.7	4.8
	12.7	0.8	1.2	1.9	2.4	3.0	3.8
	15	0.6	1.0	1.6	2.0	2.5	3.2
	20	0.5	0.8	1.3	1.6	2.0	2.6
	25	0.4	0.6	0.9	1.2	1.5	1.9

<sup>a</sup>Adapted with permission from *HVAC Air Duct Leakage Test Manual* (SMACNA 1985, Appendix A).

<sup>b</sup>Percentage applies to airflow entering a section of duct operating at an assumed pressure equal to average of upstream and downstream pressures.

<sup>c</sup>Ratios in this column are typical of fan volumetric flow rate divided by total system surface. Portions of systems may vary from these averages.

*HVAC Duct Construction Standards* (2005). Fibrous glass ducts and their closure systems are covered by UL *Standards 181* and *181A*. For fibrous glass duct construction standards, consult NAIMA (2002) and SMACNA (2003). Flexible duct performance and installation

**Table 8 Typical Design Velocities for HVAC Components**

Duct Element	Face Velocity, m/s
Louvers <sup>a</sup>	
Intake	
3300 L/s and greater	2
Less than 3300 L/s	See Figure 14
Exhaust	
2400 L/s and greater	2.5
Less than 2400 L/s	See Figure 14
Filters <sup>b</sup>	
Panel filters	
Viscous impingement	1 to 4
Dry-type, extended-surface	
Flat (low efficiency)	Duct velocity
Pleated media (intermediate efficiency)	Up to 3.8
HEPA	1.3
Renewable media filters	
Moving-curtain viscous impingement	2.5
Moving-curtain dry media	1
Electronic air cleaners	
Ionizing type	0.8 to 1.8
Heating Coils <sup>c</sup>	
Steam and hot water	
2.5 to 5	
1 min., 8 max.	
Electric	
Open wire	Refer to mfg. data
Finned tubular	Refer to mfg. data
Dehumidifying Coils <sup>d</sup>	2 to 3
Air Washers <sup>e</sup>	
Spray type	Refer to mfg. data
Cell type	Refer to mfg. data
High-velocity spray type	6 to 9

<sup>a</sup>Based on assumptions presented in text.

<sup>b</sup>Abstracted from Ch. 28, 2008 *ASHRAE Handbook—HVAC Systems and Equipment*.

<sup>c</sup>Abstracted from Ch. 26, 2008 *ASHRAE Handbook—HVAC Systems and Equipment*.

<sup>d</sup>Abstracted from Ch. 22, 2008 *ASHRAE Handbook—HVAC Systems and Equipment*.

<sup>e</sup>Abstracted from Ch. 40, 2008 *ASHRAE Handbook—HVAC Systems and Equipment*.


standards are covered by UL *Standards 181* and *181B* and ADC (2003). Soldered or welded duct construction is necessary where sealants are not suitable. Sealants used on exterior ducts must be resistant to weather, temperature cycles, sunlight, and ozone.

Shaft and compartment pressure changes affect duct leakage and are important to health and safety in the design and operation of contaminant and smoke control systems. Shafts should not be used for supply, return, and/or exhaust air without accounting for their leakage rates. Airflow around buildings, building component leakage, and the distribution of inside and outside pressures over the height of a building, including shafts, are discussed in Chapters 16 and 24.

### System Component Design Velocities

Table 8 summarizes face velocities for HVAC components in built-up systems. In most cases, the values are abstracted from pertinent chapters in the 2008 *ASHRAE Handbook—HVAC Systems and Equipment*; final selection of components should be based on data in these chapters or, preferably, from manufacturers.

Use Figure 14 for preliminary sizing of air intake and exhaust louvers. For air quantities greater than 3300 L/s per louver, the air intake gross louver openings are based on 2 m/s; for exhaust louvers, 2.5 m/s is used for air quantities of 2400 L/s per louver and greater. For smaller air quantities, refer to Figure 14. These criteria are presented on a per-louver basis (i.e., each louver in a bank of louvers) to include each louver frame. Representative production-run louvers were used in establishing Figure 14, and all data used were based on AMCA *Standard 500-L* tests. For louvers larger than



Parameters Used to Establish Figure	Intake Louver	Exhaust Louver
Minimum free area (1220 mm square test section), %	45	45
Water penetration, mL/(m²·0.25 h)	Negligible (less than 0.3)	N/A
Maximum static pressure drop, Pa	35	60

Fig. 14 Criteria for Louver Sizing

1.5 m<sup>2</sup>, the free areas are greater than 45%; for louvers less than 1.5 m<sup>2</sup>, free areas are less than 45%. Unless specific louver data are analyzed, no louver should have a face area less than 0.4 m<sup>2</sup>. If debris can collect on the screen of an intake louver, or if louvers are located at grade with adjacent pedestrian traffic, louver face velocity should not exceed 0.5 m/s.

Louvers require special treatment because the blade shapes, angles, and spacing cause significant variations in louver-free area and performance (pressure drop and water penetration). Selection and analysis should be based on test data obtained from the manufacturer in accordance with AMCA Standard 500-L, which presents both pressure drop and water penetration test procedures and a uniform method for calculating the free area of a louver. Tests are conducted on a 1220 mm square louver with the frame mounted flush in the wall. For water penetration tests, rainfall is 100 mm/h, no wind, and the water flow down the wall is 0.05 L/s per linear metre of louver width.

AMCA Standard 500-L also includes a method for measuring water rejection performance of louvers subjected to simulated rain and wind pressures. These louvers are tested at a rainfall of 76 mm/h falling on the louver's face with a predetermined wind velocity directed at the face of the louver (typically 13 or 20 m/s). Effectiveness ratings are assigned at various airflow rates through the louver.

### System and Duct Noise

The major sources of noise from air-conditioning systems are diffusers, grilles, fans, ducts, fittings, and vibrations. Chapter 47 of the 2007 ASHRAE Handbook—HVAC Applications discusses sound control for each of these sources, as well as methods for calculating required sound attenuation. Sound control for terminal devices consists of selecting devices that meet the design goal under all operating conditions and installing them properly so that no additional sound is generated. The sound power output of a fan is determined by the type of fan, airflow, and pressure. Sound control in the duct system requires proper duct layout, sizing, and provision for installing duct attenuators, if required. Noise generated by a system increases with both duct velocity and system pressure.

### Testing and Balancing

Each air duct system should be tested, adjusted, and balanced. Detailed procedures are given in Chapter 37 of the 2007 ASHRAE Handbook—HVAC Applications. To properly determine fan total (or static) pressure from field measurements taking into account fan system effect, see the section on Fan/System Interface. Equation (38) allows direct comparison of system resistance to design calculations and/or fan performance data. It is important that system effect magnitudes be known prior to testing. If necessary, use Equation (17) to calculate fan static pressure knowing fan total pressure [Equation (38)]. For TAB calculation procedures of numerous fan/system configurations encountered in the field, refer to AMCA (2007b).

### DUCT DESIGN METHODS

Duct design methods for HVAC systems and for exhaust systems conveying vapors, gases, and smoke are the equal-friction method, the static regain method, and the T-method. The section on Industrial Exhaust System Duct Design presents the design criteria and procedures for exhaust systems conveying particulates. Equal friction and static regain are nonoptimizing methods, and the T-method is a practical optimization method introduced by Tsal et al. (1988).

To ensure that system designs are acoustically acceptable, noise generation should be analyzed and sound attenuators and/or acoustically lined duct provided where necessary.

#### Equal-Friction Method

In the equal-friction method, ducts are sized for a constant pressure loss per unit length. The shaded area of the friction chart (see Figure 9) is the suggested range of friction rate and air velocity. When energy cost is high and installed ductwork cost is low, a low-friction-rate design is more economical. For low energy cost and high duct cost, a higher friction rate is more economical. After initial sizing, calculate total pressure loss for all duct sections, and then resize sections to balance pressure losses at each junction.

#### Static Regain Method

This design method is only applicable to supply air systems. The objective is to obtain the same static pressure at diverging flow junctions by changing downstream duct sizes. This design objective can be developed by rearranging Equation (7a) and setting  $p_{s,2}$  equal to  $p_{s,1}$  (neglecting thermal gravity effect term). This means that the change in static pressure from one section to another is zero, which is satisfied when the change in total pressure is equal to the change in velocity pressure. Thus,

$$p_{s,1} - p_{s,2} = \Delta p_{t,1-2} - \left[ \frac{\rho V_1^2}{2} - \frac{\rho V_2^2}{2} \right] \quad (41)$$

and

$$\Delta p_{t,1-2} = \frac{\rho V_1^2}{2} - \frac{\rho V_2^2}{2} \quad (42)$$

where  $\Delta p_{t,1-2}$  is total pressure loss from upstream of junction 1 to upstream of junction 2. Junction 2 can be a terminal section, where the total pressure is zero. For each main section, the straight-through and branch sections immediately downstream of the main duct section are determined by iteration of that section's size until Equation (42) is satisfied. However, there could be cases when the straight or branch sections need to be larger than the upstream section to satisfy Equation (42). Fittings in the 2009 ASHRAE Duct Fitting Database have not been tested under these conditions, and making downstream sections larger than upstream sections is not practical. The largest straight-through or branch size should be limited to that of the upstream section. The imbalance that occurs is resolved during total-pressure balancing of the system.

To start system design, a maximum velocity is selected for the root section (duct section downstream of a fan). In [Figure 16](#), section 19 is the root for the supply air subsystem. The shaded area on the friction chart (see [Figure 9](#)) is the suggested range of air velocity. When energy cost is high and installed ductwork cost is low, a lower initial velocity is more economical. For low energy cost and high duct cost, a higher velocity is more economical.

Because terminal sections often require additional static pressure to operate VAV terminal boxes properly, that static pressure requirement is added into the section after it is sized using static regain. Otherwise, the downstream section could be larger than the upstream section. For calculating duct sizes, the total pressure losses of grilles, registers, diffusers, or constant-volume (CV) terminal boxes should be included in the sizing iterations.

**Total Pressure Balancing.** After completing duct sizing by the static regain method, any residual unbalance can be reduced or eliminated by calculating the system's total pressure (pressure required in the critical paths) and changing duct sizes or fittings in other paths to increase the paths' total pressure to approximate what is needed in the critical paths.

### T-Method

T-method optimization (Tsal et al. 1988) is a dynamic programming procedure based on Bellman's (1957) tee-staging idea, except that phase-level vector tracing is eliminated by optimizing locally at each stage. This modification reduces the number of calculations, but requires iteration.

Ductwork sizes are determined by minimizing the objective function:

$$E = E_p(\text{PWEF}) + E_s \quad (43)$$

where

$E$  = present-worth owning and operating cost

$E_p$  = first-year energy cost

$E_s$  = initial cost

PWEF = present worth escalation factor (Smith 1968), dimensionless

The objective function includes both initial system cost and present worth of energy. Hours of operation, annual escalation and interest rates, and amortization period are also required for optimization.

The following constraints are necessary for duct optimization (Tsal and Adler 1987):

- *Continuity.* For each node, flow in equals flow out.
- *Pressure balancing.* Total pressure loss in each path must equal fan total pressure; or, in effect, at any junction, total pressure loss for all paths is the same.
- *Nominal duct size.* Ducts are constructed in discrete, nominal sizes. Each diameter of a round duct or height and width of a rectangular duct is rounded to the nearest increment, usually 25 or 50 mm, or according to ISO standards where applicable. If a lower nominal size is selected, initial cost decreases, but pressure loss increases and may exceed the fan pressure. If a higher nominal size is selected, the opposite is true: initial cost increases, but section pressure loss decreases. However, this lower pressure at one section may allow smaller ducts to be selected for sections that follow. Therefore, optimization must consider size rounding.
- *Air velocity restriction.* Maximum allowable velocity is an acoustic limitation (ductwork regenerated noise).
- *Construction restriction.* Architectural limits may restrict duct sizes. If air velocity or construction constraints are violated during an iteration, a duct size must be calculated. Pressure loss calculated for this preselected duct size is considered a fixed loss.

T-method simulation, developed by Tsal et al. (1990), determines the flow in each duct section of an existing system with a known operating fan performance curve. The simulation version of

the T-method converges very efficiently. Usually three iterations are sufficient to obtain a solution with a high degree of accuracy.

Many HVAC problems require duct system simulation. In addition to the following concerns that can be clarified by simulation, the T-method is an excellent design tool for simulating flow distribution within a system with various modes of operation.

- Flow distribution in a VAV system caused by terminal box flow diversity
- Airflow redistribution caused by HVAC system additions and/or modifications
- System airflow analysis for partially occupied buildings
- Necessity to replace fans and/or motors when retrofitting an air distribution system
- Multiple-fan system operating condition when one or more fans shut down
- Pressure differences between adjacent confined spaces in a nuclear facility when a design basis accident (DBA) occurs (Farajian et al. 1992)
- Smoke management system performance during a fire, when some fire/smoke dampers close and others remain open

**Availability.** Software for T-method optimization is under development to identify optimum duct design, considering energy, operation, and construction costs.

## BALANCING DAMPERS

### Constant-Volume (CV) Systems

Dampers should be provided throughout CV systems. Systems designed using the inherently non-self-balancing equal-friction method should have balancing dampers at each branch throughout the system, unless sections are resized to balance pressure losses at each junction. Self-balancing design methods, such as static regain and the T-method, produce fairly well-balanced systems and theoretically do not need balancing dampers; however, because of the accuracy limitations of fitting data (loss coefficients), use of fittings for which no data are available, and effects of close-coupled fittings, dampers should be provided.

### Variable-Air-Volume (VAV) Systems

VAV systems in balance at design loads will not be in balance at part-load conditions, because there is no single critical path in VAV systems. The critical path is dynamic and continually changing as loads on a building change. In general, balancing dampers are not needed for systems designed by the static regain or T-method, because these design methods are self-balancing at design loads and VAV boxes compensate for inaccuracy in fitting data or data inaccuracy caused by close-coupled fittings (at design loads) and system pressure variation (at part loads). Balancing dampers, however, are required for systems designed using the non-self-balancing equal-friction method. For systems designed using any method, dampers should not be installed in the inlets to VAV boxes.

For any design method, VAV terminal units may have upstream static pressures higher than for which the box is rated, thus possibly introducing noise into occupied spaces. In these cases, control algorithms can poll the VAV boxes and drive the duct static pressure to the minimum set point required to keep at least one unit at starvation (open) at any given time. Upstream static pressure should always be kept at a minimum that is easy for the VAV box to control. Because there may be large differences in static pressure at riser takeoffs serving many floors from a single air handler, manual dampers should be provided at each floor takeoff so that testing, adjusting, and balancing (TAB) contractors can field-adjust them after construction. Alternatively, these takeoff dampers could also be dynamically controlled to adjust the downstream static pressure applied to the VAV boxes, while simultaneously driving the air handler to the lowest possible static pressure set point.

Silencers downstream of VAV terminal units should not be necessary if the VAV box damper is operating at nearly open conditions. Their use in this location should be based on careful acoustical analysis, because silencers add total pressure to the system and therefore create more system noise by causing air handlers to operate at higher speeds for a given airflow.

### HVAC DUCT DESIGN PROCEDURES

The general procedure for HVAC system duct design is as follows:

1. Study the building plans, and arrange supply and return outlets to provide proper distribution of air in each space. Adjust calculated air quantities for duct heat gains or losses and duct leakage. Also, adjust supply, return, and/or exhaust air quantities to meet space pressurization requirements.
2. Select outlet sizes from manufacturers' data (see Chapter 20).
3. Sketch the duct system, connecting supply outlets and return intakes with the air-handling units/air conditioners. Use rigid round ducts, minimize the number of fittings, and avoid close-coupled fittings because little is known about the resulting loss

coefficients. If space is restricted and a properly designed round duct is too large, the next best option to minimize leakage and pressure losses is to use flat oval ductwork. Multiple runs of round duct should also be considered. Limit flexible duct to the final 1.5 m of connections to diffusers and terminal boxes, with no more than 5% compression. They should be installed without kinks or crimps, and no more offset between the diffuser and rigid duct than 1/8th the diffuser neck diameter to prevent a significant increase in noise level (see Figure 11 in Chapter 47 of the 2007 ASHRAE Handbook—HVAC Applications).

4. Divide the system into sections and number each section. A duct system should be divided at all points where flow, size, or shape changes. Assign fittings to the section toward the supply and return (or exhaust) terminals. The following examples are for the fittings identified for Example 6 (Figure 15), and system section numbers assigned (Figure 16). For converging flow fitting 3, assign the straight-through flow to section 1 (toward terminal 1), and the branch to section 2 (toward terminal 4). For diverging flow fitting 24, assign the straight-through flow to section 13 (toward terminals 26 and 29) and the branch to section 10





Fig. 15 Schematic for Example 6



**Fig. 16** System Schematic with Section Numbers for Example 6

(toward terminals 43 and 44). For transition fitting 11, assign the fitting to upstream section 4 [toward terminal 9 (intake louver)]. For fitting 20, assign the unequal area elbow to downstream section 9 (toward diffusers 43 and 44). The fan outlet diffuser, fitting 42, is assigned to section 19 (again, toward the supply duct terminals).

5. Size ducts by the selected design method. Calculate system total pressure loss; then select the fan (refer to Chapter 20 of the 2008 *ASHRAE Handbook—HVAC Systems and Equipment*).
6. Lay out the system in detail. If duct routing and fittings vary significantly from the original design, recalculate pressure losses. Reselect the fan if necessary.
7. Resize duct sections to approximately balance pressures at each junction.
8. Analyze the design for objectionable noise levels, and specify lined duct, double-wall duct, and sound attenuators as necessary. Refer to the section on System and Duct Noise.

**Example 6.** For the system illustrated by Figures 15 and 16, size the duct-work by the equal-friction method, and pressure-balance the system by changing duct sizes (use 10 mm increments for rectangular, and available spiral duct forming heads: 80, 100, 125, 140, 150, 160, 180, 200, 224, 250, 280, 300, 315, 355, 400, 450, 500, 560, 600, 630, 710, 800, 900, 1000, 1120, 1250, 1300, 1400, 1500, 1600, 1800, 2000, 2100, 2200, 2300, 2400, and 2500 mm). Determine system resistance and total pressure unbalance at junctions. Airflow quantities are actual values adjusted for heat gains or losses, and ductwork is sealed (assume no leakage), galvanized steel ducts with transverse joints on 1200 mm centers ( $\epsilon = 0.09$  mm). Air is at standard conditions (1.024 kg/m<sup>3</sup> density).


Because Figure 15 is intended to illustrate calculation procedures, its duct layout is not typical of any real duct system. The layout includes fittings from the local loss coefficient tables, with emphasis on converging and diverging tees and various types of entries and discharges. The supply system is constructed of rectangular ductwork; the return system, round ductwork.

**Solution:** See Figure 16 for section numbers assigned to the system. Duct sections are sized within the suggested range of friction rate shown on the friction chart (see Figure 9). Tables 9 and 10 give total pressure loss calculations and the supporting summary of loss coefficients by sections. Straight-duct friction factor and pressure loss were calculated by Equations (18) and (19). Fitting loss coefficients are from the 2009 *ASHRAE Duct Fitting Database*. Loss coefficients were calculated automatically by the database program (not by manual interpolation). Pressure loss values in Table 9 for diffusers (fittings 43 and 44), louver (fitting 9), and air-measuring station (fitting 46) are manufacturers' data.

Pressure unbalance at junctions is shown in Figure 17, the total pressure grade line for the system. System resistance  $P_t$  is 704 Pa. Noise levels and the need for sound attenuation were not evaluated. To calculate the fan static pressure, use Equation (17):

$$P_s = 704 - 119 = 585 \text{ Pa}$$

where 119 Pa is the fan outlet velocity pressure.



**Fig. 17** Total Pressure Grade Line for Example 6

## INDUSTRIAL EXHAUST SYSTEM DUCT DESIGN

Chapter 30 of the 2007 *ASHRAE Handbook—HVAC Applications* discusses design criteria, including hood design, for industrial exhaust systems. Exhaust systems conveying vapors, gases, and smoke can be designed by the equal-friction or T-method. Systems conveying particulates are designed by the constant velocity method at duct velocities adequate to convey particles to the system air cleaner. For contaminant transport velocities, see Table 2 in Chapter 30 of the 2007 *ASHRAE Handbook—HVAC Applications*.

Two pressure-balancing methods can be considered when designing industrial exhaust systems. One method uses balancing devices (e.g., dampers, blast gates) to obtain design airflow through each hood. The other approach balances systems by adding resistance to ductwork sections (i.e., changing duct size, selecting different fittings, and increasing airflow). This self-balancing method is preferred, especially for systems conveying abrasive materials. Where potentially explosive or radioactive materials are conveyed, the prebalanced system is mandatory because contaminants could accumulate at the balancing devices. To balance systems by increasing airflow, use Equation (44) which assumes that all ductwork has the same diameter and that fitting loss coefficients, including main and branch tee coefficients, are constant.

$$Q_c = Q_d(P_h/P_l)^{0.5} \quad (44)$$

where

$Q_c$  = airflow rate required to increase  $P_l$  to  $P_h$ , L/s

$Q_d$  = total airflow rate through low-resistance duct run, L/s

$P_h$  = absolute value of pressure loss in high-resistance ductwork section(s), Pa

$P_l$  = absolute value of pressure loss in low-resistance ductwork section(s), Pa

For systems conveying particulates, use elbows with a large centerline radius-to-diameter ratio ( $r/D$ ), greater than 1.5 whenever possible. If  $r/D$  is 1.5 or less, abrasion in dust-handling systems can




Fig. 18 Metalworking Exhaust System for Example 7

reduce the life of elbows. Elbows are often made of seven or more gores, especially in large diameters. For converging flow fittings, a 30° entry angle is recommended to minimize energy losses and abrasion in dust-handling systems. For the entry loss coefficients of hoods and equipment for specific operations, see Chapter 30 of the 2007 *ASHRAE Handbook—HVAC Applications* and ACGIH (2007).

**Example 7.** For the metalworking exhaust system in Figures 18 and 19, size the ductwork and calculate fan static pressure requirement for an industrial exhaust designed to convey granular materials. Pressure-balance the system by changing duct sizes and adjusting airflow rates. Minimum particulate transport velocity for the chipping and grinding table ducts (sections 1 and 5, Figure 19) is 20 m/s. For ducts associated with the grinder wheels (sections 2, 3, 4, and 5), minimum duct velocity is 23 m/s. Ductwork is galvanized steel, with absolute roughness of 0.09 mm. Use sizes for which spiral duct is available (80, 100, 125, 140, 150, 160, 180, 200, 224, 250, 280, 300, 315, 355, 400, 450, 500, 560, 600, 630, 710, 800, 900, 1000, 1120, 1250, 1300, 1400, 1500, 1600, 1800, 2000, 2100, 2200, 2300, 2400, and 2500 mm).

The building is one story, and the design wind velocity is 9 m/s. For the stack, use design J shown in Figure 2 in Chapter 44 of the 2007 *ASHRAE Handbook—HVAC Applications* for complete rain protection; stack height, determined by calculations from Chapter 44, is 4.9 m above the roof. This height is based on minimized stack downwash; therefore, the stack discharge velocity must exceed 1.5 times the design wind velocity.

**Solution:** The following table summarizes initial duct sizes and transport velocities for contaminated ducts upstream of the collector. The 22.8 m/s velocity in sections 2 and 3 is acceptable because the transport velocity is not significantly lower than 23 m/s. For the next available




Fig. 19 System Schematic with Section Numbers for Example 7

duct size (160 mm diameter), duct velocity is 28.8 m/s, significantly higher than 23 m/s.

Duct Section	Design Airflow, L/s	Transport Velocity, m/s	Diameter, mm	Duct Velocity, m/s
1	850	20	224	21.6
2, 3	290 each	23	125	23.6
4	580	23	180	22.8
5	1430	23	180	23.2

Design calculations up through the junction after sections 1 and 4 are summarized as follows:

Design No.	$D_1$ , mm	$\Delta p_1$ , Pa	$\Delta p_{2+4}$ , Pa	Imbalance, $\Delta p_1 - \Delta p_{2+4}$
1	224	411	794	-383
2	200	762	850	-88
3	180	1320	712	+609

$Q_1 = 850 \text{ L/s}$        $Q_3 = 290 \text{ L/s}; D_3 = 125 \text{ mm dia.}$   
 $Q_2 = 290 \text{ L/s}; D_2 = 125 \text{ mm dia.}$        $Q_4 = 850 \text{ L/s}; D_4 = 180 \text{ mm dia.}$

For (initial) design 1, the imbalance between section 1 and section 2 (or 3) is 383 Pa, with section 1 requiring additional resistance. Decreasing section 1 duct diameter by manufactured spiral duct sizes results in the least imbalance, 88 Pa, when the duct diameter is 200 mm (design 2). Because section 1 requires additional resistance, estimate the new airflow rate using Equation (44):

$$Q_{c,1} = 850(850/762)^{0.5} = 900 \text{ L/s}$$

At 900 L/s flow in section 1, 130 Pa imbalance remains at the junction of sections 1 and 4. By trial-and-error solution, balance is attained when the flow in section 1 is 860 L/s. The duct between the collector and fan inlet is 355 mm round to match the fan inlet (340 mm diameter). To minimize downwash, the stack discharge velocity must exceed 13.5 m/s, 1.5 times the design wind velocity (9 m/s) as stated in the problem definition. Therefore, the stack is 355 mm round, and the stack discharge velocity is 14.5 m/s.

**Table 11** summarizes the system losses by sections. The straight duct friction factor and pressure loss were calculated by Equations (18) and (19). **Table 12** lists fitting loss coefficients and input parameters necessary to determine the loss coefficients. The fitting loss coefficients are from the 2009 *ASHRAE Duct Fitting Database*. The fitting loss coefficient tables are included in the section on Fitting Loss Coefficients for illustration but cannot be obtained exactly by manual interpolation because the coefficients were calculated by the duct fitting database algorithms (more significant figures). **Figure 20** shows a pressure grade line of the system. Fan total pressure, calculated by Equation (15), is 1992 Pa. To calculate the fan static pressure, use Equation (17):

$$P_s = 1992 - 192 = 1800 \text{ Pa}$$

where 192 Pa is the fan outlet velocity pressure. The fan airflow rate is 1440 L/s, and its outlet area is 0.081 m<sup>2</sup> (260 by 310 mm). Therefore, the fan outlet velocity is 17.9 m/s.


Hood suction for the chipping and grinding table hood is 560 Pa, calculated by Equation (5) from Chapter 30 of the 2007 *ASHRAE Handbook—HVAC Applications* [ $P_{s,h} = (1 + 0.25)(451) = 560 \text{ Pa}$ , where 0.25 is hood entry loss coefficient  $C_o$ , and 451 is duct velocity pressure  $P_v$  a few diameters downstream from the hood]. Similarly, hood suction for each grinder wheel is 170 Pa:

$$P_{2,3} = (1 + 0.4)(336) = 470 \text{ Pa}$$

where 0.4 is the hood entry loss coefficient, and 336 Pa is the duct velocity pressure.

## REFERENCES

- Abushakra, B., I.S. Walker, and M.H. Sherman. 2002. A study of pressure losses in residential air distribution systems. *Proceedings of the ACEEE Summer Study 2002*, American Council for an Energy Efficient Economy, Washington, D.C. LBNL Report 49700. Lawrence Berkeley National Laboratory, CA.
- Abushakra, B., I.S. Walker, and M.H. Sherman. 2004. Compression effects on pressure loss in flexible HVAC ducts. *International Journal of HVAC&R Research* (now *HVAC&R Research*) 10(3):275-289.
- ACGIH. 2007. *Industrial ventilation: A manual of recommended practice for design*, 26th ed. American Conference of Governmental Industrial Hygienists, Lansing, MI.
- ADC. 2003. *Flexible duct performance and installation standards*, 4th ed. Air Diffusion Council, Schaumburg, IL.
- AISI/SMACNA. 1972. *Measurement and analysis of leakage rates from seams and joints of air handling systems*. American Iron and Steel Institute, Washington, D.C., and Sheet Metal and Air Conditioning Contractors' National Association, Chantilly, VA.
- AMCA. 2007. Laboratory method of testing louvers for rating. *ANSI/AMCA Standard 500-L-07*. Air Movement and Control Association International, Arlington Heights, IL.
- AMCA. 2007a. Fans and systems. *AMCA Publication 201-02* (R2007). Air Movement and Control Association International, Arlington Heights, IL.
- AMCA. 2007b. Field performance measurement of fan systems. *AMCA Publication 203-90* (R2007). Air Movement and Control Association International, Arlington Heights, IL.
- ASHRAE. 2007. Laboratory methods for testing fans for certified aerodynamic performance rating. *ANSI/ASHRAE Standard 51-07*. Also *ANSI/AMCA Standard 210-07*.
- ASHRAE. 2007. Energy standard for buildings except low-rise residential buildings. *ANSI/ASHRAE/IESNA Standard 90.1-2007*.
- ASHRAE. 2007. Energy-efficient design of low-rise residential buildings. *ANSI/ASHRAE Standard 90.2-2007*.
- ASHRAE. 2006. Energy conversation in existing buildings. *ANSI/ASHRAE/IESNA Standard 100-2006*.
- ASHRAE. 2009. *ASHRAE duct fitting database*.
- ASHRAE/SMACNA/TIMA. 1985. Investigation of duct leakage (RP-308). ASHRAE Research Project, *Final Report*.
- Behls, H.F. 1971. Computerized calculation of duct friction. *Building Science Series* 39, p. 363. National Institute of Standards and Technology, Gaithersburg, MD.
- Bellman, R.E. 1957. *Dynamic programming*. Princeton University, New York.
- Brown, R.B. 1973. Experimental determinations of fan system effect factors. In *Fans and systems*, ASHRAE Symposium Bulletin LO-73-1, Louisville, KY (June).
- Clarke, M.S., J.T. Barnhart, F.J. Bubsey, and E. Neitzel. 1978. The effects of system connections on fan performance. *ASHRAE Transactions* 84(2):227-263.
- Colebrook, C.F. 1938-1939. Turbulent flow in pipes, with particular reference to the transition region between the smooth and rough pipe laws. *Journal of the Institution of Civil Engineers* 11:133.
- Culp, C. and D. Cantrill. 2009. Static pressure losses in 12", 14", and 16" nonmetallic flexible ducts with compression and sag (RP-1333). *ASHRAE Transactions* 115(1).



**Fig. 20 Total Pressure Grade Line for Example 7**

Table 9 Total Pressure Loss Calculations by Sections for Example 6

Duct Section <sup>a</sup>	Fitting No. <sup>b</sup>	Duct Element	Airflow, Duct Size (Equivalent Round)	Velocity, m/s	Velocity Pressure, Pa	Duct Length, <sup>c</sup> m	Summary of Fitting Loss Coefficients <sup>d</sup>	Duct Pressure Loss, <sup>e</sup> Pa/m	Total Pressure Loss, Pa	Section Pressure Loss, Pa
1	—	Duct	700 315 mm $\phi$	9.0	—	4.6	—	2.7	13	
—	—	Fittings	700	9.0	49	—	0.80	—	39	52
2	—	Duct	250 224 mm $\phi$	6.3	—	18.3	—	2.2	40	
—	—	Fittings	250	6.3	24	—	-0.36	—	-9	31
3	—	Duct	950 315 mm $\phi$	12.2	—	6.1	—	4.9	30	
—	—	Fittings	950	12.2	89	—	1.09	—	97	127
4	—	Duct	950 600×600 mm (656)	2.6	—	1.5	—	0.1	0	
—	—	Fittings	950	2.6	4	—	0.68	—	3	
9	—	Louver	950 600×600 mm	—	—	—	—	—	25 <sup>f</sup>	28
5	—	Duct	950 400 mm $\phi$	7.6	—	18.3	—	1.5	27	
—	—	Fittings	950	7.6	34	—	2.47	—	84	111
6	—	Duct	1900 450 mm $\phi$	11.9	—	9.1	—	3.0	27	
—	—	Fittings	1900	11.9	86	—	0.94	—	81	108
7	—	Duct	275 250×250 mm (273)	4.4	—	4.3	—	1.0	4	
—	—	Fittings	275	4.4	12	—	0.26	—	3	
43	—	Diffuser	275 250×250 mm	—	—	—	—	—	25 <sup>f</sup>	32
8	—	Duct	275 250×250 mm (273)	4.4	—	1.2	—	1.0	1	
—	—	Fittings	275	4.4	12	—	0.91	—	11	
44	—	Diffuser	275 250×250 mm	—	—	—	—	—	25 <sup>f</sup>	37
9	—	Duct	550 500×250 mm (381)	4.4	—	7.6	—	0.7	5	
—	—	Fittings	550	4.4	12	—	1.67	—	20	25
10	—	Duct	550 400×250 mm (343)	5.5	—	13.7	—	1.1	15	
—	—	Fittings	550	5.5	18	—	2.69	—	48	63
11	—	Duct	475 250×250 mm (273)	7.6	—	3.0	—	2.7	8	
—	—	Fittings	475	7.6	35	—	2.41	—	84	92
12	—	Duct	475 250×250 mm (273)	7.6	—	6.7	—	2.7	18	
—	—	Fittings	475	7.6	35	—	2.30	—	80	98
13	—	Duct	950 420×250 mm (351)	9.0	—	10.7	—	2.8	30	
—	—	Fittings	950	9.0	49	—	0.10	—	5	35
14	—	Duct	1500 660×250 mm (414)	9.1	—	4.6	—	2.4	11	
—	—	Fittings	1500	9.1	50	—	0.13	—	7	18
15	—	Duct	200 200×150 mm (189)	6.7	—	12.2	—	3.3	40	
—	—	Fittings	200	6.7	27	—	0.62	—	17	57
16	—	Duct	200 200×150 mm (189)	6.7	—	6.1	—	3.3	20	
—	—	Fittings	200	6.7	27	—	1.87	—	50	70
17	—	Duct	400 230×150 mm (202)	11.6	—	4.2	—	8.7	36	
—	—	Fittings	400	11.6	81	—	0.54	—	44	80
18	—	Duct	1900 800×250 mm (470)	9.5	—	7.0	—	2.4	17	
—	—	Fittings	1900	9.5	54	—	2.93	—	158	175
19	—	Duct	1900 800×450 mm (649)	5.3	—	3.7	—	0.5	2	
—	—	Fittings	1900	5.3	17	—	4.37	—	74	
46	Air-meas. station	1900	—	—	—	—	—	—	15 <sup>f</sup>	91

<sup>a</sup>See Figure 16.<sup>c</sup>Duct lengths are to fitting centerlines.<sup>b</sup>See Figure 15.<sup>d</sup>See Table 10.<sup>e</sup>Duct pressure based on 0.09 mm absolute roughness factor.<sup>f</sup>Pressure drop based on manufacturers' data.

Table 10 Loss Coefficient Summary by Sections for Example 6

Duct Section	Fitting Number	Type of Fitting	ASHRAE Fitting No.*	Parameters	Loss Coefficient
1	1	Entry	ED1-3		0.03
	2	Damper	CD9-1	$\theta = 0^\circ$	0.60
	3	Wye (30°), main	ED5-1	$A_s/A_c = 1.0, A_b/A_c = 0.506, Q_s/Q_c = 0.74$	0.17 ( $C_s$ )
	Summation of Section 1 loss coefficients.....				0.80
2	4	Entry	ED1-1	$L = 0, t = 1.61 \text{ mm (16 gage)}$	0.50
	4	Screen	CD6-1	$n = 0.60, A_1/A_o = 1$	0.97
	5	Elbow	CD3-7	$45^\circ, r/D = 1.5, \text{ pleated}$	0.19
	6	Damper	CD9-1	$\theta = 0^\circ$	0.60
	3	Wye (30°), branch	ED5-1	$A_s/A_c = 1.0, A_b/A_c = 0.506, Q_b/Q_c = 0.26$	-2.62 ( $C_b$ )
	Summation of Section 2 loss coefficients.....				0.03
3	7	Damper	CD9-1	$\theta = 0^\circ$	0.60
	8	Wye (45°), main	ED5-2	$A_s/A_c = 0.498, A_b/A_c = 0.490, Q_s/Q_c = 0.5$	0.49 ( $C_s$ )
	Summation of Section 3 loss coefficients.....				1.09

\*2009 ASHRAE Duct Fitting Database data for fittings reprinted in section on Fitting Loss Coefficients.

Table 10 Loss Coefficient Summary by Sections for Example 6 (Concluded)

Duct Section	Fitting Number	Type of Fitting	ASHRAE Fitting No.*	Parameters	Loss Coefficient
4	10	Damper	CR9-4	$\theta = 0^\circ$	0.18
	11	Transition	ER4-3	$L = 750 \text{ mm}, A_o/A_1 = 2.86, \theta = 15^\circ$	0.50
		Summation of Section 4 loss coefficients.....			0.90
5	12	Elbow	CD3-17	$45^\circ, \text{ mitered}$	0.71
	13	Damper	CD9-1	$\theta = 0^\circ$	0.60
	8	Wye ( $45^\circ$ ), branch	ED5-2	$Q_b/Q_c = 0.5, A_s/A_c = 0.490, A_b/A_c = 0.790$	1.16 ( $C_b$ )
		Summation of Section 5 loss coefficients.....			2.47
6	14	Fire damper	CD9-3	Curtain type, Type C	0.12
	15	Elbow	CD3-9	$90^\circ, 5 \text{ gore}, r/D = 1.5$	0.15
	—	Fan and system interaction	ED7-2	$90^\circ \text{ elbow}, 4 \text{ gore}, r/D = 1.5, L = 900 \text{ mm}$	0.67
		Summation of Section 6 loss coefficients.....			0.87
7	16	Elbow	CR3-3	$90^\circ, r/W = 0.70, 1 \text{ splitter vane}$	0.14
	17	Damper	CR9-1	$\theta = 0^\circ, H/W = 1.0$	0.08
	19	Tee, main	SR5-13	$Q_s/Q_c = 0.5, A_s/A_c = 0.50$	0.04 ( $C_s$ )
		Summation of Section 7 loss coefficients.....			0.26
8	19	Tee, branch	SR5-13	$Q_b/Q_c = 0.5, A_b/A_c = 0.50$	0.73 ( $C_b$ )
	18	Damper	CR9-3	$\theta = 0^\circ$	0.18
		Summation of Section 8 loss coefficients.....			0.91
9	20	Elbow	SR3-1	$90^\circ, \text{ mitered}, H/W_1 = 0.625, W_o/W_1 = 1.25$	1.67
		Summation of Section 9 loss coefficients.....			1.67
10	21	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.625$	0.08
	22	Elbow	CR3-9	$90^\circ, \text{ single-thickness vanes}, 40 \text{ mm vane spacing}$	0.11
	23	Elbow	CR3-6	$\theta = 90^\circ, \text{ mitered}, H/W = 0.625$	1.25
	24	Tee, branch	SR5-1	$r/W_b = 1.0, Q_b/Q_c = 0.367, A_s/A_c = 0.636, A_b/A_c = 0.606$	1.25 ( $C_b$ )
		Summation of Section 10 loss coefficients.....			2.69
11	25	Damper	CR9-1	$\theta = 0^\circ, H/W = 1.0$	0.08
	26	Exit	SR2-1	$H/W = 1.0, \text{ Re} = 125\,800$	1.00
	27	Bullhead tee w/o vanes	SR5-15	$Q_{b1}/Q_c = 0.5, A_{b1}/A_c = 0.595$	1.33 ( $C_b$ )
		Summation of Section 11 loss coefficients.....			2.41
12	28	Damper	CR9-1	$\theta = 0^\circ, H/W = 1.0$	0.08
	29	Exit	SR2-5	$\theta = 30^\circ, A_1/A_o = 3.86, \text{ Re} = 126\,000, L = 450 \text{ mm}$	0.89
	27	Bullhead tee w/o vanes	SR5-15	$Q_{b2}/Q_c = 0.5, A_{b2}/A_c = 0.595$	1.33 ( $C_b$ )
		Summation of Section 12 loss coefficients.....			2.30
13	30	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.595$	0.08
	24	Tee, main	SR5-1	$r/W_b = 1.0, Q_s/Q_c = 0.63, A_s/A_c = 0.633, A_b/A_c = 0.606$	0.02 ( $C_s$ )
		Summation of Section 13 loss coefficients.....			0.10
14	31	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.38$	0.08
	32	Tee, main	SR5-13	$Q_s/Q_c = 0.79, A_s/A_c = 0.825$	0.05 ( $C_s$ )
		Summation of Section 14 loss coefficients.....			0.13
15	48	Elbow	CR3-1	$\theta = 90^\circ, r/W = 1.5, H/W = 0.75$	0.19
	33	Exit	SR2-6	$L = 500 \text{ mm}, D_h = 171$	0.26
	34	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.75$	0.08
	35	Tee, main	SR5-1	$r/W_b = 1.0, Q_s/Q_c = 0.5, A_s/A_c = 0.870, A_b/A_c = 0.870$	0.09 ( $C_s$ )
		Summation of Section 15 loss coefficients.....			0.62
16	36	Exit	SR2-3	$\theta = 20^\circ, L = 500 \text{ mm}, A_1/A_o = 2.0, \text{ Re} = 76\,000$	0.63
	36	Screen	CR6-1	$n = 0.8, A_1/A_o = 2.06$	0.08
	37	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.75$	0.08
	35	Tee, branch	SR5-1	$r/W_b = 1.0, Q_b/Q_c = 0.5, A_s/A_c = 0.870, A_b/A_c = 0.870$	1.08 ( $C_b$ )
		Summation of Section 16 loss coefficients.....			1.87
17	38	Damper	CR9-1	$\theta = 0^\circ, H/W = 0.65$	0.08
	32	Tee, branch	SR5-13	$Q_b/Q_c = 0.21, A_b/A_c = 0.187$	0.46 ( $C_b$ )
		Summation of Section 17 loss coefficients.....			0.54
18	39	Obstruction, pipe	CR6-4	$\text{Re} = 16\,000, y = 0, d = 25 \text{ mm}, S_m/A_o = 0.10, y/H = 0$	0.17
	40	Transition	SR4-1	$\theta = 25^\circ, A_o/A_1 = 0.556, L = 450 \text{ mm}$	0.04
	41	Elbows, Z-shaped	CR3-17	$L = 1000 \text{ mm}, L/W = 4.2\,4.0, H/W = 3.2, \text{ Re} = 240\,000$	2.53
	45	Fire damper	CR9-6	Curtain type, Type B	0.19
		Summation of Section 18 loss coefficients.....			2.93
19	42	Diffuser, fan	SR7-17	$\theta_1 = 28^\circ, L = 1000 \text{ mm}, A_o/A_1 = 2.67, C_1 = 0.59$	4.19 ( $C_o$ )
	47	Damper	CR9-4	$\theta = 0^\circ$	0.18
		Summation of Section 19 loss coefficients.....			4.37

\*2009 ASHRAE Duct Fitting Database data for fittings reprinted in section on Fitting Loss Coefficients

Table 11 Total Pressure Loss Calculations by Sections for Example 7

Duct Section <sup>a</sup>	Duct Element	Airflow, L/s	Duct Size	Velocity, m/s	Velocity Pressure, Pa	Duct Length, <sup>b</sup> m	Summary of Fitting Loss Coefficients <sup>c</sup>	Duct Pressure Loss, Pa/m <sup>d</sup>	Total Pressure Loss, Pa	Section Pressure Loss, Pa
1	Duct	860	200 mm $\phi$	27.4	—	7.32	—	40	293	
	Fittings	860	—	27.4	451	—	1.09	—	492	785
2, 3	Duct	290	125 mm $\phi$	23.6	—	2.7	—	54	146	
	Fittings	290	—	23.6	336	—	1.06	—	356	502
4	Duct	580	180 mm $\phi$	22.8	—	3.84	—	32	123	
	Fittings	580	—	22.8	313	—	0.51	—	160	283
5	Duct	1440	280 mm $\phi$	23.4	—	2.7	—	18.5	50	
	Fittings	1440	—	23.4	329	—	0.23	—	76	126
—	Collector, <sup>e</sup> fabric	1440	—	—	—	—	—	—	750	750
6	Duct	1440	355 mm $\phi$	14.5	—	3.0	—	6	18	
	Fittings	1440	—	14.5	127	—	0.03	—	4	22
7	Duct	1440	355 mm $\phi$	14.5	—	14.0	—	6	84	
	Fittings	1440	—	14.5	127	—	1.77	—	225	309

<sup>a</sup>See Figure 15.<sup>b</sup>Duct lengths are to fitting center-lines.<sup>c</sup>See Table 12.<sup>d</sup>Duct pressure based on a 0.09 mm absolute roughness factor.<sup>e</sup>Collector manufacturers set fabric bag cleaning mechanism to actuate at a pressure difference of 750 Pa between inlet and outlet plenums. Pressure difference across clean media is approximately 400 Pa.

Table 12 Loss Coefficient Summary by Sections for Example 7

Duct Section	Fitting Number	Type of Fitting	ASHRAE Fitting No. <sup>a</sup>	Parameters	Loss Coefficient
1	1	Hood <sup>b</sup>	—	Hood face area: 0.9 by 1.2 m	0.25
	2	Elbow	CD3-10	90°, 7 gore, $r/D = 2.5$	0.11
	4	Capped wye (45°), with 45° elbow	ED5-6	$A_b/A_c = 1$	0.61 ( $C_b$ )
	5	Wye (30°), main	ED5-1	$Q_s/Q_c = 0.60, A_s/A_c = 0.510, A_b/A_c = 0.413$	0.12 ( $C_s$ )
	Summation of Section 1 loss coefficients .....				1.09
2,3	6	Hood <sup>c</sup>	—	Type hood: For double wheels, dia. = 560 mm each, wheel width = 100 mm each; type takeoff: tapered	0.40
	7	Elbow	CD3-12	90°, 3 gore, $r/D = 1.5$	0.34
	8	Symmetrical wye (60°)	ED5-9	$Q_b/Q_c = 0.5, A_{b1}/A_c = 0.482, A_{b2}/A_c = 0.482$	0.32 ( $C_b$ )
	Summation of Sections 2 and 3 loss coefficients .....				1.06
4	9	Elbow	CD3-10	90°, 7 gore, $r/D = 2.5$	0.11
	10	Elbow	CD3-13	60°, 3 gore, $r/D = 1.5$	0.19
	5	Wye (30°), branch	ED5-1	$Q_b/Q_c = 0.40, A_s/A_c = 0.510, A_b/A_c = 0.413$	0.21 ( $C_b$ )
	Summation of Section 4 loss coefficients .....				0.51
5	11	Exit, conical diffuser to collector	ED2-1	$L = 600 \text{ mm}, L/D_o = 2.14, A_1/A_o \approx 21$	0.23
	Summation of Section 5 loss coefficients .....				0.23
6	12	Entry, bellmouth from collector	ER2-1	$r/D_1 = 0.21, r = 75 \text{ mm}, C_o = 4.69$	0.03 ( $C_1$ )
	Summation of Section 6 loss coefficients .....				0.03
7	13	Diffuser, fan outlet <sup>d</sup>	SD4-2	Fan outlet size: 260 by 310 mm; $L = 460 \text{ mm}$	0.16
	14	Capped wye (45°), with 45° elbow	ED5-6	$A_b/A_c = 1$	0.61 ( $C_b$ )
	15	Stackhead	SD2-6	$D_e/D = 1$	1.0
	Summation of Section 7 loss coefficients .....				1.77

<sup>a</sup>ASHRAE Duct Fitting Database (2009) data for fittings reprinted in the section on Fitting Loss Coefficients.<sup>b</sup>From Industrial Ventilation (ACGIH 2007, Figure VS-80-19).

Farajian, T., G. Grewal, and R.J. Tsal. 1992. Post-accident air leakage analysis in a nuclear facility via T-method airflow simulation. *Proceedings of the 22nd DOE/NRC Nuclear Air Cleaning and Treatment Conference*, Denver, CO, vol. 1, pp. 374-392. (Available at [www.hss.energy.gov/CSCA/CSP/hepa/Nureg\\_22nd/session8.pdf](http://www.hss.energy.gov/CSCA/CSP/hepa/Nureg_22nd/session8.pdf).)

Farquhar, H.F. 1973. System effect values for fans. In *Fans and systems*, ASHRAE Symposium Bulletin LO-73-1, Louisville, KY (June).

Griggs, E.I. and F. Khodabakhsh-Sharifabad. 1992. Flow characteristics in rectangular ducts (RP-549). *ASHRAE Transactions* 98(1):116-127.

Griggs, E.I., W.B. Swim, and G.H. Henderson. 1987. Resistance to flow of round galvanized ducts. *ASHRAE Transactions* 93(1):3-16.

Heyt, J.W. and M.J. Diaz. 1975. Pressure drop in flat-oval spiral air duct. *ASHRAE Transactions* 81(2):221-232.

Huebscher, R.G. 1948. Friction equivalents for round, square and rectangular ducts. *ASHVE Transactions* 54:101-118.

<sup>c</sup>From Industrial Ventilation (ACGIH 2007, Figure VS-80-11).<sup>d</sup>Fan specified: Industrial exhauster for granular materials: 530 mm wheel diameter, 340 mm inlet diameter, 260 by 310 mm outlet, 6 kW motor.

Hutchinson, F.W. 1953. Friction losses in round aluminum ducts. *ASHVE Transactions* 59:127-138.

Idelchik, I.E., M.O. Steinberg, G.R. Malyavskaya, and O.G. Martynenko. 1994. *Handbook of hydraulic resistance*, 3rd ed. CRC Press/Begell House, Boca Raton.

Jones, C.D. 1979. *Friction factor and roughness of United Sheet Metal Company spiral duct*. United Sheet Metal, Division of United McGill Corp., Westerville, OH (August). Based on data in *Friction loss tests*, United Sheet Metal Company Spiral Duct, Ohio State University Engineering Experiment Station, File No. T-1011, September 1958.

Klote, J.H. and J.A. Milke. 2002. *Principles of smoke management*. ASHRAE.

Kulkarni, D., S. Khaire, and S. Idem. 2009. Pressure loss of corrugated spiral duct. *ASHRAE Transactions* 115(1).

Meyer, M.L. 1973. A new concept: The fan system effect factor. In *Fans and systems*, ASHRAE Symposium Bulletin LO-73-1, Louisville, KY (June).

- Moody, L.F. 1944. Friction factors for pipe flow. *ASME Transactions* 66:671.
- NAIMA. 2002. *Fibrous glass duct construction standards*, 5th ed. North American Insulation Manufacturers Association.
- NFPA. 2002. Installation of air-conditioning and ventilating systems. ANSI/NFPA Standard 90A. National Fire Protection Association, Quincy, MA.
- NFPA. 2008. *Fire protection handbook*. National Fire Protection Association, Quincy, MA.
- Osborne, W.C. 1966. *Fans*. Pergamon, London.
- SMACNA. 1985. *HVAC air duct leakage test manual*. Sheet Metal and Air Conditioning Contractors' National Association, Chantilly, VA.
- SMACNA. 2003. *Fibrous glass duct construction standards*, 7th ed. Sheet Metal and Air Conditioning Contractors' National Association, Chantilly, VA.
- SMACNA. 2005. *HVAC duct construction standards—Metal and flexible*, 3rd ed. ANSI. Sheet Metal and Air Conditioning Contractors' National Association, Chantilly, VA.
- Smith, G.W. 1968. *Engineering economy: Analysis of capital expenditures*. Iowa State University, Ames.
- Swim, W.B. 1978. Flow losses in rectangular ducts lined with fiberglass. *ASHRAE Transactions* 84(2):216.
- Swim, W.B. 1982. Friction factor and roughness for airflow in plastic pipe. *ASHRAE Transactions* 88(1):269.
- Swim, W.B. and E.I. Griggs. 1995. Duct leakage measurement and analysis. *ASHRAE Transactions* 101(1):274-291.
- Tsal, R.J. and M.S. Adler. 1987. Evaluation of numerical methods for duct-work and pipeline optimization. *ASHRAE Transactions* 93(1):17-34.
- Tsal, R.J., H.F. Behls, and R. Mangel. 1988. T-method duct design, Part I: Optimization theory; Part II: Calculation procedure and economic analysis. *ASHRAE Transactions* 94(2):90-111.
- Tsal, R.J., H.F. Behls, and R. Mangel. 1990. T-method duct design, Part III: Simulation. *ASHRAE Transactions* 96(2).
- UL. Published annually. *Building materials directory*. Underwriters Laboratories, Northbrook, IL.
- UL. Published annually. *Fire resistance directory*. Underwriters Laboratories, Northbrook, IL.
- UL. 2005. Factory-made air ducts and air connectors, 10th ed. ANSI/UL Standard 181. Underwriters Laboratories, Northbrook, IL.
- UL. 2005. Closure systems for use with rigid air ducts and air connectors, 3rd ed. ANSI/UL Standard 181A. Underwriters Laboratories, Northbrook, IL.
- UL. 2005. Closure systems for use with rigid air ducts and air connectors, 2nd ed. ANSI/UL Standard 181B. Underwriters Laboratories, Northbrook, IL.
- UL. 1999. Fire dampers, 6th ed. Standard UL 555. Underwriters Laboratories, Northbrook, IL.
- UL. 1999. Smoke dampers. UL Standard 555S. Underwriters Laboratories, Northbrook, IL.
- Wright, D.K., Jr. 1945. A new friction chart for round ducts. *ASHVE Transactions* 51:303-316.

## FITTING LOSS COEFFICIENTS


Fittings to support Examples 6 and 7 and some of the more common fittings are reprinted here.

For the complete fitting database see the *ASHRAE Duct Fitting Database* (ASHRAE 2009).

### ROUND FITTINGS


**CD3-1 Elbow, Die Stamped, 90 Degree,  $r/D = 1.5$**

$D$ , mm	75	100	125	150	180	200	230	250
$C_o$	0.30	0.21	0.16	0.14	0.12	0.11	0.11	0.11




**CD3-3 Elbow, Die Stamped, 45 Degree,  $r/D = 1.5$**

$D$ , mm	75	100	125	150	180	200	230	250
$C_o$	0.18	0.13	0.10	0.08	0.07	0.07	0.07	0.07




**CD3-5 Elbow, Pleated, 90 Degree,  $r/D = 1.5$**

$D$ , mm	100	150	200	250	300	350	400
$C_o$	0.57	0.43	0.34	0.28	0.26	0.25	0.25




**CD3-7 Elbow, Pleated, 45 Degree,  $r/D = 1.5$**

$D$ , mm	100	150	200	250	300	350	400
$C_o$	0.34	0.26	0.21	0.17	0.16	0.15	0.15




CD3-9 Elbow, 5 Gore, 90 Degree,  $r/D = 1.5$ 


$D, \text{ mm}$	75	150	230	300	380	450	530	600	690	750	1500
$C_o$	0.51	0.28	0.21	0.18	0.16	0.15	0.14	0.13	0.12	0.12	0.12

CD3-10 Elbow, 7 Gore, 90 Degree,  $r/D = 2.5$ 


$D, \text{ mm}$	75	150	230	300	380	450	690	1500
$C_o$	0.16	0.12	0.10	0.08	0.07	0.06	0.05	0.03

CD3-12 Elbow, 3 Gore, 90 Degree,  $r/D = 0.75$  to 2.0


$r/D$	0.75	1.00	1.50	2.00
$C_o$	0.54	0.42	0.34	0.33

CD3-13 Elbow, 3 Gore, 60 Degree,  $r/D = 1.5$ 

$D, \text{ mm}$	75	150	230	300	380	450	530	600	690	750	1500
$C_o$	0.40	0.21	0.16	0.14	0.12	0.12	0.11	0.10	0.09	0.09	0.09


CD3-14 Elbow, 3 Gore, 45 Degree,  $r/D = 1.5$ 

$D, \text{ mm}$	75	150	230	300	380	450	530	600	690	750	1500
$C_o$	0.31	0.17	0.13	0.11	0.11	0.09	0.08	0.08	0.07	0.07	0.07




**CD3-17 Elbow, Mitered, 45 Degree**

<i>D, mm</i>	75	150	230	300	380	450	530	600	690	1500
<i>C<sub>o</sub></i>	0.87	0.79	0.74	0.72	0.71	0.70	0.69	0.68	0.68	0.67

**CD6-1 Screen (Only)**

<i>A<sub>1</sub>/A<sub>o</sub></i>	<i>C<sub>o</sub></i> Values												
	0.30	0.35	0.40	0.45	0.50	0.55	0.60	0.65	0.70	0.75	0.80	0.90	1.00
0.2	155.00	102.50	75.00	55.00	41.25	31.50	24.25	18.75	14.50	11.00	8.00	3.50	0.0
0.3	68.89	45.56	33.33	24.44	18.33	14.00	10.78	8.33	6.44	4.89	3.56	1.56	0.0
0.4	38.75	25.63	18.75	13.75	10.31	7.88	6.06	4.69	3.63	2.75	2.00	0.88	0.0
0.5	24.80	16.40	12.00	8.80	6.60	5.04	3.88	3.00	2.32	1.76	1.28	0.56	0.0
0.6	17.22	11.39	8.33	6.11	4.58	3.50	2.69	2.08	1.61	1.22	0.89	0.39	0.0
0.7	12.65	8.37	6.12	4.49	3.37	2.57	1.98	1.53	1.18	0.90	0.65	0.29	0.0
0.8	9.69	6.40	4.69	3.44	2.58	1.97	1.52	1.17	0.91	0.69	0.50	0.22	0.0
0.9	7.65	5.06	3.70	2.72	2.04	1.56	1.20	0.93	0.72	0.54	0.40	0.17	0.0
1.0	6.20	4.10	3.00	2.20	1.65	1.26	0.97	0.75	0.58	0.44	0.32	0.14	0.0
1.2	4.31	2.85	2.08	1.53	1.15	0.88	0.67	0.52	0.40	0.31	0.22	0.10	0.0
1.4	3.16	2.09	1.53	1.12	0.84	0.64	0.49	0.38	0.30	0.22	0.16	0.07	0.0
1.6	2.42	1.60	1.17	0.86	0.64	0.49	0.38	0.29	0.23	0.17	0.13	0.05	0.0
1.8	1.91	1.27	0.93	0.68	0.51	0.39	0.30	0.23	0.18	0.14	0.10	0.04	0.0
2.0	1.55	1.03	0.75	0.55	0.41	0.32	0.24	0.19	0.15	0.11	0.08	0.04	0.0
2.5	0.99	0.66	0.48	0.35	0.26	0.20	0.16	0.12	0.09	0.07	0.05	0.02	0.0
3.0	0.69	0.46	0.33	0.24	0.18	0.14	0.11	0.08	0.06	0.05	0.04	0.02	0.0
4.0	0.39	0.26	0.19	0.14	0.10	0.08	0.06	0.05	0.04	0.03	0.02	0.01	0.0
6.0	0.17	0.11	0.08	0.06	0.05	0.04	0.03	0.02	0.02	0.01	0.01	0.00	0.0




*n* = free area ratio of screen

*A<sub>o</sub>* = area of duct

*A<sub>1</sub>* = cross-sectional area of duct or fitting where screen is located

**CD9-1 Damper, Butterfly**


<i>θ</i>	0	10	20	30	40	50	60	70	75	90
<i>C<sub>o</sub></i>	0.60	0.85	1.70	4.0	9.4	24	67	215	400	9999



$$\frac{D}{D_o} = 0.98$$


**CD9-3 Fire Damper, Curtain Type, Type C, Horizontal Duct**

$$C_o = 0.12$$




**ED1-1 Duct Mounted in Wall**


$t/D$	$C_o$ Values								
	$L/D$								
0.0	0.002	0.01	0.05	0.10	0.20	0.30	0.50	10.0	
0.00	0.50	0.57	0.68	0.80	0.86	0.92	0.97	1.00	1.00
0.02	0.50	0.51	0.52	0.55	0.60	0.66	0.69	0.72	0.72
0.05	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
10.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50

**ED1-3 Bellmouth, with Wall**

$r/D$	0.0	0.01	0.02	0.03	0.04	0.05	0.06	0.08	0.10	0.12	0.16	0.20	10.0
$C_o$	0.50	0.44	0.37	0.31	0.26	0.22	0.20	0.15	0.12	0.09	0.06	0.03	0.03

**ED2-1 Conical Diffuser, Round to Plenum, Exhaust/Return Systems**


$A_1/A_o$	$C_o$ Values										
	$L/D_o$										
0.5	1.0	2.0	3.0	4.0	5.0	6.0	8.0	10.0	12.0	14.0	
1.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
1.5	0.03	0.02	0.03	0.03	0.04	0.05	0.06	0.08	0.10	0.11	0.13
2.0	0.08	0.06	0.04	0.04	0.04	0.05	0.05	0.06	0.08	0.09	0.10
2.5	0.13	0.09	0.06	0.06	0.06	0.06	0.06	0.07	0.08	0.09	0.09
3.0	0.17	0.12	0.09	0.07	0.07	0.06	0.06	0.07	0.07	0.08	0.08
4.0	0.23	0.17	0.12	0.10	0.09	0.08	0.08	0.08	0.08	0.08	0.08
6.0	0.30	0.22	0.16	0.13	0.12	0.10	0.10	0.09	0.09	0.09	0.08
8.0	0.34	0.26	0.18	0.15	0.13	0.12	0.11	0.10	0.09	0.09	0.09
10.0	0.36	0.28	0.20	0.16	0.14	0.13	0.12	0.11	0.10	0.09	0.09
14.0	0.39	0.30	0.22	0.18	0.16	0.14	0.13	0.12	0.10	0.10	0.10
20.0	0.41	0.32	0.24	0.20	0.17	0.15	0.14	0.12	0.11	0.11	0.10
1000.0	0.41	0.32	0.24	0.20	0.17	0.15	0.14	0.12	0.11	0.11	0.10





$A_1/A_o$	Optimum Angle $\theta$ , degrees										
	0.5	1.0	2.0	3.0	4.0	5.0	6.0	8.0	10.0	12.0	14.0
1.0	0	0	0	0	0	0	0	0	0	0	0
1.5	17	10	6.5	4.5	3.5	2.8	2.2	1.7	1.2	1.0	0.8
2.0	21	14	8.5	6.2	5.0	4.3	3.8	3.0	2.3	2.0	1.6
2.5	25	16	10	7.4	6.0	5.4	4.8	4.0	3.5	3.0	2.5
3.0	27	17	11	8.5	7.0	6.1	5.6	4.8	4.2	3.8	3.2
4.0	29	20	13	9.8	8.0	7.2	6.6	5.8	5.2	4.8	4.4
6.0	31	21	14	11	9.4	8.2	7.4	6.2	5.6	5.2	4.7
8.0	32	22	15	12	10	8.8	8.0	6.6	5.8	5.4	5.0
14.0	33	24	16	13	11	9.6	8.7	7.3	6.3	5.6	5.4
20.0	34	24	16	13	11	9.8	9.0	7.5	6.5	6.0	5.6
1000.0	34	24	16	13	11	9.8	9.0	7.5	6.5	6.0	5.6

**ED4-1 Transition, Round to Round, Exhaust/Return Systems**

$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.063	0.0	0.18	0.18	0.20	0.29	0.38	0.60	0.84	0.88	0.88	0.88	0.88	0.88
0.10	0.0	0.20	0.18	0.20	0.27	0.38	0.59	0.76	0.80	0.83	0.84	0.83	0.83
0.167	0.0	0.18	0.17	0.18	0.25	0.33	0.48	0.66	0.77	0.74	0.73	0.73	0.72
0.25	0.0	0.20	0.17	0.16	0.21	0.30	0.46	0.61	0.68	0.64	0.63	0.62	0.62
0.50	0.0	0.15	0.13	0.11	0.13	0.19	0.32	0.33	0.33	0.32	0.31	0.30	0.30
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.00	0.0	0.30	0.26	0.21	0.19	0.19	0.19	0.23	0.27	0.51	0.73	0.90	0.95
4.00	0.0	1.60	1.14	0.75	0.70	0.70	0.70	0.90	1.09	2.78	4.29	5.63	6.53
6.00	0.0	3.89	3.02	1.73	1.58	1.58	2.12	2.66	6.62	10.01	13.03	15.12	
10.00	0.0	11.80	9.30	5.30	5.00	5.00	5.00	6.45	7.90	19.00	28.50	36.70	42.70

**ED4-2 Transition, Round to Rectangular, Exhaust/Return Systems**

$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.063	0.0	0.17	0.19	0.30	0.46	0.53	0.64	0.77	0.88	0.95	0.95	0.94	0.93
0.10	0.0	0.17	0.19	0.30	0.45	0.53	0.64	0.75	0.84	0.89	0.89	0.89	0.88
0.167	0.0	0.18	0.19	0.30	0.44	0.53	0.63	0.72	0.78	0.79	0.79	0.79	0.79
0.25	0.0	0.16	0.18	0.25	0.36	0.45	0.52	0.58	0.62	0.64	0.64	0.64	0.64
0.50	0.0	0.14	0.14	0.15	0.22	0.25	0.30	0.33	0.33	0.33	0.32	0.31	0.30
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.00	0.0	0.30	0.27	0.26	0.28	0.25	0.19	0.23	0.27	0.52	0.75	0.91	0.95
4.00	0.0	1.60	1.14	0.84	0.85	0.86	0.76	0.90	1.09	2.78	4.30	5.65	6.55
6.00	0.0	3.89	3.04	1.84	1.77	1.78	1.73	2.18	2.67	6.67	10.07	13.09	15.18
10.00	0.0	11.80	9.31	5.40	5.18	5.15	5.05	6.44	7.94	19.06	28.55	36.75	42.75

**ED5-1 Wye, 30 Degree, Converging** **$C_b$  Values**

$A_s/A_c$	$A_b/A_c$	$Q_b/Q_c$								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-13.25	-1.80	0.01	0.55	0.75	0.84	0.88	0.91	0.97
	0.2	-56.10	-10.12	-2.80	-0.63	0.19	0.53	0.69	0.75	0.78
	0.3	-127.28	-23.81	-7.31	-2.44	-0.59	0.19	0.52	0.66	0.70
	0.4	-226.84	-42.88	-13.55	-4.89	-1.61	-0.22	0.38	0.62	0.68
	0.5	-354.79	-67.34	-21.52	-7.98	-2.86	-0.69	0.24	0.61	0.70
	0.6	-511.13	-97.21	-31.22	-11.73	-4.35	-1.23	0.11	0.64	0.77
	0.7	-695.87	-132.47	-42.66	-16.13	-6.08	-1.84	0.00	0.71	0.89
	0.8	-909.01	-173.14	-55.83	-21.17	-8.05	-2.51	-0.12	0.82	1.05
	0.9	-1151.	-219.20	-70.73	-26.87	-10.27	-3.25	-0.22	0.97	1.26
	1.0	-1420.	-270.66	-87.36	-33.21	-12.72	-4.05	-0.31	1.15	1.51

## ED5-1 Wye, 30 Degree, Converging (Continued)

$A_s/A_c$	$A_b/A_c$	$C_b$ Values (Continued)									
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	$Q_b/Q_c$
0.2	0.1	-5.30	-0.24	0.54	0.77	0.85	0.88	0.90	0.93	0.98	
	0.2	-24.17	-3.78	-0.60	0.30	0.64	0.77	0.83	0.88	0.98	
	0.3	-55.88	-9.77	-2.57	-0.50	0.25	0.55	0.67	0.70	0.71	
	0.4	-99.93	-17.94	-5.13	-1.45	-0.11	0.42	0.62	0.68	0.68	
	0.5	-156.51	-28.40	-8.37	-2.62	-0.52	0.30	0.62	0.71	0.69	
	0.6	-225.62	-41.13	-12.30	-4.01	-0.99	0.20	0.66	0.78	0.75	
	0.7	-307.26	-56.14	-16.90	-5.61	-1.51	0.11	0.73	0.90	0.86	
	0.8	-401.44	-73.44	-22.18	-7.44	-2.08	0.04	0.84	1.06	1.01	
	0.9	-508.15	-93.02	-28.15	-9.49	-2.71	-0.03	0.99	1.27	1.20	
	1.0	-627.39	-114.89	-34.80	-11.77	-3.39	-0.08	1.18	1.52	1.43	
0.3	0.1	-2.77	0.26	0.71	0.83	0.88	0.90	0.91	0.93	0.99	
	0.2	-13.97	-1.77	0.08	0.59	0.77	0.84	0.88	0.92	1.06	
	0.3	-33.06	-5.33	-1.09	0.10	0.51	0.66	0.71	0.72	0.74	
	0.4	-59.43	-10.08	-2.52	-0.41	0.32	0.59	0.67	0.68	0.66	
	0.5	-93.24	-16.11	-4.30	-1.00	0.14	0.56	0.69	0.70	0.66	
	0.6	-134.51	-23.45	-6.44	-1.68	-0.03	0.57	0.76	0.77	0.70	
	0.7	-183.25	-32.08	-8.93	-2.45	-0.21	0.61	0.87	0.88	0.79	
	0.8	-239.47	-42.01	-11.77	-3.32	-0.38	0.69	1.02	1.03	0.91	
	0.9	-303.16	-53.25	-14.97	-4.27	-0.56	0.80	1.21	1.23	1.07	
	1.0	-374.32	-65.79	-18.53	-5.32	-0.73	0.94	1.45	1.47	1.27	
0.4	0.1	-1.58	0.48	0.78	0.86	0.89	0.90	0.91	0.93	0.99	
	0.2	-9.20	-0.85	0.39	0.71	0.82	0.87	0.90	0.94	1.09	
	0.3	-22.31	-3.24	-0.38	0.39	0.64	0.73	0.76	0.78	0.85	
	0.4	-40.52	-6.48	-1.37	0.02	0.48	0.64	0.67	0.66	0.65	
	0.5	-63.71	-10.50	-2.50	-0.33	0.40	0.63	0.69	0.67	0.63	
	0.6	-92.00	-15.37	-3.84	-0.71	0.33	0.67	0.75	0.71	0.65	
	0.7	-125.40	-21.08	-5.40	-1.13	0.28	0.75	0.85	0.80	0.70	
	0.8	-163.90	-27.65	-7.16	-1.59	0.25	0.86	1.00	0.93	0.80	
	0.9	-207.52	-35.07	-9.14	-2.09	0.25	1.02	1.18	1.10	0.93	
	1.0	-256.25	-43.35	-11.33	-2.63	0.26	1.21	1.42	1.31	1.09	
0.5	0.1	-0.94	0.60	0.82	0.87	0.89	0.90	0.91	0.93	0.99	
	0.2	-6.62	-0.36	0.54	0.77	0.85	0.88	0.90	0.95	1.11	
	0.3	-16.42	-2.11	-0.01	0.54	0.72	0.78	0.80	0.83	0.96	
	0.4	-30.26	-4.59	-0.79	0.22	0.54	0.64	0.66	0.64	0.64	
	0.5	-47.68	-7.55	-1.61	-0.02	0.48	0.63	0.65	0.62	0.59	
	0.6	-68.93	-11.13	-2.56	-0.28	0.45	0.67	0.69	0.65	0.58	
	0.7	-94.00	-15.31	-3.65	-0.55	0.44	0.74	0.77	0.71	0.61	
	0.8	-122.90	-20.12	-4.88	-0.83	0.46	0.85	0.90	0.81	0.68	
	0.9	-155.63	-25.54	-6.25	-1.12	0.51	1.00	1.06	0.94	0.77	
	1.0	-192.18	-31.58	-7.77	-1.43	0.59	1.19	1.26	1.12	0.90	
0.6	0.1	-0.57	0.66	0.84	0.88	0.89	0.90	0.91	0.93	0.99	
	0.2	-5.12	-0.10	0.62	0.79	0.85	0.87	0.90	0.95	1.11	
	0.3	-13.00	-1.49	0.18	0.61	0.75	0.79	0.82	0.86	1.02	
	0.4	-24.31	-3.55	-0.50	0.30	0.55	0.62	0.63	0.62	0.63	
	0.5	-38.41	-5.94	-1.16	0.09	0.48	0.59	0.60	0.57	0.55	
	0.6	-55.58	-8.80	-1.92	-0.12	0.45	0.61	0.62	0.57	0.52	
	0.7	-75.83	-12.16	-2.79	-0.33	0.44	0.66	0.67	0.60	0.52	
	0.8	-99.17	-16.00	-3.76	-0.54	0.46	0.74	0.76	0.67	0.56	
	0.9	-125.60	-20.33	-4.83	-0.76	0.51	0.86	0.88	0.77	0.62	
	1.0	-155.12	-25.14	-6.02	-0.99	0.58	1.02	1.04	0.90	0.71	
0.7	0.1	-0.35	0.70	0.84	0.88	0.89	0.90	0.90	0.92	0.99	
	0.2	-4.24	0.05	0.65	0.80	0.85	0.87	0.89	0.94	1.12	
	0.3	-11.00	-1.15	0.27	0.63	0.75	0.79	0.82	0.87	1.06	
	0.4	-20.82	-3.00	-0.38	0.31	0.52	0.59	0.60	0.59	0.61	
	0.5	-32.99	-5.09	-0.98	0.10	0.43	0.53	0.54	0.52	0.51	
	0.6	-47.78	-7.58	-1.67	-0.11	0.38	0.52	0.53	0.49	0.45	
	0.7	-65.22	-10.50	-2.44	-0.32	0.34	0.53	0.54	0.49	0.43	
	0.8	-85.32	-13.83	-3.30	-0.53	0.33	0.58	0.59	0.52	0.43	
	0.9	-108.07	-17.58	-4.26	-0.75	0.34	0.66	0.67	0.58	0.46	
	1.0	-133.48	-21.76	-5.30	-0.97	0.38	0.76	0.78	0.67	0.51	
0.8	0.1	-0.23	0.71	0.84	0.88	0.89	0.89	0.90	0.92	0.98	
	0.2	-3.75	0.11	0.65	0.79	0.84	0.86	0.88	0.94	1.12	
	0.3	-9.88	-0.99	0.29	0.63	0.74	0.78	0.81	0.87	1.09	
	0.4	-18.88	-2.75	-0.36	0.28	0.48	0.55	0.56	0.57	0.61	
	0.5	-29.98	-4.71	-0.96	0.04	0.36	0.46	0.47	0.46	0.47	
	0.6	-43.46	-7.05	-1.64	-0.20	0.26	0.41	0.43	0.41	0.39	
	0.7	-59.34	-9.77	-2.40	-0.44	0.19	0.38	0.41	0.38	0.34	
	0.8	-77.64	-12.88	-3.26	-0.69	0.13	0.38	0.42	0.37	0.31	
	0.9	-98.35	-16.38	-4.20	-0.95	0.09	0.40	0.45	0.39	0.30	
	1.0	-121.48	-20.27	-5.24	-1.23	0.06	0.45	0.51	0.43	0.31	


ED5-1 Wye, 30 Degree, Converging (*Continued*)

		<i>C<sub>b</sub></i> Values ( <i>Concluded</i> )								
		<i>Q<sub>b</sub>/Q<sub>c</sub></i>								
<i>A<sub>s</sub>/A<sub>c</sub></i>	<i>A<sub>b</sub>/A<sub>c</sub></i>	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.9	0.1	-0.18	0.72	0.84	0.87	0.88	0.89	0.90	0.92	0.98
	0.2	-3.52	0.12	0.64	0.78	0.82	0.85	0.88	0.93	1.12
	0.3	-9.34	-0.95	0.28	0.60	0.71	0.76	0.80	0.87	1.10
	0.4	-17.96	-2.70	-0.40	0.22	0.43	0.50	0.53	0.54	0.60
	0.5	-28.58	-4.65	-1.05	-0.07	0.26	0.37	0.40	0.41	0.42
	0.6	-41.45	-6.97	-1.77	-0.35	0.12	0.28	0.32	0.32	0.32
	0.7	-56.61	-9.66	-2.58	-0.65	0.00	0.21	0.27	0.26	0.24
	0.8	-74.08	-12.74	-3.49	-0.97	-0.12	0.16	0.23	0.22	0.18
	0.9	-93.84	-16.21	-4.50	-1.30	-0.23	0.13	0.21	0.19	0.14
	1.0	-115.92	-20.06	-5.61	-1.66	-0.34	0.11	0.21	0.18	0.11
1.0	0.1	-0.17	0.71	0.83	0.87	0.88	0.89	0.90	0.92	0.98
	0.2	-3.48	0.10	0.62	0.76	0.81	0.84	0.87	0.92	1.11
	0.3	-9.22	-1.00	0.23	0.56	0.68	0.74	0.78	0.86	1.11
	0.4	-17.76	-2.79	-0.50	0.14	0.37	0.45	0.49	0.52	0.60
	0.5	-28.31	-4.82	-1.21	-0.20	0.15	0.28	0.33	0.35	0.38
	0.6	-41.06	-7.21	-2.01	-0.55	-0.04	0.15	0.22	0.23	0.25
	0.7	-56.09	-9.99	-2.91	-0.92	-0.23	0.03	0.12	0.14	0.15
	0.8	-73.39	-13.17	-3.92	-1.32	-0.41	-0.07	0.04	0.06	0.06
	0.9	-92.98	-16.75	-5.04	-1.75	-0.60	-0.17	-0.03	-0.01	-0.02
	1.0	-114.85	-20.74	-6.28	-2.21	-0.79	-0.26	-0.09	-0.07	-0.09
		<i>C<sub>s</sub></i> Values								
		<i>Q<sub>s</sub>/Q<sub>c</sub></i>								
<i>A<sub>s</sub>/A<sub>c</sub></i>	<i>A<sub>b</sub>/A<sub>c</sub></i>	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-3.90	-1.07	-0.04	0.66	1.27	1.87	2.47	3.10	3.76
	0.2	-3.76	-0.34	0.52	1.05	1.53	2.02	2.56	3.14	3.77
	0.3	-2.50	0.10	0.76	1.20	1.62	2.08	2.59	3.15	3.77
	0.4	-1.64	0.35	0.88	1.27	1.67	2.11	2.60	3.15	3.77
	0.5	-1.05	0.52	0.96	1.32	1.69	2.12	2.61	3.16	3.77
	0.6	-0.63	0.63	1.02	1.35	1.71	2.13	2.61	3.16	3.77
	0.7	-0.32	0.71	1.06	1.37	1.73	2.14	2.62	3.16	3.77
	0.8	-0.07	0.78	1.09	1.39	1.74	2.15	2.62	3.16	3.77
	0.9	0.13	0.83	1.11	1.40	1.74	2.15	2.62	3.16	3.77
	1.0	0.29	0.87	1.13	1.41	1.75	2.15	2.63	3.17	3.77
0.2	0.1	-14.54	-4.50	-1.82	-0.62	0.05	0.47	0.75	0.95	1.09
	0.2	-16.02	-3.15	-0.80	0.04	0.45	0.69	0.86	0.99	1.10
	0.3	-11.65	-1.94	-0.26	0.32	0.60	0.77	0.90	1.01	1.10
	0.4	-8.56	-1.20	0.05	0.47	0.68	0.82	0.92	1.02	1.11
	0.5	-6.41	-0.71	0.25	0.57	0.73	0.84	0.93	1.02	1.11
	0.6	-4.85	-0.36	0.38	0.63	0.76	0.86	0.94	1.02	1.11
	0.7	-3.68	-0.10	0.48	0.68	0.79	0.87	0.95	1.03	1.11
	0.8	-2.77	0.10	0.56	0.71	0.81	0.88	0.95	1.03	1.11
	0.9	-2.04	0.26	0.62	0.74	0.82	0.89	0.95	1.03	1.11
	1.0	-1.45	0.38	0.66	0.76	0.83	0.89	0.96	1.03	1.11
0.3	0.1	-32.30	-10.04	-4.34	-1.94	-0.73	-0.07	0.30	0.50	0.59
	0.2	-36.37	-7.59	-2.48	-0.79	-0.06	0.29	0.47	0.57	0.61
	0.3	-26.79	-5.07	-1.42	-0.27	0.21	0.42	0.53	0.59	0.61
	0.4	-19.94	-3.49	-0.80	0.02	0.35	0.49	0.56	0.60	0.62
	0.5	-15.18	-2.44	-0.41	0.20	0.43	0.54	0.58	0.61	0.62
	0.6	-11.73	-1.70	-0.13	0.32	0.49	0.56	0.60	0.61	0.62
	0.7	-9.13	-1.14	0.07	0.41	0.53	0.58	0.60	0.61	0.62
	0.8	-7.11	-0.72	0.23	0.48	0.57	0.60	0.61	0.62	0.62
	0.9	-5.49	-0.38	0.35	0.53	0.59	0.61	0.62	0.62	0.62
	1.0	-4.17	-0.11	0.45	0.58	0.61	0.62	0.62	0.62	0.62
0.4	0.1	-57.18	-17.78	-7.80	-3.69	-1.66	-0.59	-0.02	0.26	0.37
	0.2	-64.82	-13.76	-4.74	-1.81	-0.59	-0.02	0.24	0.36	0.39
	0.3	-47.92	-9.38	-2.93	-0.94	-0.16	0.19	0.34	0.39	0.40
	0.4	-35.81	-6.62	-1.88	-0.46	0.07	0.30	0.38	0.41	0.40
	0.5	-27.39	-4.78	-1.20	-0.16	0.22	0.36	0.41	0.42	0.41
	0.6	-21.28	-3.48	-0.73	0.04	0.31	0.41	0.43	0.43	0.41
	0.7	-16.68	-2.51	-0.38	0.20	0.38	0.44	0.45	0.43	0.41
	0.8	-13.10	-1.77	-0.12	0.31	0.44	0.46	0.46	0.44	0.41
	0.9	-10.24	-1.18	0.09	0.40	0.48	0.48	0.46	0.44	0.41
	1.0	-7.90	-0.69	0.26	0.47	0.51	0.50	0.47	0.44	0.41

## ED5-1 Wye, 30 Degree, Converging (Continued)

$A_s/A_c$	$A_b/A_c$	$C_s$ Values (Concluded)								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.5	0.1	-89.21	-27.74	-12.24	-5.89	-2.79	-1.18	-0.33	0.08	0.23
	0.2	-101.39	-21.64	-7.61	-3.07	-1.19	-0.34	0.05	0.22	0.26
	0.3	-75.05	-14.87	-4.83	-1.75	-0.54	-0.03	0.19	0.26	0.27
	0.4	-56.18	-10.59	-3.21	-1.02	-0.20	0.13	0.26	0.29	0.27
	0.5	-43.04	-7.74	-2.16	-0.56	0.02	0.23	0.30	0.30	0.27
	0.6	-33.51	-5.72	-1.43	-0.24	0.16	0.30	0.33	0.31	0.28
	0.7	-26.34	-4.22	-0.90	-0.01	0.27	0.35	0.35	0.32	0.28
	0.8	-20.75	-3.06	-0.49	0.16	0.35	0.39	0.37	0.33	0.28
	0.9	-16.29	-2.14	-0.17	0.30	0.41	0.41	0.38	0.33	0.28
	1.0	-12.64	-1.39	0.10	0.41	0.46	0.44	0.39	0.33	0.28
0.6	0.1	-128.36	-39.93	-17.66	-8.57	-4.15	-1.85	-0.66	-0.09	0.12
	0.2	-146.06	-31.26	-11.09	-4.56	-1.89	-0.68	-0.12	0.10	0.16
	0.3	-108.19	-21.55	-7.12	-2.69	-0.97	-0.24	0.07	0.17	0.17
	0.4	-81.04	-15.40	-4.80	-1.65	-0.48	-0.01	0.17	0.20	0.18
	0.5	-62.13	-11.31	-3.30	-0.99	-0.17	0.13	0.22	0.22	0.18
	0.6	-48.43	-8.41	-2.25	-0.54	0.03	0.22	0.26	0.24	0.18
	0.7	-38.10	-6.25	-1.49	-0.22	0.18	0.29	0.29	0.25	0.19
	0.8	-30.07	-4.59	-0.90	0.03	0.30	0.34	0.31	0.25	0.19
	0.9	-23.64	-3.27	-0.44	0.23	0.39	0.38	0.33	0.26	0.19
	1.0	-18.39	-2.20	-0.06	0.39	0.46	0.42	0.34	0.27	0.19
0.7	0.1	-174.66	-54.33	-24.05	-11.71	-5.72	-2.62	-1.01	-0.25	0.03
	0.2	-198.85	-42.62	-15.17	-6.31	-2.68	-1.04	-0.29	0.01	0.08
	0.3	-147.33	-29.41	-9.78	-3.77	-1.44	-0.45	-0.04	0.10	0.10
	0.4	-110.40	-21.07	-6.64	-2.36	-0.77	-0.14	0.09	0.15	0.11
	0.5	-84.67	-15.50	-4.60	-1.48	-0.36	0.05	0.17	0.17	0.11
	0.6	-66.02	-11.56	-3.19	-0.86	-0.08	0.18	0.23	0.19	0.12
	0.7	-51.97	-8.63	-2.15	-0.42	0.12	0.27	0.27	0.20	0.12
	0.8	-41.04	-6.37	-1.35	-0.08	0.27	0.34	0.29	0.21	0.12
	0.9	-32.30	-4.58	-0.72	0.19	0.39	0.39	0.32	0.22	0.12
	1.0	-25.16	-3.12	-0.21	0.40	0.49	0.43	0.33	0.23	0.13
0.8	0.1	-228.09	-70.95	-31.43	-15.33	-7.52	-3.48	-1.39	-0.40	-0.04
	0.2	-259.75	-55.70	-19.86	-8.29	-3.56	-1.43	-0.46	-0.06	-0.03
	0.3	-192.48	-38.47	-12.84	-4.99	-1.95	-0.66	-0.12	0.05	0.05
	0.4	-144.25	-27.58	-8.74	-3.16	-1.09	-0.26	0.05	0.11	0.06
	0.5	-110.65	-20.32	-6.08	-2.00	-0.55	-0.01	0.15	0.15	0.07
	0.6	-86.30	-15.17	-4.24	-1.20	-0.19	0.15	0.22	0.17	0.08
	0.7	-67.95	-11.34	-2.88	-0.62	0.08	0.27	0.27	0.19	0.08
	0.8	-53.67	-8.40	-1.84	-0.18	0.28	0.36	0.30	0.20	0.08
	0.9	-42.26	-6.05	-1.02	0.16	0.44	0.43	0.33	0.21	0.08
	1.0	-32.93	-4.15	-0.35	0.44	0.56	0.49	0.36	0.22	0.09
0.9	0.1	-288.66	-89.79	-39.78	-19.41	-9.54	-4.43	-1.80	-0.55	-0.09
	0.2	-328.76	-70.51	-25.16	-10.53	-4.54	-1.84	-0.62	-0.12	0.00
	0.3	-243.63	-48.72	-16.28	-6.35	-2.50	-0.87	-0.20	0.03	0.03
	0.4	-182.60	-34.94	-11.09	-4.03	-1.41	-0.37	0.02	0.10	0.04
	0.5	-140.07	-25.75	-7.74	-2.57	-0.74	-0.06	0.15	0.14	0.05
	0.6	-109.25	-19.24	-5.40	-1.56	-0.28	0.15	0.23	0.17	0.05
	0.7	-86.04	-14.40	-3.68	-0.83	0.06	0.30	0.30	0.20	0.06
	0.8	-67.96	-10.66	-2.37	-0.27	0.31	0.41	0.34	0.21	0.06
	0.9	-53.52	-7.70	-1.33	0.17	0.51	0.50	0.38	0.22	0.06
	1.0	-41.71	-5.29	-0.49	0.52	0.67	0.57	0.41	0.23	0.07
1.0	0.1	-356.36	-110.84	-49.12	-23.97	-11.78	-5.48	-2.23	-0.69	-0.12
	0.2	-405.88	-87.06	-31.07	-13.01	-5.62	-2.29	-0.77	-0.16	-0.02
	0.3	-300.78	-60.15	-20.11	-7.85	-3.10	-1.09	-0.26	0.02	0.02
	0.4	-225.44	-43.14	-13.70	-4.99	-1.76	-0.47	0.01	0.11	0.04
	0.5	-172.93	-31.80	-9.56	-3.18	-0.92	-0.09	0.17	0.17	0.05
	0.6	-134.89	-23.76	-6.68	-1.94	-0.35	0.17	0.28	0.20	0.06
	0.7	-106.23	-17.78	-4.56	-1.04	0.06	0.36	0.35	0.23	0.06
	0.8	-83.92	-13.18	-2.93	-0.35	0.37	0.50	0.41	0.25	0.06
	0.9	-66.08	-9.52	-1.65	0.19	0.62	0.61	0.46	0.26	0.07
	1.0	-51.51	-6.54	-0.61	0.63	0.81	0.70	0.49	0.28	0.07

## ED5-2 Wye, 45 Degree, Converging

*C<sub>b</sub>* Values

<i>A<sub>s</sub>/A<sub>c</sub></i>	<i>A<sub>b</sub>/A<sub>c</sub></i>	<i>Q<sub>b</sub>/Q<sub>c</sub></i>								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-13.70	-1.90	-0.02	0.54	0.75	0.85	0.89	0.92	0.96
	0.2	-57.73	-10.44	-2.88	-0.64	0.22	0.59	0.76	0.85	0.94
	0.3	-131.08	-24.63	-7.59	-2.53	-0.60	0.24	0.61	0.79	0.92
	0.4	-233.78	-44.46	-14.15	-5.15	-1.71	-0.23	0.43	0.72	0.88
	0.5	-365.85	-69.96	-22.58	-8.50	-3.12	-0.81	0.21	0.65	0.82
	0.6	-527.21	-101.08	-32.83	-12.55	-4.80	-1.49	-0.02	0.59	0.79
	0.7	-717.81	-137.79	-44.90	-17.28	-6.74	-2.23	-0.23	0.60	0.85
	0.8	-937.72	-180.12	-58.79	-22.73	-8.96	-3.06	-0.45	0.63	0.95
	0.9	-1187.	-228.09	-74.53	-28.88	-11.45	-3.99	-0.69	0.67	1.07
	1.0	-1465.	-281.68	-92.10	-35.74	-14.23	-5.01	-0.94	0.74	1.22
0.2	0.1	-5.52	-0.26	0.56	0.79	0.88	0.92	0.95	0.97	1.05
	0.2	-25.19	-3.97	-0.64	0.32	0.67	0.82	0.90	0.96	1.08
	0.3	-58.03	-10.14	-2.63	-0.45	0.36	0.69	0.84	0.93	1.08
	0.4	-104.08	-18.80	-5.40	-1.51	-0.07	0.52	0.77	0.88	1.01
	0.5	-163.36	-29.97	-8.97	-2.87	-0.62	0.29	0.67	0.80	0.84
	0.6	-235.59	-43.47	-13.22	-4.44	-1.20	0.12	0.65	0.83	0.85
	0.7	-320.90	-59.38	-18.21	-6.25	-1.84	-0.04	0.68	0.91	0.93
	0.8	-419.32	-77.73	-23.95	-8.33	-2.56	-0.22	0.72	1.02	1.02
	0.9	-530.86	-98.50	-30.44	-10.66	-3.36	-0.40	0.79	1.16	1.14
	1.0	-655.51	-121.72	-37.68	-13.26	-4.25	-0.59	0.87	1.33	1.28
0.3	0.1	-2.74	0.32	0.78	0.90	0.94	0.97	0.99	1.02	1.13
	0.2	-14.27	-1.77	0.13	0.66	0.85	0.93	0.97	1.03	1.21
	0.3	-33.62	-5.28	-0.95	0.27	0.70	0.87	0.94	1.01	1.19
	0.4	-60.85	-10.26	-2.48	-0.30	0.47	0.77	0.88	0.93	1.04
	0.5	-95.87	-16.64	-4.44	-1.00	0.21	0.66	0.82	0.84	0.84
	0.6	-138.38	-24.26	-6.68	-1.73	0.01	0.66	0.88	0.91	0.88
	0.7	-188.60	-33.25	-9.32	-2.58	-0.20	0.68	0.98	1.02	0.95
	0.8	-246.54	-43.60	-12.34	-3.54	-0.43	0.72	1.11	1.15	1.03
	0.9	-312.21	-55.33	-15.76	-4.61	-0.68	0.78	1.26	1.31	1.13
	1.0	-385.59	-68.43	-19.56	-5.79	-0.94	0.86	1.45	1.49	1.24
0.4	0.1	-1.32	0.63	0.90	0.96	0.99	1.00	1.02	1.06	1.20
	0.2	-8.77	-0.64	0.54	0.85	0.95	0.99	1.03	1.09	1.31
	0.3	-21.41	-2.85	-0.10	0.63	0.87	0.96	1.00	1.06	1.26
	0.4	-39.30	-6.02	-1.05	0.28	0.72	0.87	0.91	0.92	1.00
	0.5	-62.10	-9.96	-2.16	-0.06	0.63	0.85	0.90	0.88	0.86
	0.6	-89.77	-14.65	-3.42	-0.38	0.61	0.93	0.99	0.95	0.90
	0.7	-122.46	-20.19	-4.88	-0.74	0.61	1.04	1.12	1.06	0.95
	0.8	-160.18	-26.56	-6.55	-1.15	0.62	1.18	1.29	1.19	1.01
	0.9	-202.93	-33.77	-8.44	-1.60	0.64	1.36	1.48	1.35	1.07
	1.0	-250.70	-41.83	-10.54	-2.09	0.68	1.56	1.71	1.53	1.15
0.5	0.1	-0.44	0.83	0.98	1.01	1.02	1.03	1.05	1.10	1.27
	0.2	-5.45	0.04	0.79	0.97	1.02	1.04	1.07	1.14	1.39
	0.3	-14.10	-1.39	0.40	0.84	0.97	1.00	1.02	1.07	1.28
	0.4	-26.48	-3.53	-0.24	0.59	0.83	0.89	0.88	0.85	0.86
	0.5	-41.84	-5.96	-0.80	0.51	0.88	0.97	0.95	0.90	0.87
	0.6	-60.61	-8.90	-1.46	0.43	0.97	1.09	1.06	0.97	0.90
	0.7	-82.80	-12.36	-2.22	0.35	1.09	1.25	1.20	1.08	0.93
	0.8	-108.39	-16.35	-3.09	0.27	1.24	1.45	1.38	1.20	0.96
	0.9	-137.41	-20.86	-4.07	0.19	1.42	1.68	1.59	1.35	0.99
	1.0	-169.84	-25.90	-5.15	0.11	1.63	1.95	1.83	1.52	1.02
0.6	0.1	-0.41	0.83	0.98	1.02	1.03	1.04	1.07	1.13	1.33
	0.2	-5.54	-0.08	0.70	0.91	0.98	1.01	1.05	1.14	1.42
	0.3	-14.48	-1.75	0.13	0.64	0.81	0.88	0.92	0.98	1.19
	0.4	-27.10	-4.14	-0.68	0.26	0.57	0.68	0.71	0.72	0.76
	0.5	-42.84	-6.91	-1.50	-0.02	0.47	0.64	0.68	0.69	0.70
	0.6	-62.07	-10.28	-2.48	-0.34	0.37	0.61	0.67	0.66	0.63
	0.7	-84.79	-14.26	-3.62	-0.71	0.27	0.59	0.67	0.63	0.54
	0.8	-111.02	-18.84	-4.92	-1.12	0.16	0.58	0.67	0.61	0.44
	0.9	-140.76	-24.03	-6.40	-1.57	0.04	0.58	0.68	0.59	0.31
	1.0	-174.01	-29.83	-8.04	-2.07	-0.08	0.58	0.70	0.56	0.15

## ED5-2 Wye, 45 Degree, Converging (Continued)

$A_s/A_c$	$A_b/A_c$	$C_b$ Values (Concluded)								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.7	0.1	0.03	0.94	1.03	1.05	1.06	1.07	1.10	1.16	1.39
	0.2	-3.96	0.25	0.83	0.97	1.01	1.04	1.08	1.17	1.47
	0.3	-11.07	-1.10	0.34	0.71	0.83	0.87	0.90	0.95	1.13
	0.4	-20.92	-2.92	-0.27	0.43	0.65	0.72	0.73	0.73	0.77
	0.5	-33.20	-5.01	-0.85	0.24	0.59	0.69	0.71	0.69	0.70
	0.6	-48.21	-7.55	-1.55	0.03	0.53	0.68	0.69	0.65	0.61
	0.7	-65.95	-10.56	-2.37	-0.20	0.48	0.68	0.69	0.62	0.49
	0.8	-86.42	-14.01	-3.30	-0.46	0.43	0.68	0.69	0.58	0.35
	0.9	-109.65	-17.93	-4.35	-0.75	0.38	0.70	0.70	0.53	0.18
	1.0	-135.63	-22.32	-5.53	-1.07	0.33	0.72	0.71	0.48	-0.03
0.8	0.1	0.38	1.02	1.08	1.08	1.08	1.09	1.12	1.19	1.44
	0.2	-2.78	0.50	0.91	1.01	1.03	1.05	1.09	1.18	1.49
	0.3	-8.58	-0.65	0.47	0.74	0.82	0.85	0.86	0.89	1.02
	0.4	-16.29	-2.00	0.05	0.56	0.71	0.75	0.74	0.74	0.78
	0.5	-25.98	-3.59	-0.37	0.44	0.68	0.73	0.72	0.69	0.69
	0.6	-37.82	-5.52	-0.87	0.31	0.65	0.72	0.70	0.64	0.58
	0.7	-51.83	-7.79	-1.44	0.17	0.63	0.73	0.69	0.59	0.43
	0.8	-68.01	-10.42	-2.10	0.01	0.62	0.75	0.69	0.53	0.25
	0.9	-86.37	-13.39	-2.84	-0.16	0.61	0.77	0.68	0.47	0.03
	1.0	-106.91	-16.73	-3.68	-0.35	0.61	0.79	0.68	0.38	-0.25
0.9	0.1	0.65	1.10	1.11	1.10	1.10	1.11	1.14	1.22	1.49
	0.2	-1.87	0.68	0.98	1.03	1.05	1.06	1.09	1.18	1.49
	0.3	-6.70	-0.33	0.54	0.74	0.79	0.80	0.80	0.81	0.87
	0.4	-12.69	-1.29	0.29	0.66	0.76	0.77	0.75	0.74	0.78
	0.5	-20.37	-2.48	0.00	0.59	0.74	0.75	0.72	0.69	0.67
	0.6	-29.77	-3.94	-0.34	0.52	0.73	0.75	0.70	0.63	0.54
	0.7	-40.89	-5.66	-0.73	0.45	0.74	0.76	0.68	0.56	0.36
	0.8	-53.74	-7.64	-1.18	0.37	0.76	0.78	0.67	0.48	0.13
	0.9	-68.32	-9.89	-1.69	0.28	0.77	0.80	0.65	0.38	-0.15
	1.0	-84.66	-12.42	-2.27	0.18	0.80	0.83	0.62	0.26	-0.49
1.0	0.1	0.88	1.16	1.14	1.12	1.12	1.13	1.16	1.25	1.54
	0.2	-1.17	0.81	1.02	1.05	1.05	1.06	1.09	1.18	1.48
	0.3	-5.09	-0.02	0.64	0.78	0.81	0.81	0.80	0.80	0.86
	0.4	-9.81	-0.72	0.48	0.74	0.79	0.78	0.76	0.74	0.77
	0.5	-15.89	-1.61	0.29	0.71	0.79	0.77	0.72	0.68	0.65
	0.6	-23.34	-2.69	0.07	0.68	0.80	0.77	0.69	0.60	0.49
	0.7	-32.15	-3.96	-0.18	0.66	0.82	0.78	0.67	0.51	0.27
	0.8	-42.35	-5.44	-0.47	0.64	0.85	0.79	0.63	0.41	0.00
	0.9	-53.94	-7.12	-0.80	0.61	0.88	0.81	0.60	0.28	-0.34
	1.0	-66.93	-9.01	-1.17	0.58	0.92	0.82	0.55	0.13	-0.75
$A_s/A_c$	$A_b/A_c$	$C_s$ Values								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9


$A_s/A_c$	$A_b/A_c$	$Q_s/Q_c$								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-0.64	-0.63	0.17	1.00	1.87	2.79	3.76	4.81	5.92
	0.2	-2.38	-0.06	0.77	1.47	2.19	2.99	3.88	4.86	5.93
	0.3	-1.56	0.35	1.03	1.64	2.30	3.06	3.91	4.87	5.94
	0.4	-0.89	0.59	1.17	1.73	2.36	3.09	3.93	4.88	5.94
	0.5	-0.40	0.75	1.26	1.78	2.40	3.11	3.94	4.88	5.94
	0.6	-0.04	0.86	1.32	1.82	2.42	3.13	3.95	4.89	5.94
	0.7	0.23	0.95	1.36	1.85	2.44	3.14	3.96	4.89	5.94
	0.8	0.45	1.01	1.40	1.87	2.45	3.15	3.96	4.89	5.94
	0.9	0.62	1.06	1.42	1.88	2.46	3.15	3.96	4.89	5.94
	1.0	0.76	1.10	1.44	1.89	2.47	3.16	3.97	4.89	5.94
0.2	0.1	-0.33	-2.09	-1.13	-0.35	0.22	0.65	0.97	1.23	1.45
	0.2	-10.16	-2.08	-0.43	0.24	0.62	0.88	1.10	1.29	1.46
	0.3	-7.83	-1.20	0.03	0.50	0.77	0.97	1.14	1.30	1.46
	0.4	-5.62	-0.59	0.30	0.65	0.85	1.01	1.16	1.31	1.46
	0.5	-3.96	-0.18	0.48	0.74	0.90	1.04	1.18	1.32	1.47
	0.6	-2.71	0.12	0.60	0.80	0.94	1.06	1.19	1.32	1.47
	0.7	-1.75	0.34	0.70	0.85	0.96	1.07	1.19	1.32	1.47
	0.8	-0.99	0.52	0.77	0.88	0.98	1.08	1.20	1.32	1.47
	0.9	-0.38	0.66	0.82	0.91	0.99	1.09	1.20	1.33	1.47
	1.0	0.13	0.77	0.87	0.93	1.00	1.10	1.20	1.33	1.47

ED5-2 Wye, 45 Degree, Converging (*Continued*)

$A_s/A_c$	$A_b/A_c$	$C_s$ Values ( <i>Continued</i> )								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.3	0.1	-0.18	-4.36	-2.61	-1.29	-0.45	0.08	0.41	0.60	0.71
	0.2	-23.33	-5.14	-1.67	-0.44	0.12	0.42	0.58	0.67	0.72
	0.3	-18.44	-3.44	-0.84	0.00	0.36	0.54	0.64	0.69	0.73
	0.4	-13.64	-2.22	-0.34	0.25	0.49	0.60	0.67	0.70	0.73
	0.5	-10.00	-1.37	0.00	0.41	0.57	0.64	0.69	0.71	0.73
	0.6	-7.26	-0.75	0.24	0.52	0.62	0.67	0.70	0.72	0.73
	0.7	-5.15	-0.29	0.41	0.60	0.66	0.69	0.71	0.72	0.73
	0.8	-3.48	0.07	0.55	0.66	0.69	0.70	0.71	0.72	0.73
	0.9	-2.14	0.36	0.65	0.71	0.72	0.72	0.72	0.73	0.73
	1.0	-1.03	0.60	0.74	0.75	0.73	0.73	0.72	0.72	0.73
0.4	0.1	-0.46	-7.64	-4.66	-2.49	-1.15	-0.36	0.10	0.33	0.43
	0.2	-42.17	-9.48	-3.34	-1.23	-0.31	0.12	0.33	0.42	0.44
	0.3	-33.68	-6.60	-1.98	-0.53	0.05	0.31	0.41	0.45	0.45
	0.4	-25.24	-4.51	-1.13	-0.13	0.25	0.40	0.46	0.47	0.45
	0.5	-18.83	-3.04	-0.57	0.13	0.37	0.46	0.48	0.48	0.46
	0.6	-13.99	-1.97	-0.17	0.31	0.46	0.50	0.50	0.48	0.46
	0.7	-10.27	-1.17	0.12	0.44	0.52	0.53	0.51	0.49	0.46
	0.8	-7.32	-0.54	0.35	0.54	0.57	0.55	0.52	0.49	0.46
	0.9	-4.94	-0.04	0.53	0.62	0.61	0.57	0.53	0.49	0.46
	1.0	-2.98	0.37	0.68	0.68	0.64	0.58	0.54	0.50	0.46
0.5	0.1	-1.43	-12.03	-7.36	-4.03	-2.01	-0.84	-0.18	0.14	0.26
	0.2	-66.95	-15.18	-5.49	-2.21	-0.81	-0.16	0.14	0.26	0.28
	0.3	-53.80	-10.77	-3.45	-1.17	-0.27	0.11	0.26	0.30	0.29
	0.4	-40.66	-7.54	-2.16	-0.57	0.02	0.25	0.32	0.33	0.30
	0.5	-30.68	-5.27	-1.30	-0.18	0.21	0.33	0.36	0.34	0.30
	0.6	-23.15	-3.62	-0.69	0.09	0.33	0.39	0.38	0.35	0.30
	0.7	-17.34	-2.38	-0.24	0.29	0.42	0.43	0.40	0.35	0.30
	0.8	-12.75	-1.41	0.11	0.44	0.49	0.47	0.41	0.36	0.30
	0.9	-9.04	-0.64	0.39	0.56	0.55	0.49	0.43	0.36	0.30
	1.0	-5.99	0.00	0.61	0.65	0.59	0.51	0.43	0.36	0.30
0.6	0.1	-3.34	-17.58	-10.74	-5.94	-3.06	-1.39	-0.48	-0.03	0.13
	0.2	-97.90	-22.29	-8.18	-3.41	-1.39	-0.46	-0.03	0.13	0.16
	0.3	-79.03	-15.99	-5.28	-1.94	-0.64	-0.09	0.13	0.19	0.17
	0.4	-60.15	-11.37	-3.44	-1.09	-0.23	0.10	0.21	0.22	0.18
	0.5	-45.80	-8.13	-2.22	-0.55	0.03	0.22	0.26	0.24	0.18
	0.6	-34.97	-5.77	-1.35	-0.17	0.20	0.30	0.30	0.25	0.18
	0.7	-26.62	-3.98	-0.71	0.11	0.33	0.36	0.32	0.26	0.19
	0.8	-20.02	-2.59	-0.21	0.33	0.43	0.41	0.34	0.26	0.19
	0.9	-14.68	-1.48	0.18	0.49	0.51	0.44	0.35	0.27	0.19
	1.0	-10.29	-0.57	0.51	0.63	0.57	0.47	0.37	0.27	0.19
0.7	0.1	-6.43	-24.36	-14.82	-8.23	-4.31	-2.04	-0.81	-0.20	0.01
	0.2	-135.28	-30.88	-11.42	-4.85	-2.08	-0.80	-0.21	0.02	0.06
	0.3	-109.64	-22.35	-7.50	-2.88	-1.07	-0.31	0.00	0.09	0.07
	0.4	-83.96	-16.08	-5.02	-1.73	-0.52	-0.05	0.11	0.13	0.08
	0.5	-64.44	-11.67	-3.36	-0.99	-0.17	0.11	0.18	0.15	0.09
	0.6	-49.71	-8.47	-2.19	-0.48	0.06	0.22	0.22	0.17	0.09
	0.7	-38.35	-6.04	-1.31	-0.10	0.24	0.30	0.26	0.18	0.09
	0.8	-29.37	-4.16	-0.64	0.18	0.37	0.36	0.28	0.19	0.09
	0.9	-22.12	-2.65	-0.10	0.41	0.47	0.40	0.30	0.19	0.09
	1.0	-16.14	-1.41	0.33	0.60	0.55	0.44	0.32	0.20	0.09
0.8	0.1	-10.94	-32.43	-19.63	-10.93	-5.77	-2.80	-1.18	-0.38	-0.09
	0.2	-179.32	-41.01	-15.25	-6.55	-2.88	-1.19	-0.41	-0.10	-0.04
	0.3	-145.86	-29.89	-10.14	-3.99	-1.58	-0.55	-0.13	0.00	-0.02
	0.4	-112.34	-21.71	-6.91	-2.50	-0.86	-0.22	0.01	0.05	-0.01
	0.5	-86.85	-15.96	-4.75	-1.54	-0.41	-0.01	0.10	0.08	0.00
	0.6	-67.62	-11.78	-3.22	-0.87	-0.10	0.13	0.16	0.10	0.00
	0.7	-52.79	-8.62	-2.08	-0.38	0.12	0.23	0.20	0.11	0.00
	0.8	-41.06	-6.16	-1.20	0.00	0.29	0.31	0.23	0.12	0.01
	0.9	-31.59	-4.19	-0.51	0.29	0.43	0.37	0.26	0.13	0.01
	1.0	-23.78	-2.58	0.06	0.53	0.54	0.42	0.28	0.14	0.01

## ED5-2 Wye, 45 Degree, Converging (Continued)

$A_s/A_c$	$A_b/A_c$	$C_s$ Values (Concluded)								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.9	0.1	-17.13	-41.85	-25.21	-14.05	-7.45	-3.66	-1.59	-0.57	-0.20
	0.2	-230.27	-52.75	-19.69	-8.53	-3.81	-1.63	-0.63	-0.22	-0.13
	0.3	-187.95	-38.69	-13.24	-5.29	-2.16	-0.83	-0.28	-0.10	-0.10
	0.4	-145.53	-28.34	-9.15	-3.41	-1.26	-0.41	-0.10	-0.04	-0.09
	0.5	-113.27	-21.07	-6.42	-2.19	-0.69	-0.15	0.01	0.00	-0.09
	0.6	-88.94	-15.78	-4.48	-1.35	-0.30	0.03	0.09	0.03	-0.08
	0.7	-70.16	-11.78	-3.04	-0.73	-0.02	0.16	0.14	0.04	-0.08
	0.8	-55.33	-8.67	-1.93	-0.25	0.20	0.26	0.18	0.06	-0.07
	0.9	-43.33	-6.18	-1.05	0.12	0.37	0.33	0.21	0.07	-0.07
	1.0	-33.46	-4.14	-0.34	0.42	0.50	0.39	0.24	0.08	-0.07
1.0	0.1	-25.23	-52.69	-31.58	-17.61	-9.37	-4.64	-2.06	-0.79	-0.31
	0.2	-288.39	-66.15	-24.77	-10.80	-4.88	-2.14	-0.87	-0.35	-0.22
	0.3	-236.14	-48.79	-16.81	-6.80	-2.85	-1.15	-0.44	-0.20	-0.19
	0.4	-183.77	-36.02	-11.76	-4.47	-1.73	-0.63	-0.22	-0.12	-0.18
	0.5	-143.95	-27.05	-8.39	-2.98	-1.03	-0.31	-0.08	-0.08	-0.17
	0.6	-113.91	-20.52	-6.00	-1.93	-0.55	-0.09	0.01	-0.04	-0.16
	0.7	-90.73	-15.58	-4.23	-1.17	-0.20	0.07	0.08	-0.02	-0.16
	0.8	-72.41	-11.74	-2.86	-0.58	0.06	0.19	0.13	-0.01	-0.16
	0.9	-57.61	-8.66	-1.77	-0.12	0.27	0.28	0.16	0.01	-0.15
	1.0	-45.42	-6.15	-0.88	0.25	0.44	0.36	0.20	0.02	-0.15

ED5-3 Tee,  $D_c < \text{or} = 250$  mm, Converging

$A_s/A_c$	$A_b/A_c$	$C_b$ Values								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-13.39	-1.73	0.13	0.68	0.89	0.98	1.02	1.05	1.08
	0.2	-56.68	-9.99	-2.53	-0.32	0.52	0.88	1.04	1.12	1.18
	0.3	-128.89	-23.79	-6.99	-2.02	-0.12	0.68	1.04	1.20	1.29
	0.4	-230.03	-43.12	-13.26	-4.40	-1.04	0.40	1.03	1.30	1.42
	0.5	-360.10	-68.01	-21.33	-7.49	-2.23	0.02	1.00	1.40	1.53
	0.6	-519.10	-98.44	-31.20	-11.27	-3.69	-0.46	0.95	1.52	1.66
	0.7	-706.92	-134.35	-42.83	-15.70	-5.38	-0.99	0.93	1.70	1.88
	0.8	-923.64	-175.79	-56.25	-20.82	-7.34	-1.60	0.90	1.91	2.15
	0.9	-1169.	-222.75	-71.47	-26.62	-9.56	-2.30	0.87	2.14	2.44
	1.0	-1444.	-275.24	-88.47	-33.10	-12.04	-3.08	0.84	2.40	2.76
0.2	0.1	-5.33	-0.12	0.69	0.92	1.01	1.04	1.06	1.08	1.13
	0.2	-24.56	-3.63	-0.36	0.59	0.93	1.08	1.14	1.19	1.27
	0.3	-56.72	-9.54	-2.15	-0.01	0.78	1.10	1.23	1.30	1.39
	0.4	-101.83	-17.86	-4.68	-0.87	0.52	1.09	1.32	1.41	1.48
	0.5	-159.91	-28.59	-7.98	-2.02	0.17	1.05	1.40	1.51	1.51
	0.6	-230.83	-41.68	-11.98	-3.39	-0.24	1.03	1.53	1.66	1.61
	0.7	-314.56	-57.10	-16.68	-4.98	-0.69	1.04	1.71	1.90	1.82
	0.8	-411.18	-74.90	-22.10	-6.82	-1.21	1.04	1.92	2.16	2.05
	0.9	-520.69	-95.08	-28.25	-8.90	-1.81	1.04	2.15	2.45	2.31
	1.0	-643.09	-117.63	-35.12	-11.24	-2.47	1.04	2.41	2.78	2.58

ED5-3 Tee,  $D_c < \text{or } = 250 \text{ mm}$ , Converging (*Continued*)

$A_s/A_c$	$A_b/A_c$	$C_b$ Values ( <i>Continued</i> )								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.3	0.1	-2.67	0.42	0.88	1.01	1.05	1.07	1.09	1.11	1.18
	0.2	-14.05	-1.55	0.36	0.89	1.08	1.16	1.19	1.23	1.34
	0.3	-33.18	-4.91	-0.58	0.64	1.07	1.23	1.30	1.34	1.44
	0.4	-60.09	-9.68	-1.94	0.24	1.00	1.29	1.39	1.42	1.47
	0.5	-94.80	-15.89	-3.74	-0.33	0.87	1.32	1.46	1.46	1.38
	0.6	-136.97	-23.33	-5.84	-0.92	0.81	1.45	1.65	1.66	1.53
	0.7	-186.81	-32.14	-8.32	-1.62	0.74	1.61	1.88	1.88	1.70
	0.8	-244.33	-42.30	-11.19	-2.43	0.65	1.78	2.14	2.13	1.88
	0.9	-309.54	-53.82	-14.44	-3.35	0.54	1.98	2.42	2.41	2.08
	1.0	-382.43	-66.70	-18.08	-4.39	0.42	2.19	2.74	2.72	2.29
0.4	0.1	-1.36	0.69	0.98	1.06	1.08	1.10	1.11	1.14	1.23
	0.2	-8.95	-0.54	0.71	1.04	1.15	1.20	1.22	1.26	1.40
	0.3	-21.82	-2.70	0.16	0.94	1.19	1.29	1.32	1.35	1.47
	0.4	-39.99	-5.81	-0.67	0.73	1.19	1.35	1.39	1.39	1.41
	0.5	-63.37	-9.82	-1.75	0.45	1.18	1.42	1.47	1.43	1.32
	0.6	-91.72	-14.59	-2.97	0.20	1.26	1.60	1.67	1.60	1.43
	0.7	-125.23	-20.24	-4.41	-0.10	1.34	1.81	1.90	1.81	1.56
	0.8	-163.91	-26.77	-6.09	-0.45	1.43	2.04	2.16	2.03	1.69
	0.9	-207.76	-34.17	-7.99	-0.85	1.53	2.30	2.44	2.28	1.82
	1.0	-256.79	-42.45	-10.12	-1.30	1.63	2.58	2.75	2.54	1.95
0.5	0.1	-0.60	0.85	1.04	1.09	1.11	1.12	1.13	1.16	1.27
	0.2	-6.03	0.04	0.91	1.13	1.20	1.22	1.24	1.29	1.44
	0.3	-15.35	-1.46	0.56	1.09	1.25	1.30	1.32	1.35	1.46
	0.4	-28.59	-3.67	-0.01	0.96	1.26	1.34	1.35	1.32	1.29
	0.5	-45.45	-6.42	-0.66	0.85	1.33	1.45	1.45	1.38	1.24
	0.6	-65.92	-9.70	-1.41	0.78	1.46	1.64	1.63	1.53	1.32
	0.7	-90.12	-13.58	-2.29	0.69	1.61	1.86	1.85	1.70	1.39
	0.8	-118.07	-18.07	-3.32	0.57	1.78	2.11	2.09	1.89	1.46
	0.9	-149.75	-23.18	-4.49	0.43	1.96	2.38	2.35	2.09	1.53
	1.0	-185.19	-28.89	-5.81	0.27	2.16	2.67	2.63	2.31	1.57
0.6	0.1	-0.11	0.96	1.09	1.12	1.12	1.13	1.15	1.18	1.31
	0.2	-4.20	0.39	1.03	1.18	1.22	1.24	1.26	1.30	1.47
	0.3	-11.33	-0.72	0.79	1.16	1.27	1.30	1.31	1.33	1.43
	0.4	-21.57	-2.42	0.35	1.05	1.25	1.29	1.27	1.22	1.12
	0.5	-34.29	-4.35	-0.03	1.07	1.38	1.44	1.41	1.32	1.16
	0.6	-49.85	-6.73	-0.50	1.08	1.54	1.63	1.57	1.45	1.19
	0.7	-68.26	-9.55	-1.06	1.09	1.71	1.83	1.76	1.58	1.21
	0.8	-89.52	-12.81	-1.72	1.10	1.91	2.07	1.97	1.73	1.22
	0.9	-113.64	-16.52	-2.47	1.10	2.12	2.32	2.20	1.88	1.21
	1.0	-140.62	-20.68	-3.33	1.09	2.35	2.60	2.44	2.03	1.16
0.7	0.1	0.22	1.03	1.12	1.14	1.14	1.14	1.16	1.20	1.35
	0.2	-3.00	0.62	1.10	1.21	1.23	1.24	1.26	1.31	1.49
	0.3	-8.74	-0.27	0.91	1.19	1.26	1.27	1.27	1.28	1.36
	0.4	-16.90	-1.59	0.58	1.11	1.25	1.27	1.24	1.18	1.06
	0.5	-26.99	-3.06	0.33	1.17	1.38	1.41	1.36	1.26	1.06
	0.6	-39.35	-4.86	0.02	1.22	1.54	1.57	1.50	1.35	1.05
	0.7	-53.97	-7.01	-0.35	1.29	1.72	1.76	1.65	1.45	1.02
	0.8	-70.87	-9.50	-0.79	1.35	1.91	1.97	1.82	1.54	0.96
	0.9	-90.04	-12.34	-1.31	1.41	2.12	2.19	2.00	1.64	0.86
	1.0	-111.50	-15.53	-1.89	1.46	2.34	2.43	2.19	1.73	0.72
0.8	0.1	0.46	1.08	1.14	1.15	1.15	1.16	1.17	1.22	1.38
	0.2	-2.20	0.76	1.14	1.22	1.24	1.24	1.26	1.31	1.49
	0.3	-7.04	-0.01	0.95	1.18	1.23	1.23	1.23	1.22	1.27
	0.4	-13.77	-1.06	0.71	1.13	1.24	1.24	1.20	1.13	1.00
	0.5	-22.11	-2.24	0.54	1.20	1.36	1.36	1.30	1.19	0.97
	0.6	-32.33	-3.69	0.31	1.27	1.50	1.50	1.41	1.25	0.90
	0.7	-44.42	-5.41	0.04	1.34	1.66	1.65	1.53	1.30	0.81
	0.8	-58.40	-7.42	-0.29	1.42	1.83	1.83	1.65	1.35	0.67
	0.9	-74.28	-9.72	-0.67	1.49	2.01	2.01	1.78	1.38	0.49
	1.0	-92.06	-12.30	-1.12	1.56	2.21	2.20	1.92	1.40	0.24

ED5-3 Tee,  $D_c < \text{or } = 250 \text{ mm}$ , Converging (*Continued*)

		$C_b$ Values ( <i>Concluded</i> )								
		$Q_b/Q_c$								
$A_s/A_c$	$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.9	0.1	0.62	1.12	1.16	1.16	1.16	1.17	1.19	1.24	1.41
	0.2	-1.67	0.85	1.16	1.22	1.23	1.24	1.25	1.30	1.48
	0.3	-5.95	0.12	0.95	1.14	1.18	1.18	1.16	1.15	1.14
	0.4	-11.68	-0.74	0.77	1.12	1.20	1.20	1.16	1.08	0.93
	0.5	-18.85	-1.74	0.63	1.18	1.31	1.30	1.23	1.11	0.86
	0.6	-27.63	-2.98	0.44	1.24	1.42	1.41	1.31	1.13	0.75
	0.7	-38.04	-4.45	0.21	1.30	1.55	1.53	1.39	1.14	0.58
	0.8	-50.07	-6.17	-0.07	1.36	1.69	1.66	1.47	1.13	0.37
	0.9	-63.75	-8.14	-0.40	1.42	1.83	1.79	1.54	1.11	0.09
	1.0	-79.08	-10.36	-0.79	1.46	1.98	1.92	1.61	1.06	-0.26
1.0	0.1	0.74	1.15	1.18	1.17	1.17	1.18	1.20	1.25	1.43
	0.2	-1.33	0.89	1.16	1.21	1.22	1.22	1.24	1.29	1.46
	0.3	-5.30	0.15	0.90	1.08	1.11	1.11	1.09	1.06	0.99
	0.4	-10.31	-0.57	0.78	1.09	1.16	1.15	1.11	1.03	0.86
	0.5	-16.71	-1.47	0.64	1.13	1.24	1.22	1.15	1.03	0.74
	0.6	-24.56	-2.59	0.46	1.17	1.32	1.30	1.20	1.01	0.57
	0.7	-33.87	-3.93	0.23	1.20	1.41	1.38	1.24	0.97	0.34
	0.8	-44.64	-5.49	-0.05	1.22	1.51	1.46	1.27	0.91	0.05
	0.9	-56.89	-7.29	-0.38	1.24	1.59	1.54	1.28	0.82	-0.33
	1.0	-70.62	-9.32	-0.77	1.24	1.68	1.61	1.28	0.69	-0.80
		$C_s$ Values								
		$Q_s/Q_c$								
$A_s/A_c$	$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	6.57	1.67	1.10	0.95	0.88	0.85	0.84	0.83	0.82
	0.2	4.13	1.39	1.03	0.92	0.87	0.85	0.83	0.83	0.82
	0.3	3.30	1.30	1.00	0.91	0.87	0.85	0.83	0.82	0.82
	0.4	2.89	1.24	0.99	0.90	0.86	0.84	0.83	0.82	0.82
	0.5	2.63	1.21	0.97	0.90	0.86	0.84	0.83	0.82	0.82
	0.6	2.45	1.18	0.97	0.89	0.86	0.84	0.83	0.82	0.82
	0.7	2.32	1.16	0.96	0.89	0.86	0.84	0.83	0.82	0.82
	0.8	2.22	1.15	0.95	0.89	0.85	0.84	0.83	0.82	0.82
	0.9	2.14	1.13	0.95	0.88	0.85	0.84	0.83	0.82	0.82
	1.0	2.07	1.12	0.94	0.88	0.85	0.84	0.83	0.82	0.82
0.2	0.1	34.53	5.26	2.11	1.29	0.98	0.84	0.76	0.71	0.68
	0.2	18.11	3.42	1.62	1.11	0.90	0.80	0.74	0.70	0.68
	0.3	12.67	2.79	1.45	1.04	0.87	0.78	0.73	0.70	0.68
	0.4	9.98	2.47	1.36	1.01	0.85	0.77	0.72	0.69	0.67
	0.5	8.39	2.27	1.30	0.98	0.84	0.76	0.72	0.69	0.67
	0.6	7.34	2.13	1.26	0.96	0.83	0.76	0.72	0.69	0.67
	0.7	6.61	2.02	1.22	0.95	0.82	0.75	0.71	0.69	0.67
	0.8	6.08	1.94	1.19	0.93	0.81	0.75	0.71	0.68	0.67
	0.9	5.68	1.87	1.17	0.92	0.80	0.74	0.70	0.68	0.66
	1.0	4.55	1.61	1.05	0.86	0.76	0.71	0.68	0.66	0.65
0.3	0.1	90.35	12.35	4.15	2.07	1.30	0.95	0.76	0.65	0.59
	0.2	44.33	7.19	2.80	1.57	1.08	0.84	0.71	0.63	0.57
	0.3	29.24	5.46	2.33	1.40	1.00	0.80	0.69	0.62	0.57
	0.4	21.88	4.59	2.09	1.30	0.96	0.78	0.67	0.61	0.56
	0.5	17.62	4.06	1.93	1.24	0.92	0.76	0.66	0.60	0.56
	0.6	14.90	3.71	1.82	1.19	0.90	0.74	0.65	0.59	0.55
	0.7	13.06	3.45	1.74	1.15	0.88	0.73	0.64	0.59	0.55
	0.8	11.78	3.26	1.67	1.12	0.86	0.72	0.63	0.58	0.54
	0.9	9.02	2.64	1.41	0.97	0.77	0.66	0.59	0.54	0.51
	1.0	8.36	2.52	1.36	0.95	0.75	0.65	0.58	0.54	0.51
0.4	0.1	167.76	22.21	7.04	3.22	1.81	1.17	0.84	0.64	0.52
	0.2	78.99	12.25	4.42	2.26	1.39	0.97	0.74	0.60	0.50
	0.3	50.14	8.96	3.54	1.92	1.24	0.90	0.70	0.57	0.49
	0.4	36.26	7.32	3.08	1.74	1.16	0.85	0.67	0.56	0.48
	0.5	28.38	6.35	2.80	1.63	1.10	0.82	0.65	0.54	0.47
	0.6	23.50	5.72	2.61	1.54	1.05	0.79	0.63	0.53	0.46
	0.7	20.32	5.27	2.46	1.47	1.02	0.77	0.62	0.52	0.45
	0.8	14.94	4.13	1.98	1.21	0.85	0.65	0.53	0.46	0.40
	0.9	13.55	3.88	1.89	1.16	0.82	0.63	0.52	0.45	0.39
	1.0	12.66	3.69	1.80	1.12	0.79	0.62	0.51	0.44	0.39

ED5-3 Tee,  $D_c < \text{or } = 250 \text{ mm}$ , Converging (Continued)

		$C_s$ Values (Concluded)								
		$Q_s/Q_c$								
$A_s/A_c$	$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.5	0.1	252.09	33.17	10.32	4.56	2.44	1.47	0.97	0.67	0.49
	0.2	114.73	17.76	6.27	3.07	1.79	1.16	0.81	0.60	0.46
	0.3	70.56	12.71	4.92	2.56	1.56	1.05	0.75	0.56	0.44
	0.4	49.68	10.24	4.23	2.29	1.43	0.98	0.71	0.54	0.42
	0.5	38.12	8.81	3.81	2.11	1.34	0.93	0.68	0.52	0.41
	0.6	31.23	7.90	3.53	1.99	1.27	0.88	0.65	0.50	0.39
	0.7	21.87	6.00	2.75	1.57	1.01	0.71	0.52	0.40	0.32
	0.8	19.30	5.57	2.59	1.49	0.96	0.67	0.50	0.38	0.30
	0.9	17.84	5.27	2.46	1.42	0.92	0.65	0.48	0.37	0.29
	1.0	17.16	5.05	2.36	1.36	0.88	0.62	0.46	0.35	0.28
0.6	0.1	323.56	42.99	13.40	5.88	3.09	1.80	1.12	0.73	0.48
	0.2	142.32	22.64	8.06	3.91	2.23	1.39	0.92	0.63	0.44
	0.3	84.89	16.05	6.28	3.24	1.92	1.23	0.83	0.58	0.41
	0.4	58.43	12.90	5.39	2.88	1.75	1.14	0.78	0.55	0.39
	0.5	44.34	11.13	4.86	2.66	1.63	1.07	0.74	0.52	0.37
	0.6	29.06	8.20	3.69	2.04	1.25	0.81	0.55	0.38	0.26
	0.7	24.71	7.51	3.44	1.91	1.18	0.77	0.52	0.35	0.24
	0.8	22.56	7.06	3.26	1.81	1.11	0.72	0.48	0.33	0.22
	0.9	21.89	6.78	3.12	1.73	1.06	0.68	0.45	0.30	0.20
	1.0	22.24	6.61	3.00	1.65	1.00	0.65	0.43	0.28	0.18
0.7	0.1	360.67	49.26	15.65	6.94	3.65	2.11	1.29	0.80	0.49
	0.2	152.32	25.82	9.48	4.66	2.65	1.63	1.04	0.68	0.44
	0.3	87.85	18.38	7.46	3.88	2.29	1.44	0.94	0.62	0.40
	0.4	59.34	14.92	6.47	3.48	2.09	1.33	0.87	0.58	0.37
	0.5	35.18	10.56	4.78	2.60	1.55	0.97	0.62	0.38	0.22
	0.6	28.26	9.51	4.41	2.42	1.45	0.90	0.57	0.35	0.19
	0.7	25.45	8.91	4.16	2.28	1.36	0.85	0.53	0.32	0.17
	0.8	25.21	8.60	3.99	2.18	1.29	0.79	0.49	0.28	0.14
	0.9	26.68	8.48	3.86	2.08	1.22	0.74	0.45	0.25	0.12
	1.0	29.34	8.49	3.77	2.01	1.16	0.70	0.41	0.22	0.10
0.8	0.1	343.46	49.71	16.47	7.52	4.02	2.35	1.43	0.87	0.51
	0.2	136.74	26.38	10.30	5.22	3.01	1.85	1.17	0.74	0.45
	0.3	75.52	19.20	8.32	4.45	2.64	1.66	1.06	0.67	0.41
	0.4	37.55	12.79	5.92	3.23	1.91	1.17	0.72	0.42	0.21
	0.5	27.25	11.28	5.41	2.98	1.77	1.08	0.66	0.37	0.18
	0.6	24.23	10.57	5.10	2.81	1.66	1.01	0.60	0.33	0.14
	0.7	25.36	10.32	4.91	2.69	1.57	0.94	0.55	0.29	0.11
	0.8	29.09	10.37	4.80	2.59	1.50	0.88	0.50	0.25	0.08
	0.9	34.55	10.60	4.74	2.50	1.42	0.82	0.46	0.21	0.05
	1.0	41.23	10.98	4.71	2.43	1.36	0.77	0.41	0.18	0.01
0.9	0.1	256.86	42.66	15.41	7.44	4.14	2.48	1.53	0.93	0.54
	0.2	90.70	23.73	10.34	5.54	3.28	2.05	1.30	0.81	0.47
	0.3	29.93	14.20	6.95	3.86	2.30	1.41	0.85	0.48	0.22
	0.4	16.27	12.21	6.28	3.55	2.12	1.29	0.77	0.42	0.18
	0.5	14.80	11.58	5.96	3.35	1.99	1.20	0.70	0.37	0.14
	0.6	19.43	11.62	5.81	3.23	1.89	1.13	0.64	0.32	0.10
	0.7	27.55	12.06	5.77	3.14	1.81	1.06	0.59	0.27	0.06
	0.8	37.84	12.73	5.79	3.07	1.74	0.99	0.53	0.23	0.02
	0.9	49.59	13.57	5.85	3.01	1.67	0.93	0.48	0.18	-0.02
	1.0	62.35	14.52	5.94	2.97	1.61	0.87	0.42	0.14	-0.06
1.0	0.1	94.95	27.29	12.24	6.64	3.96	2.48	1.57	0.98	0.57
	0.2	-6.40	12.70	7.32	4.31	2.64	1.64	1.00	0.56	0.25
	0.3	-17.35	10.90	6.66	3.97	2.44	1.51	0.90	0.49	0.20
	0.4	-11.05	11.02	6.50	3.82	2.32	1.41	0.83	0.43	0.15
	0.5	2.15	11.91	6.54	3.74	2.23	1.33	0.76	0.38	0.10
	0.6	18.80	13.18	6.67	3.70	2.16	1.26	0.70	0.32	0.06
	0.7	37.42	14.67	6.86	3.68	2.09	1.19	0.63	0.26	0.01
	0.8	57.27	16.30	7.09	3.67	2.03	1.12	0.57	0.21	-0.04
	0.9	77.95	18.02	7.35	3.66	1.97	1.06	0.51	0.15	-0.09
	1.0	99.20	19.80	7.61	3.67	1.92	1.00	0.45	0.10	-0.14

D5-3,  $D_c > 250$  mm, Converging

$A_s/A_c$	$A_b/A_c$	$C_b$ Values								
		$Q_b/Q_c$								
0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	0.1	0.2
0.1	0.1	-13.86	-1.90	0.03	0.61	0.83	0.92	0.96	0.98	0.98
	0.2	-58.25	-10.48	-2.80	-0.51	0.36	0.74	0.90	0.96	0.96
	0.3	-132.23	-24.75	-7.50	-2.36	-0.39	0.45	0.82	0.96	0.96
	0.4	-235.84	-44.74	-14.07	-4.93	-1.43	0.07	0.73	0.98	0.99
	0.5	-369.15	-70.45	-22.51	-8.23	-2.76	-0.42	0.61	1.01	1.05
	0.6	-532.21	-101.89	-32.83	-12.26	-4.38	-1.00	0.48	1.06	1.13
	0.7	-725.06	-139.08	-45.04	-17.02	-6.30	-1.70	0.33	1.13	1.24
	0.8	-947.77	-182.03	-59.15	-22.53	-8.52	-2.50	0.16	1.22	1.38
	0.9	-1200.	-230.76	-75.15	-28.78	-11.03	-3.40	-0.03	1.32	1.55
	1.0	-1483.	-285.27	-93.06	-35.78	-13.84	-4.41	-0.25	1.43	1.75
0.2	0.1	-5.86	-0.35	0.54	0.81	0.91	0.95	0.97	0.97	0.96
	0.2	-26.08	-4.19	-0.70	0.33	0.71	0.87	0.93	0.95	0.93
	0.3	-59.71	-10.53	-2.72	-0.43	0.43	0.78	0.91	0.95	0.91
	0.4	-106.78	-19.39	-5.53	-1.46	0.05	0.67	0.91	0.97	0.91
	0.5	-167.36	-30.77	-9.12	-2.78	-0.42	0.55	0.93	1.02	0.93
	0.6	-241.50	-44.68	-13.50	-4.37	-0.97	0.42	0.96	1.10	0.98
	0.7	-329.25	-61.15	-18.68	-6.25	-1.62	0.27	1.02	1.21	1.06
	0.8	-430.67	-80.18	-24.67	-8.42	-2.37	0.10	1.09	1.35	1.17
	0.9	-545.81	-101.78	-31.47	-10.89	-3.22	-0.08	1.17	1.52	1.31
	1.0	-674.72	-125.98	-39.08	-13.64	-4.17	-0.28	1.28	1.72	1.48
0.3	0.1	-3.26	0.15	0.70	0.86	0.93	0.96	0.97	0.97	0.95
	0.2	-15.50	-2.16	-0.04	0.58	0.81	0.90	0.93	0.94	0.91
	0.3	-35.76	-5.90	-1.20	0.16	0.66	0.85	0.92	0.92	0.88
	0.4	-64.09	-11.09	-2.78	-0.38	0.48	0.82	0.93	0.94	0.86
	0.5	-100.54	-17.73	-4.78	-1.06	0.29	0.80	0.97	0.98	0.87
	0.6	-145.16	-25.85	-7.21	-1.86	0.06	0.80	1.05	1.05	0.90
	0.7	-198.01	-35.46	-10.08	-2.81	-0.19	0.82	1.15	1.16	0.96
	0.8	-259.13	-46.56	-13.39	-3.89	-0.47	0.85	1.28	1.30	1.05
	0.9	-328.59	-59.18	-17.15	-5.11	-0.78	0.89	1.44	1.47	1.17
	1.0	-406.44	-73.33	-21.37	-6.48	-1.12	0.94	1.63	1.68	1.32
0.4	0.1	-1.99	0.38	0.77	0.89	0.94	0.96	0.97	0.97	0.95
	0.2	-10.31	-1.18	0.26	0.69	0.84	0.91	0.93	0.93	0.90
	0.3	-23.96	-3.65	-0.48	0.43	0.75	0.88	0.91	0.91	0.86
	0.4	-42.98	-7.03	-1.46	0.11	0.67	0.87	0.93	0.91	0.84
	0.5	-67.44	-11.35	-2.69	-0.26	0.59	0.90	0.97	0.94	0.84
	0.6	-97.39	-16.60	-4.17	-0.69	0.52	0.95	1.06	1.01	0.87
	0.7	-132.88	-22.81	-5.91	-1.17	0.46	1.03	1.17	1.11	0.92
	0.8	-173.96	-29.99	-7.90	-1.73	0.40	1.15	1.33	1.24	1.00
	0.9	-220.69	-38.15	-10.16	-2.35	0.35	1.29	1.51	1.40	1.11
	1.0	-273.12	-47.31	-12.70	-3.04	0.29	1.45	1.74	1.61	1.26
0.5	0.1	-1.26	0.51	0.81	0.90	0.94	0.96	0.97	0.96	0.95
	0.2	-7.26	-0.62	0.43	0.75	0.86	0.91	0.93	0.93	0.90
	0.3	-16.99	-2.35	-0.07	0.57	0.80	0.89	0.91	0.90	0.87
	0.4	-30.49	-4.67	-0.72	0.38	0.76	0.89	0.92	0.90	0.85
	0.5	-47.82	-7.61	-1.50	0.19	0.75	0.93	0.97	0.93	0.85
	0.6	-69.03	-11.17	-2.42	-0.03	0.76	1.01	1.05	0.98	0.88
	0.7	-94.17	-15.37	-3.49	-0.26	0.80	1.13	1.17	1.07	0.93
	0.8	-123.30	-20.22	-4.71	-0.50	0.87	1.29	1.33	1.20	1.02
	0.9	-156.48	-25.73	-6.09	-0.77	0.96	1.48	1.53	1.36	1.13
	1.0	-193.74	-31.92	-7.63	-1.07	1.06	1.71	1.77	1.56	1.28
0.6	0.1	-0.79	0.59	0.83	0.91	0.95	0.96	0.97	0.97	0.95
	0.2	-5.28	-0.27	0.54	0.78	0.88	0.91	0.93	0.93	0.91
	0.3	-12.43	-1.51	0.18	0.66	0.83	0.89	0.91	0.91	0.89
	0.4	-22.29	-3.15	-0.25	0.55	0.82	0.90	0.92	0.91	0.88
	0.5	-34.92	-5.19	-0.74	0.46	0.84	0.95	0.96	0.93	0.89
	0.6	-50.35	-7.64	-1.30	0.38	0.91	1.05	1.04	0.98	0.93
	0.7	-68.66	-10.52	-1.94	0.32	1.01	1.18	1.16	1.07	0.99
	0.8	-89.89	-13.83	-2.65	0.26	1.15	1.36	1.33	1.19	1.08
	0.9	-114.09	-17.61	-3.46	0.22	1.32	1.59	1.53	1.35	1.21
	1.0	-141.33	-21.84	-4.35	0.18	1.54	1.85	1.77	1.54	1.37

D5-3,  $D_c > 250$  mm, Converging (Continued)

		$C_b$ Values (Continued)								
		$Q_b/Q_c$								
$A_s/A_c$	$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.7	0.1	-0.47	0.65	0.85	0.92	0.95	0.96	0.97	0.97	0.96
	0.2	-3.90	-0.03	0.61	0.81	0.89	0.92	0.94	0.94	0.93
	0.3	-9.25	-0.94	0.35	0.72	0.85	0.90	0.92	0.92	0.92
	0.4	-16.54	-2.10	0.07	0.66	0.85	0.91	0.93	0.92	0.92
	0.5	-25.85	-3.51	-0.22	0.64	0.90	0.97	0.97	0.94	0.95
	0.6	-37.21	-5.18	-0.54	0.65	1.00	1.07	1.05	1.00	1.00
	0.7	-50.68	-7.13	-0.87	0.70	1.14	1.22	1.17	1.08	1.08
	0.8	-66.31	-9.37	-1.24	0.78	1.33	1.41	1.33	1.21	1.20
	0.9	-84.17	-11.92	-1.64	0.89	1.56	1.65	1.53	1.36	1.34
	1.0	-104.29	-14.78	-2.09	1.03	1.84	1.94	1.78	1.56	1.52
0.8	0.1	-0.23	0.69	0.87	0.93	0.95	0.97	0.97	0.98	0.97
	0.2	-2.90	0.15	0.67	0.83	0.90	0.93	0.94	0.95	0.96
	0.3	-6.91	-0.53	0.47	0.76	0.87	0.91	0.93	0.94	0.96
	0.4	-12.31	-1.34	0.30	0.74	0.88	0.93	0.94	0.95	0.98
	0.5	-19.16	-2.29	0.15	0.77	0.94	0.99	0.98	0.98	1.03
	0.6	-27.50	-3.39	0.01	0.84	1.06	1.09	1.06	1.03	1.11
	0.7	-37.38	-4.66	-0.11	0.97	1.23	1.24	1.18	1.12	1.21
	0.8	-48.87	-6.11	-0.22	1.15	1.46	1.45	1.35	1.25	1.35
	0.9	-62.01	-7.75	-0.33	1.37	1.73	1.70	1.55	1.41	1.52
	1.0	-76.85	-9.59	-0.44	1.63	2.06	2.00	1.80	1.61	1.73
0.9	0.1	-0.05	0.72	0.88	0.93	0.96	0.97	0.98	0.99	0.99
	0.2	-2.14	0.28	0.71	0.85	0.91	0.94	0.96	0.97	0.99
	0.3	-5.14	-0.21	0.57	0.80	0.88	0.92	0.95	0.97	1.02
	0.4	-9.09	-0.76	0.47	0.80	0.91	0.94	0.96	0.98	1.06
	0.5	-14.06	-1.36	0.42	0.86	0.98	1.01	1.01	1.02	1.14
	0.6	-20.08	-2.04	0.42	0.99	1.11	1.12	1.09	1.09	1.24
	0.7	-27.21	-2.79	0.47	1.17	1.30	1.27	1.21	1.19	1.38
	0.8	-35.50	-3.63	0.55	1.42	1.55	1.49	1.38	1.32	1.55
	0.9	-45.01	-4.57	0.66	1.72	1.86	1.75	1.59	1.49	1.75
	1.0	-55.79	-5.64	0.80	2.08	2.22	2.06	1.84	1.69	1.99
1.0	0.1	0.09	0.75	0.89	0.94	0.97	0.98	0.99	1.00	1.01
	0.2	-1.54	0.39	0.74	0.87	0.92	0.95	0.97	0.99	1.03
	0.3	-3.75	0.03	0.64	0.83	0.90	0.94	0.97	1.00	1.08
	0.4	-6.57	-0.32	0.61	0.85	0.93	0.97	0.99	1.03	1.16
	0.5	-10.05	-0.65	0.64	0.94	1.02	1.03	1.04	1.08	1.26
	0.6	-14.24	-0.98	0.74	1.10	1.16	1.15	1.13	1.16	1.40
	0.7	-19.20	-1.32	0.91	1.33	1.37	1.31	1.26	1.27	1.57
	0.8	-24.98	-1.69	1.14	1.63	1.63	1.53	1.43	1.41	1.78
	0.9	-31.62	-2.10	1.42	2.00	1.96	1.80	1.64	1.59	2.02
	1.0	-39.19	-2.55	1.76	2.43	2.35	2.12	1.90	1.81	2.30
		$C_s$ Values								
		$Q_b/Q_c$								
$A_s/A_c$	$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	7.87	1.70	1.07	0.92	0.86	0.84	0.82	0.82	0.81
	0.2	4.21	1.30	0.97	0.88	0.85	0.83	0.82	0.81	0.81
	0.3	3.02	1.16	0.93	0.87	0.84	0.83	0.82	0.81	0.81
	0.4	2.45	1.10	0.92	0.86	0.84	0.83	0.82	0.81	0.81
	0.5	2.13	1.07	0.91	0.86	0.84	0.82	0.82	0.81	0.81
	0.6	1.93	1.04	0.90	0.86	0.84	0.82	0.82	0.81	0.81
	0.7	1.80	1.03	0.90	0.85	0.83	0.82	0.82	0.81	0.81
	0.8	1.72	1.02	0.90	0.85	0.83	0.82	0.82	0.81	0.81
	0.9	1.67	1.01	0.89	0.85	0.83	0.82	0.82	0.81	0.81
	1.0	1.63	1.01	0.89	0.85	0.83	0.82	0.82	0.81	0.81
0.2	0.1	44.93	6.00	2.16	1.24	0.92	0.78	0.71	0.67	0.65
	0.2	20.43	3.28	1.45	0.98	0.81	0.73	0.69	0.66	0.64
	0.3	12.53	2.40	1.22	0.90	0.77	0.71	0.68	0.66	0.64
	0.4	8.78	1.98	1.12	0.86	0.76	0.70	0.67	0.66	0.64
	0.5	6.69	1.75	1.06	0.84	0.75	0.70	0.67	0.65	0.64
	0.6	5.43	1.61	1.02	0.83	0.74	0.70	0.67	0.65	0.64
	0.7	4.64	1.52	1.00	0.82	0.74	0.70	0.67	0.65	0.64
	0.8	4.15	1.47	0.98	0.81	0.74	0.69	0.67	0.65	0.64
	0.9	3.86	1.43	0.97	0.81	0.74	0.69	0.67	0.65	0.64
	1.0	3.71	1.42	0.97	0.81	0.73	0.69	0.67	0.65	0.64

D5-3,  $D_c > 250$  mm, Converging (Continued)


$A_s/A_c$	$A_b/A_c$	$C_s$ Values (Continued)								
		$Q_b/Q_c$								
0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9		
0.3	0.1	118.96	14.64	4.45	2.03	1.20	0.84	0.66	0.57	0.51
	0.2	51.24	7.11	2.49	1.33	0.90	0.70	0.60	0.54	0.50
	0.3	29.57	4.70	1.87	1.10	0.80	0.66	0.58	0.53	0.50
	0.4	19.40	3.57	1.58	1.00	0.76	0.64	0.57	0.52	0.50
	0.5	13.84	2.96	1.42	0.94	0.73	0.62	0.56	0.52	0.50
	0.6	10.58	2.59	1.32	0.90	0.72	0.62	0.56	0.52	0.49
	0.7	8.64	2.38	1.27	0.88	0.71	0.61	0.56	0.52	0.49
	0.8	7.52	2.25	1.23	0.87	0.70	0.61	0.56	0.52	0.49
	0.9	6.95	2.19	1.22	0.87	0.70	0.61	0.56	0.52	0.49
	1.0	6.76	2.17	1.21	0.86	0.70	0.61	0.55	0.52	0.49
0.4	0.1	218.57	26.35	7.61	3.18	1.65	1.00	0.68	0.50	0.40
	0.2	90.30	12.10	3.91	1.85	1.08	0.74	0.55	0.45	0.38
	0.3	49.68	7.59	2.74	1.42	0.90	0.65	0.51	0.43	0.37
	0.4	30.96	5.51	2.21	1.23	0.82	0.61	0.49	0.42	0.37
	0.5	21.00	4.40	1.92	1.13	0.78	0.59	0.48	0.42	0.37
	0.6	15.43	3.78	1.76	1.07	0.75	0.58	0.48	0.41	0.37
	0.7	12.36	3.44	1.67	1.04	0.74	0.57	0.48	0.41	0.37
	0.8	10.86	3.27	1.63	1.02	0.73	0.57	0.47	0.41	0.37
	0.9	10.40	3.22	1.61	1.01	0.73	0.57	0.47	0.41	0.37
	1.0	10.67	3.25	1.62	1.02	0.73	0.57	0.47	0.41	0.37
0.5	0.1	320.10	38.52	10.97	4.44	2.18	1.21	0.72	0.46	0.31
	0.2	126.36	16.99	5.39	2.42	1.32	0.81	0.54	0.38	0.28
	0.3	65.94	10.28	3.65	1.79	1.05	0.68	0.48	0.35	0.27
	0.4	38.84	7.27	2.87	1.51	0.93	0.63	0.45	0.34	0.27
	0.5	25.07	5.74	2.47	1.37	0.87	0.60	0.44	0.33	0.26
	0.6	17.98	4.95	2.27	1.29	0.84	0.58	0.43	0.33	0.26
	0.7	14.69	4.58	2.17	1.26	0.82	0.58	0.43	0.33	0.26
	0.8	13.78	4.48	2.15	1.25	0.82	0.57	0.43	0.33	0.26
	0.9	14.45	4.56	2.17	1.26	0.82	0.58	0.43	0.33	0.26
	1.0	16.24	4.76	2.22	1.28	0.83	0.58	0.43	0.33	0.26
0.6	0.1	393.66	47.81	13.66	5.50	2.64	1.40	0.78	0.44	0.23
	0.2	146.22	20.32	6.54	2.92	1.54	0.89	0.54	0.33	0.20
	0.3	70.93	11.95	4.37	2.13	1.20	0.73	0.46	0.30	0.18
	0.4	38.66	8.37	3.44	1.80	1.06	0.67	0.43	0.28	0.18
	0.5	23.61	6.70	3.00	1.64	0.99	0.64	0.42	0.28	0.18
	0.6	17.17	5.98	2.82	1.57	0.97	0.62	0.41	0.27	0.18
	0.7	15.64	5.81	2.77	1.56	0.96	0.62	0.41	0.27	0.18
	0.8	17.19	5.98	2.82	1.57	0.97	0.62	0.41	0.27	0.18
	0.9	20.79	6.38	2.92	1.61	0.98	0.63	0.42	0.27	0.18
	1.0	25.82	6.94	3.07	1.66	1.00	0.64	0.42	0.28	0.18
0.7	0.1	409.10	50.88	14.82	6.03	2.90	1.51	0.81	0.41	0.17
	0.2	137.78	20.74	7.01	3.21	1.70	0.96	0.54	0.29	0.13
	0.3	58.74	11.96	4.73	2.39	1.34	0.79	0.47	0.26	0.12
	0.4	27.78	8.52	3.84	2.06	1.21	0.73	0.44	0.24	0.11
	0.5	16.04	7.21	3.50	1.94	1.15	0.71	0.43	0.24	0.11
	0.6	13.91	6.97	3.44	1.92	1.14	0.70	0.42	0.24	0.11
	0.7	17.28	7.35	3.54	1.95	1.16	0.71	0.43	0.24	0.11
	0.8	24.08	8.10	3.73	2.02	1.19	0.72	0.43	0.24	0.11
	0.9	33.17	9.11	3.99	2.12	1.23	0.74	0.44	0.25	0.11
	1.0	43.86	10.30	4.30	2.23	1.28	0.76	0.45	0.25	0.11
0.8	0.1	341.98	45.02	13.75	5.80	2.86	1.50	0.79	0.38	0.12
	0.2	92.97	17.35	6.57	3.21	1.75	0.99	0.55	0.27	0.08
	0.3	26.98	10.02	4.67	2.52	1.46	0.86	0.48	0.24	0.07
	0.4	6.75	7.77	4.09	2.31	1.37	0.81	0.46	0.23	0.06
	0.5	4.83	7.56	4.03	2.29	1.36	0.81	0.46	0.23	0.06
	0.6	12.05	8.36	4.24	2.37	1.39	0.83	0.47	0.23	0.07
	0.7	24.51	9.75	4.60	2.49	1.45	0.85	0.48	0.24	0.07
	0.8	40.23	11.49	5.05	2.66	1.52	0.88	0.50	0.24	0.07
	0.9	58.13	13.48	5.57	2.85	1.60	0.92	0.51	0.25	0.07
	1.0	77.56	15.64	6.13	3.05	1.68	0.96	0.53	0.26	0.08

D5-3,  $D_c > 250$  mm, Converging (Continued)

$A_s/A_c$	$A_b/A_c$	$C_s$ Values (Concluded)								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.9	0.1	179.59	28.81	10.06	4.66	2.45	1.34	0.71	0.32	0.07
	0.2	10.77	10.05	5.20	2.91	1.70	0.99	0.55	0.25	0.04
	0.3	-21.27	6.49	4.28	2.57	1.56	0.93	0.52	0.24	0.04
	0.4	-19.11	6.73	4.34	2.60	1.57	0.93	0.52	0.24	0.04
	0.5	-3.28	8.49	4.80	2.76	1.64	0.97	0.54	0.24	0.04
	0.6	19.39	11.01	5.45	3.00	1.74	1.01	0.56	0.25	0.04
	0.7	45.97	13.96	6.21	3.27	1.86	1.07	0.58	0.27	0.05
	0.8	74.99	17.18	7.05	3.58	1.98	1.13	0.61	0.28	0.05
	0.9	105.64	20.59	7.93	3.89	2.12	1.19	0.64	0.29	0.06
	1.0	137.43	24.12	8.85	4.23	2.26	1.26	0.67	0.31	0.06
1.0	0.1	-73.14	2.79	3.92	2.68	1.70	1.04	0.58	0.26	0.03
	0.2	-99.78	-0.17	3.15	2.40	1.58	0.98	0.56	0.25	0.02
	0.3	-75.42	2.54	3.85	2.65	1.69	1.03	0.58	0.26	0.03
	0.4	-38.31	6.66	4.92	3.04	1.86	1.11	0.62	0.28	0.03
	0.5	3.90	11.35	6.14	3.48	2.04	1.20	0.66	0.29	0.04
	0.6	48.66	16.32	7.43	3.94	2.24	1.29	0.70	0.31	0.04
	0.7	94.88	21.46	8.76	4.43	2.45	1.38	0.75	0.33	0.05
	0.8	142.01	26.70	10.12	4.92	2.66	1.48	0.79	0.35	0.06
	0.9	189.74	32.00	11.49	5.41	2.87	1.58	0.84	0.37	0.07
	1.0	237.90	37.35	12.88	5.92	3.08	1.68	0.88	0.39	0.07

ED5-6 Capped Wye, Branch with 45-Degree Elbow,  
Branch 90 Degrees to Main, Converging,  $r/D_b = 1.5$ 

$A_b/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
$C_b$	1.02	0.97	0.93	0.88	0.84	0.79	0.75	0.70	0.66	0.61

ED5-9 Symmetrical Wye, 60 Degree,  $D_{b1} \geq D_{b2}$ , Converging

$A_{b1}/A_c$	$A_{b2}/A_c$	$C_{b1}$ Values								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-3.00	-0.50	-0.11	0.06	0.12	0.14	0.14	0.13	0.11
	0.2	-16.00	-3.00	-1.01	0.01	0.32	0.44	0.49	0.56	0.49
0.3	0.1	-54.00	-11.25	-3.57	-0.43	-0.22	0.38	0.55	1.41	1.22
	0.2	-45.45	-9.39	-2.44	-0.41	0.33	0.68	0.89	1.03	1.13
0.3	0.3	-16.88	-2.92	-0.09	0.59	0.85	1.02	1.12	1.12	1.22
	0.4	-97.28	-18.48	-6.35	-1.58	-0.57	-0.15	0.23	0.35	0.50
0.4	0.2	-72.04	-14.00	-4.26	-1.24	-0.32	0.09	0.40	0.50	0.62
	0.3	-52.95	-9.91	-2.86	-0.91	-0.06	0.32	0.56	0.64	0.73
0.4	0.4	-40.00	-6.22	-2.15	-0.57	0.19	0.56	0.72	0.79	0.85
	0.5	-167.71	-32.20	-10.05	-2.52	-1.25	-0.26	0.17	0.34	0.36
0.5	0.2	-126.04	-23.80	-7.44	-2.64	-0.85	-0.13	0.16	0.26	0.28
	0.3	-91.07	-16.91	-5.16	-1.73	-0.46	0.04	0.23	0.29	0.28
0.4	0.4	-56.41	-10.07	-2.90	-0.82	-0.07	0.21	0.30	0.31	0.29
	0.5	-30.58	-5.23	-1.06	0.00	0.32	0.43	0.47	0.47	0.41

ED5-9 Symmetrical Wye, 60 Degree,  $D_{b1} \geq D_{b2}$ , Converging (Continued)


		$C_{b1}$ Values (Concluded)								
		$Q_{b1}/Q_c$								
$A_{b1}/A_c$	$A_{b2}/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.6	0.1	-299.02	-55.99	-16.77	-5.89	-2.09	-0.54	0.11	0.25	0.23
	0.2	-209.81	-39.31	-12.13	-4.35	-1.54	-0.40	0.06	0.25	0.23
	0.3	-147.43	-27.69	-8.75	-3.20	-1.13	-0.29	0.07	0.23	0.22
	0.4	-85.06	-16.07	-5.38	-2.04	-0.71	-0.17	0.08	0.23	0.22
	0.5	-58.22	-11.03	-3.84	-1.49	-0.50	-0.09	0.11	0.23	0.22
	0.6	-40.57	-7.86	-2.60	-0.99	-0.32	0.00	0.14	0.23	0.22
0.7	0.1	-420.02	-77.23	-23.37	-8.01	-3.30	-1.46	-0.71	-0.10	0.03
	0.2	-285.70	-53.45	-16.65	-6.05	-2.52	-1.02	-0.46	-0.02	0.06
	0.3	-195.01	-37.35	-12.21	-4.72	-1.87	-0.77	-0.14	0.04	0.09
	0.4	-104.16	-21.18	-7.20	-3.23	-1.37	-0.39	-0.10	0.08	0.12
	0.5	-67.21	-13.02	-4.52	-1.78	-0.73	-0.26	-0.03	0.12	0.15
	0.6	-49.01	-9.63	-3.13	-1.28	-0.51	-0.14	-0.02	0.16	0.17
	0.7	-59.33	-10.05	-2.53	-0.54	-0.21	-0.09	-0.01	0.23	0.24
0.8	0.1	-518.26	-95.93	-30.34	-11.09	-4.30	-2.51	-1.58	-0.63	-0.31
	0.2	-373.33	-69.73	-21.93	-8.08	-3.84	-1.96	-1.31	-0.50	-0.24
	0.3	-247.31	-48.35	-16.32	-6.65	-2.89	-1.51	-0.49	-0.30	-0.16
	0.4	-120.88	-26.76	-9.24	-4.80	-2.30	-0.71	-0.39	-0.20	-0.08
	0.5	-72.08	-14.20	-4.98	-2.00	-1.02	-0.53	-0.26	-0.10	0.01
	0.6	-55.91	-11.20	-3.56	-1.60	-0.77	-0.36	-0.13	0.01	0.05
	0.7	-35.96	-7.20	-2.31	-1.08	-0.45	-0.09	0.03	0.11	0.13
	0.8	-16.00	-3.20	-1.07	-0.56	-0.13	0.18	0.20	0.20	0.21
0.9	0.1	-629.39	-114.67	-35.12	-13.73	-6.55	-3.65	-2.25	-1.20	-0.70
	0.2	-473.23	-88.43	-27.99	-11.44	-5.67	-3.21	-2.07	-1.11	-0.65
	0.3	-303.64	-60.65	-21.13	-9.65	-4.91	-2.87	-1.51	-0.95	-0.58
	0.4	-216.44	-44.78	-16.20	-8.35	-4.46	-2.31	-1.43	-0.87	-0.52
	0.5	-116.49	-28.35	-12.15	-6.45	-3.65	-2.19	-1.35	-0.81	-0.47
	0.6	-98.16	-25.31	-10.76	-5.82	-3.48	-2.16	-1.35	-0.81	-0.49
	0.7	-78.15	-21.31	-9.54	-5.37	-3.28	-1.99	-1.25	-0.75	-0.44
	0.8	-58.15	-17.32	-8.33	-4.93	-3.08	-1.82	-1.15	-0.69	-0.39
	0.9	-72.90	-18.23	-8.10	-4.56	-2.92	-1.92	-1.29	-0.66	-0.39
1.0	0.1	-677.01	-124.30	-37.45	-16.24	-8.10	-4.89	-3.06	-1.95	-1.23
	0.2	-585.16	-109.39	-34.85	-15.63	-8.00	-4.86	-3.06	-1.95	-1.23
	0.3	-363.31	-74.20	-26.68	-13.44	-7.60	-4.72	-2.96	-1.88	-1.17
	0.4	-345.54	-68.75	-25.56	-13.13	-7.40	-4.58	-2.92	-1.84	-1.16
	0.5	-175.00	-47.50	-22.22	-12.81	-7.40	-4.58	-2.92	-1.84	-1.16
	0.6	-155.00	-45.00	-21.00	-11.88	-7.40	-4.77	-3.13	-2.02	-1.28
	0.7	-136.79	-41.38	-19.95	-11.58	-7.40	-4.77	-3.13	-2.02	-1.28
	0.8	-118.58	-37.76	-18.91	-11.29	-7.40	-4.77	-3.13	-2.02	-1.28
	0.9	-100.29	-34.13	-17.90	-10.99	-7.39	-4.77	-3.13	-2.02	-1.28
	1.0	-82.00	-30.50	-16.89	-10.69	-7.39	-4.77	-3.13	-2.02	-1.28
		$C_{b1}$ Values								
		$Q_{b2}/Q_c$								
$A_{b1}/A_c$	$A_{b2}/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.1	-3.00	-0.50	-0.11	0.06	0.12	0.14	0.14	0.13	0.11
	0.2	-2.70	-0.04	0.23	0.15	0.16	0.18	0.20	0.17	0.16
0.2	0.1	-11.95	-1.89	-0.09	0.41	0.62	0.74	0.80	0.80	0.79
	0.2	-2.00	-0.30	0.22	0.42	0.61	0.73	0.78	0.77	0.76
	0.3	-16.88	-2.92	-0.09	0.59	0.85	1.02	1.12	1.12	1.22
0.3	0.1	-2.12	0.12	0.33	0.22	0.22	0.23	0.26	0.22	0.22
	0.2	-2.00	-0.30	0.22	0.42	0.61	0.73	0.78	0.77	0.76
	0.3	-16.88	-2.92	-0.09	0.59	0.85	1.02	1.12	1.12	1.22
	0.4	-2.38	-0.17	0.13	0.23	0.25	0.24	0.23	0.24	0.24
0.4	0.1	-6.95	-1.00	0.16	0.53	0.67	0.71	0.72	0.72	0.71
	0.2	-16.21	-2.90	-0.44	0.40	0.79	0.98	1.05	1.06	1.05
	0.3	-40.00	-6.22	-2.15	-0.57	0.19	0.56	0.72	0.79	0.85
	0.4	-1.58	0.11	0.33	0.31	0.32	0.33	0.34	0.32	0.32
0.5	0.1	-4.82	-0.01	0.56	0.71	0.82	0.89	0.92	0.90	0.89
	0.2	-12.27	-1.17	0.44	0.88	1.11	1.25	1.29	1.25	1.23
	0.3	-22.40	-2.93	-0.21	0.48	0.73	0.84	0.88	0.87	0.82
	0.4	-30.58	-5.23	-1.06	0.00	0.32	0.43	0.47	0.46	0.41
	0.5	-12.27	-1.17	0.44	0.88	1.11	1.25	1.29	1.25	1.23

ED5-9 Symmetrical Wye, 60 Degree,  $D_{b1} \geq D_{b2}$ , Converging (Continued)

$A_{b1}/A_c$	$A_{b2}/A_c$	$C_{b1}$ Values (Concluded)								
		$Q_{b2}/Q_c$								
0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9		
0.6	0.1	-0.78	0.11	0.32	0.40	0.42	0.43	0.43	0.42	0.42
	0.2	-3.68	0.07	0.77	0.98	1.06	1.08	1.08	1.06	1.04
	0.3	-9.06	-0.55	0.86	1.27	1.42	1.48	1.49	1.46	1.42
	0.4	-17.62	-2.12	0.06	0.60	0.83	0.95	0.98	0.95	0.91
	0.5	-28.00	-4.26	-0.99	-0.16	0.20	0.39	0.45	0.41	0.38
	0.6	-40.57	-7.86	-2.60	-0.99	-0.32	0.00	0.14	0.23	0.22
0.7	0.1	-0.12	0.17	0.22	0.34	0.39	0.40	0.40	0.39	0.39
	0.2	-1.24	0.33	0.55	0.86	0.98	1.02	1.04	1.03	1.02
	0.3	-4.03	0.06	0.73	1.20	1.39	1.47	1.49	1.47	1.44
	0.4	-9.77	-0.84	0.30	0.36	0.71	0.89	0.97	0.98	0.97
	0.5	-15.88	-2.51	-0.34	-0.06	0.21	0.51	0.65	0.68	0.70
	0.6	-23.89	-4.60	-1.54	-0.55	-0.51	-0.04	0.21	0.37	0.44
	0.7	-59.33	-10.05	-2.53	-0.54	-0.21	-0.09	-0.01	0.23	0.24
0.8	0.1	0.53	0.24	0.12	0.29	0.36	0.37	0.37	0.36	0.35
	0.2	1.20	0.60	0.33	0.73	0.90	0.97	1.00	1.00	0.99
	0.3	0.99	0.68	0.60	1.13	1.36	1.45	1.49	1.48	1.46
	0.4	-1.92	0.44	0.53	0.11	0.59	0.83	0.96	1.01	1.03
	0.5	-3.75	-0.75	0.31	0.05	0.22	0.62	0.84	0.96	1.03
	0.6	-7.20	-1.35	-0.48	-0.11	-0.70	-0.09	0.28	0.51	0.65
	0.7	-11.03	-2.14	-0.74	-0.29	-2.11	0.01	0.26	0.42	0.52
	0.8	-16.00	-3.20	-1.07	-0.56	-0.13	0.18	0.20	0.20	0.21
	0.9	-0.13	0.32	0.23	0.32	0.36	0.36	0.36	0.35	0.34
0.9	0.2	-0.98	0.80	0.61	0.85	0.97	1.03	1.04	1.03	1.01
	0.3	-3.06	0.35	0.55	1.06	1.32	1.44	1.49	1.49	1.48
	0.4	-7.36	-2.06	-1.01	-0.12	0.47	0.78	0.95	1.04	1.09
	0.5	-11.88	-4.00	-1.88	-0.98	-0.30	0.24	0.56	0.75	0.87
	0.6	-18.18	-5.99	-3.20	-1.67	-1.08	-0.30	0.18	0.49	0.70
	0.7	-25.36	-8.36	-4.42	-2.45	-2.82	-0.55	-0.01	0.34	0.56
	0.8	-33.92	-11.20	-5.87	-3.43	-1.94	-0.90	-0.35	0.00	0.24
	0.9	-72.90	-18.23	-8.10	-4.56	-2.92	-1.92	-1.29	-0.66	-0.39
	1.0	-0.78	0.40	0.33	0.35	0.36	0.36	0.35	0.34	0.33
	0.2	-3.16	1.00	0.89	0.96	1.05	1.08	1.08	1.06	1.04
1.0	0.3	-7.11	0.02	0.50	0.99	1.29	1.43	1.49	1.50	1.50
	0.4	-12.80	-4.56	-2.56	-0.36	0.35	0.72	0.93	1.07	1.15
	0.5	-20.00	-7.25	-4.06	-2.02	-0.81	-0.14	0.27	0.54	0.72
	0.6	-29.16	-10.62	-5.92	-3.24	-1.47	-0.50	0.09	0.48	0.74
	0.7	-39.69	-14.58	-8.11	-4.61	-3.53	-1.10	-0.28	0.25	0.60
	0.8	-51.84	-19.20	-10.67	-6.30	-3.75	-1.97	-0.89	-0.20	0.27
	0.9	-66.02	-24.50	-13.59	-8.31	-5.93	-3.18	-1.83	-0.95	-0.35
	1.0	-82.00	-30.50	-16.89	-10.69	-7.39	-4.77	-3.13	-2.02	-1.28


## ED7-1 Centrifugal Fan Located in Plenum or Cabinet

$L/D_o$	0.30	0.40	0.50	0.75
$C_o$	0.80	0.53	0.40	0.22




**ED7-2 Fan Inlet, Centrifugal, SWSI, with 4 Gore Elbow**


$r/D_o$	$C_o$ Values			
	0.0	2.0	5.0	10.0
0.50	1.80	1.00	0.53	0.53
0.75	1.40	0.80	0.40	0.40
1.00	1.20	0.67	0.33	0.33
1.50	1.10	0.60	0.33	0.33
2.00	1.00	0.53	0.33	0.33
3.00	0.67	0.40	0.22	0.22

**SD1-1 Bellmouth, Plenum to Round, Supply Air Systems**


$r/D_o$	0.0	0.01	0.02	0.03	0.04	0.05	0.06	0.08	0.10	0.12	0.16	0.20	10.0
$C_o$	0.50	0.44	0.37	0.31	0.26	0.22	0.20	0.15	0.12	0.09	0.06	0.03	0.03

**SD1-2 Conical Bellmouth/Sudden Contraction, Plenum to Round, Supply Air Systems**

$L/D_o$	$C_o$ Values								
	0	10	20	30	45	60	100	140	180
0.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
0.025	0.50	0.47	0.45	0.43	0.41	0.40	0.42	0.45	0.50
0.05	0.50	0.45	0.41	0.36	0.33	0.30	0.35	0.42	0.50
0.075	0.50	0.42	0.35	0.30	0.26	0.23	0.30	0.40	0.50
0.10	0.50	0.39	0.32	0.25	0.22	0.18	0.27	0.38	0.50
0.15	0.50	0.37	0.27	0.20	0.16	0.15	0.25	0.37	0.50
0.60	0.50	0.27	0.18	0.13	0.11	0.12	0.23	0.36	0.50


**SD2-6 and SD2-7 Stackheads**

$D_e/D$	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
$C_o$	130.	41.02	16.80	8.10	4.37	2.56	1.60	1.00




SD2-7

SD2-6

**SD4-1 Transition, Round to Round, Supply Air Systems** **$C_o$  Values**

$A_o/A_1$	$\theta$												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.10	0.0	0.12	0.09	0.05	0.05	0.05	0.05	0.06	0.08	0.19	0.29	0.37	0.43
0.167	0.0	0.11	0.08	0.05	0.04	0.04	0.04	0.06	0.07	0.18	0.28	0.36	0.42
0.25	0.0	0.10	0.07	0.05	0.04	0.04	0.04	0.06	0.07	0.17	0.27	0.35	0.41
0.39	0.0	0.10	0.07	0.05	0.05	0.05	0.05	0.06	0.06	0.16	0.25	0.32	0.36
0.50	0.0	0.07	0.06	0.05	0.05	0.05	0.05	0.06	0.07	0.13	0.18	0.23	0.24
0.64	0.0	0.07	0.07	0.05	0.04	0.04	0.04	0.05	0.06	0.09	0.13	0.17	0.19
1.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.0	0.0	0.59	0.51	0.43	0.52	0.76	1.26	1.32	1.30	1.26	1.23	1.21	1.19
4.0	0.0	3.15	2.78	2.51	3.38	4.77	7.38	9.70	10.88	10.29	10.08	9.96	9.84
6.0	0.0	6.55	6.08	6.44	9.14	11.92	17.35	23.58	27.58	26.71	26.32	26.15	25.99
10.0	0.0	19.50	18.25	20.00	27.30	38.00	58.50	76.00	80.00	83.40	84.00	83.35	82.70
16.0	0.0	45.82	44.80	50.18	73.73	96.77	153.60	215.04	225.28	225.28	225.28	225.28	225.28

**SD4-2 Transition, Rectangular to Round, Supply Air Systems** **$C_o$  Values**


$A_o/A_1$	$\theta$												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.10	0.0	0.12	0.09	0.05	0.05	0.05	0.05	0.06	0.08	0.19	0.29	0.37	0.43
0.167	0.0	0.11	0.08	0.05	0.05	0.05	0.05	0.06	0.07	0.19	0.28	0.37	0.42
0.25	0.0	0.10	0.07	0.05	0.05	0.05	0.05	0.06	0.07	0.17	0.27	0.35	0.41
0.50	0.0	0.08	0.07	0.06	0.07	0.06	0.05	0.06	0.07	0.13	0.19	0.23	0.24
1.0	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.0	0.0	0.57	0.55	0.61	0.87	1.00	1.20	1.30	1.30	1.30	1.28	1.24	1.20
4.0	0.0	2.60	2.84	3.92	5.72	7.20	8.32	9.28	9.92	10.24	10.24	10.24	10.24
6.0	0.0	6.57	6.75	10.62	15.84	18.90	22.50	25.74	27.90	28.44	28.44	28.35	28.26
10.0	0.0	17.25	18.75	30.00	45.00	53.00	63.50	75.00	84.00	89.00	89.00	88.50	88.00
16.0	0.0	42.75	48.13	77.57	116.74	136.45	164.10	196.86	224.26	241.92	241.92	240.38	238.59

**SD5-1 Wye, 45 Degree, Diverging**

$A_b/A_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.38	0.38	0.48	0.45	0.40	0.36	0.32	0.29	0.26
0.2	2.25	0.38	0.31	0.38	0.47	0.48	0.47	0.45	0.42
0.3	6.29	1.02	0.38	0.30	0.33	0.38	0.45	0.48	0.48
0.4	12.41	2.25	0.74	0.38	0.30	0.31	0.35	0.38	0.44
0.5	20.58	4.01	1.37	0.62	0.38	0.30	0.30	0.32	0.36
0.6	30.78	6.29	2.25	1.02	0.56	0.38	0.31	0.30	0.31
0.7	43.02	9.10	3.36	1.57	0.85	0.52	0.38	0.31	0.30
0.8	57.29	12.41	4.71	2.25	1.22	0.74	0.50	0.38	0.32
0.9	73.59	16.24	6.29	3.06	1.69	1.02	0.67	0.48	0.38
1.0	91.92	20.58	8.11	4.01	2.25	1.37	0.90	0.62	0.47


$A_s/A_c$	$C_s$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.13	0.24	0.57	0.74	0.74	0.70	0.65	0.60	0.56
0.2	0.20	0.13	0.15	0.16	0.28	0.57	0.69	0.74	0.75
0.3	0.90	0.14	0.13	0.14	0.15	0.16	0.20	0.42	0.57
0.4	2.88	0.20	0.14	0.13	0.14	0.15	0.15	0.16	0.34
0.5	6.25	0.38	0.17	0.14	0.13	0.14	0.14	0.15	0.15
0.6	11.88	0.90	0.20	0.14	0.14	0.13	0.14	0.14	0.15
0.7	18.62	1.72	0.33	0.18	0.16	0.14	0.13	0.15	0.14
0.8	26.88	2.88	0.50	0.20	0.15	0.14	0.13	0.13	0.14
0.9	36.45	4.46	0.90	0.30	0.19	0.16	0.15	0.14	0.13
1.0	45.00	6.25	1.44	0.38	0.20	0.17	0.12	0.13	0.14

**SD5-9 Tee, Diverging**

$A_b/A_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	1.20	0.62	0.80	1.28	1.99	2.92	4.07	5.44	7.02
0.2	4.10	1.20	0.72	0.62	0.66	0.80	1.01	1.28	1.60
0.3	8.99	2.40	1.20	0.81	0.66	0.62	0.64	0.70	0.80
0.4	15.89	4.10	1.94	1.20	0.88	0.72	0.64	0.62	0.63
0.5	24.80	6.29	2.91	1.74	1.20	0.92	0.77	0.68	0.63
0.6	35.73	8.99	4.10	2.40	1.62	1.20	0.96	0.81	0.72
0.7	48.67	12.19	5.51	3.19	2.12	1.55	1.20	0.99	0.85
0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.49	1.20	1.01
0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.46	1.20
1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.43


  

$A_s/A_c$	$C_s$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.13	0.24	0.57	0.74	0.74	0.70	0.65	0.60	0.56
0.2	0.20	0.13	0.15	0.16	0.28	0.57	0.69	0.74	0.75
0.3	0.90	0.14	0.13	0.14	0.15	0.16	0.20	0.42	0.57
0.4	2.88	0.20	0.14	0.13	0.14	0.15	0.15	0.16	0.34
0.5	6.25	0.38	0.17	0.14	0.13	0.14	0.14	0.15	0.15
0.6	11.88	0.90	0.20	0.14	0.14	0.13	0.14	0.14	0.15
0.7	18.62	1.72	0.33	0.18	0.16	0.14	0.13	0.15	0.14
0.8	26.88	2.88	0.50	0.20	0.15	0.14	0.13	0.13	0.14
0.9	36.45	4.46	0.90	0.30	0.19	0.16	0.15	0.14	0.13
1.0	45.00	6.25	1.44	0.38	0.20	0.17	0.12	0.13	0.14



**SD5-10 Tee, Conical Branch Tapered into Body, Diverging**


$A_b/A_c$	$C_b$ Values								
	$Q_b/Q_c$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.65	0.24	0.15	0.11	0.09	0.07	0.06	0.05	0.05
0.2	2.98	0.65	0.33	0.24	0.18	0.15	0.13	0.11	0.10
0.3	7.36	1.56	0.65	0.39	0.29	0.24	0.20	0.17	0.15
0.4	13.78	2.98	1.20	0.65	0.43	0.33	0.27	0.24	0.21
0.5	22.24	4.92	1.98	1.04	0.65	0.47	0.36	0.31	0.27
0.6	32.73	7.36	2.98	1.56	0.96	0.65	0.49	0.39	0.33
0.7	45.26	10.32	4.21	2.21	1.34	0.90	0.65	0.51	0.42
0.8	59.82	13.78	5.67	2.98	1.80	1.20	0.86	0.65	0.52
0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.11	0.83	0.65
1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.04	0.81



$A_s/A_c$	$C_s$ Values								
	$Q_s/Q_c$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.13	0.24	0.57	0.74	0.74	0.70	0.65	0.60	0.56
0.2	0.20	0.13	0.15	0.16	0.28	0.57	0.69	0.74	0.75
0.3	0.90	0.14	0.13	0.14	0.15	0.16	0.20	0.42	0.57
0.4	2.88	0.20	0.14	0.13	0.14	0.15	0.15	0.16	0.34
0.5	6.25	0.38	0.17	0.14	0.13	0.14	0.14	0.15	0.15
0.6	11.88	0.90	0.20	0.14	0.14	0.13	0.14	0.14	0.15
0.7	18.62	1.72	0.33	0.18	0.16	0.14	0.13	0.15	0.14
0.8	26.88	2.88	0.50	0.20	0.15	0.14	0.13	0.13	0.14
0.9	36.45	4.46	0.90	0.30	0.19	0.16	0.15	0.14	0.13
1.0	45.00	6.25	1.44	0.38	0.20	0.17	0.12	0.13	0.14

**SD5-24 Cross, Diverging**

$A_s/A_c$	$A_{b1}/A_c$	$C_{b1}$ Values								
		$Q_{b1}/Q_c$								
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.20	0.1	2.07	2.08	1.62	1.30	1.99	2.92	4.07	5.44	7.02
	0.2	4.10	2.07	2.31	2.08	1.83	1.62	1.44	1.30	1.60
	0.3	8.99	2.40	2.07	2.34	2.24	2.08	1.91	1.76	1.62
	0.4	15.89	4.10	1.94	2.07	2.32	2.31	2.21	2.08	1.95
	0.5	24.80	6.29	2.91	1.74	2.07	2.30	2.33	2.27	2.18
	0.6	35.73	8.99	4.10	2.40	1.62	2.07	2.29	2.34	2.31
	0.7	48.67	12.19	5.51	3.19	2.12	1.60	2.07	2.27	2.33
	0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.68	2.07	2.25
	0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.74	2.07
	1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.78
0.35	0.1	1.20	3.25	3.11	2.69	2.32	2.92	4.07	5.44	7.02
	0.2	4.10	1.20	2.44	3.25	3.28	3.11	2.90	2.69	2.49
	0.3	8.99	2.40	1.20	1.69	2.88	3.25	3.31	3.23	3.11
	0.4	15.89	4.10	1.94	1.20	1.12	2.44	3.02	3.25	3.31
	0.5	24.80	6.29	2.91	1.74	1.20	0.92	2.04	2.73	3.09
	0.6	35.73	8.99	4.10	2.40	1.62	1.20	0.96	1.69	2.44
	0.7	48.67	12.19	5.51	3.19	2.12	1.55	1.20	0.99	1.38
	0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.49	1.20	1.01
	0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.46	1.20
	1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.43
0.55	0.1	1.20	0.62	0.80	1.28	1.99	2.92	4.07	5.44	7.02
	0.2	4.10	1.20	0.72	0.62	0.66	0.80	1.01	1.28	1.60
	0.3	8.99	2.40	1.20	0.81	0.66	0.62	0.64	0.70	0.80
	0.4	15.89	4.10	1.94	1.20	0.88	0.72	0.64	0.62	0.63
	0.5	24.80	6.29	2.91	1.74	1.20	0.92	0.77	0.68	0.63
	0.6	35.73	8.99	4.10	2.40	1.62	1.20	0.96	0.81	0.72
	0.7	48.67	12.19	5.51	3.19	2.12	1.55	1.20	0.99	0.85
	0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.49	1.20	1.01
	0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.46	1.20
	1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.43




## SD5-24 Cross, Diverging (Continued)

		$C_{b1}$ Values (Concluded)								
		$Q_{b1}/Q_c$								
$A_s/A_c$	$A_{b1}/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.80	0.1	1.20	0.62	0.80	1.28	1.99	2.92	4.07	5.44	7.02
	0.2	4.10	1.20	0.72	0.62	0.66	0.80	1.01	1.28	1.60
	0.3	8.99	2.40	1.20	0.81	0.66	0.62	0.64	0.70	0.80
	0.4	15.89	4.10	1.94	1.20	0.88	0.72	0.64	0.62	0.63
	0.5	24.80	6.29	2.91	1.74	1.20	0.92	0.77	0.68	0.63
	0.6	35.73	8.99	4.10	2.40	1.62	1.20	0.96	0.81	0.72
	0.7	48.67	12.19	5.51	3.19	2.12	1.55	1.20	0.99	0.85
	0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.49	1.20	1.01
	0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.46	1.20
	1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.43
1.00	0.1	1.20	0.62	0.80	1.28	1.99	2.92	4.07	5.44	7.02
	0.2	4.10	1.20	0.72	0.62	0.66	0.80	1.01	1.28	1.60
	0.3	8.99	2.40	1.20	0.81	0.66	0.62	0.64	0.70	0.80
	0.4	15.89	4.10	1.94	1.20	0.88	0.72	0.64	0.62	0.63
	0.5	24.80	6.29	2.91	1.74	1.20	0.92	0.77	0.68	0.63
	0.6	35.73	8.99	4.10	2.40	1.62	1.20	0.96	0.81	0.72
	0.7	48.67	12.19	5.51	3.19	2.12	1.55	1.20	0.99	0.85
	0.8	63.63	15.89	7.14	4.10	2.70	1.94	1.49	1.20	1.01
	0.9	80.60	20.10	8.99	5.13	3.36	2.40	1.83	1.46	1.20
	1.0	99.60	24.80	11.07	6.29	4.10	2.91	2.20	1.74	1.43
		$C_s$ Values								
		$Q_s/Q_c$								
$A_s/A_c$		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1		0.13	0.24	0.57	0.74	0.74	0.70	0.65	0.60	0.56
0.2		0.20	0.13	0.15	0.16	0.28	0.57	0.69	0.74	0.75
0.3		0.90	0.14	0.13	0.14	0.15	0.16	0.20	0.42	0.57
0.4		2.88	0.20	0.14	0.13	0.14	0.15	0.15	0.16	0.34
0.5		6.25	0.38	0.17	0.14	0.13	0.14	0.14	0.15	0.15
0.6		11.88	0.90	0.20	0.14	0.14	0.13	0.14	0.14	0.15
0.7		18.62	1.72	0.33	0.18	0.16	0.14	0.13	0.15	0.14
0.8		26.88	2.88	0.50	0.20	0.15	0.14	0.13	0.13	0.14
0.9		36.45	4.46	0.90	0.30	0.19	0.16	0.15	0.14	0.13
1.0		45.00	6.25	1.44	0.38	0.20	0.17	0.12	0.13	0.14

For the other branch, subscripts 1 and 2 change places.

## SD5-25 Cross, Conical Branches Tapered into Body, Diverging

		$C_{b1}$ Values								
		$Q_{b1}/Q_c$								
$A_s/A_c$	$A_{b1}/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.20	0.1	2.07	2.08	1.62	1.30	1.08	0.93	0.81	0.72	0.64
	0.2	2.98	2.07	2.31	2.08	1.83	1.62	1.44	1.30	1.18
	0.3	7.36	1.56	2.07	2.34	2.24	2.08	1.91	1.76	1.62
	0.4	13.78	2.98	1.20	2.07	2.32	2.31	2.21	2.08	1.95
	0.5	22.24	4.92	1.98	1.28	2.07	2.30	2.33	2.27	2.18
	0.6	32.73	7.36	2.98	1.56	1.48	2.07	2.29	2.34	2.31
	0.7	45.26	10.32	4.21	2.21	1.34	1.60	2.07	2.27	2.33
	0.8	59.82	13.78	5.67	2.98	1.80	1.20	1.68	2.07	2.25
	0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.12	1.74	2.07
	1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.28	1.78
0.35	0.1	0.65	3.25	3.11	2.69	2.32	2.03	1.80	1.61	1.46
	0.2	2.98	0.65	2.44	3.25	3.28	3.11	2.90	2.69	2.49
	0.3	7.36	1.56	0.65	1.69	2.88	3.25	3.31	3.23	3.11
	0.4	13.78	2.98	1.20	0.65	1.12	2.44	3.02	3.25	3.31
	0.5	22.24	4.92	1.98	1.04	0.65	0.69	2.04	2.73	3.09
	0.6	32.73	7.36	2.98	1.56	0.96	0.65	0.49	1.69	2.44
	0.7	45.26	10.32	4.21	2.21	1.34	0.90	0.65	0.51	1.38
	0.8	59.82	13.78	5.67	2.98	1.80	1.20	0.86	0.65	0.52
	0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.11	0.83	0.65
	1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.04	0.81
0.55	0.1	0.65	1.50	1.56	1.38	1.20	1.06	0.94	0.84	0.77
	0.2	2.98	0.65	0.89	1.50	1.60	1.56	1.47	1.38	1.28
	0.3	7.36	1.56	0.65	0.39	1.20	1.50	1.59	1.59	1.56
	0.4	13.78	2.98	1.20	0.65	0.43	0.89	1.31	1.50	1.58
	0.5	22.24	4.92	1.98	1.04	0.65	0.47	0.61	1.09	1.36
	0.6	32.73	7.36	2.98	1.56	0.96	0.65	0.49	0.39	0.89
	0.7	45.26	10.32	4.21	2.21	1.34	0.90	0.65	0.51	0.42
	0.8	59.82	13.78	5.67	2.98	1.80	1.20	0.86	0.65	0.52
	0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.11	0.83	0.65
	1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.04	0.81



## SD5-25 Cross, Conical Branches Tapered into Body, Diverging (Continued)

		$C_{b1}$ Values (Concluded)								
		$Q_{b1}/Q_c$								
$A_s/A_c$	$A_{b1}/A_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.80	0.1	0.65	0.24	0.15	0.11	0.09	0.07	0.06	0.05	0.05
	0.2	2.98	0.65	0.33	0.24	0.18	0.15	0.13	0.11	0.10
	0.3	7.36	1.56	0.65	0.39	0.29	0.24	0.20	0.17	0.15
	0.4	13.78	2.98	1.20	0.65	0.43	0.33	0.27	0.24	0.21
	0.5	22.24	4.92	1.98	1.04	0.65	0.47	0.36	0.31	0.27
	0.6	32.73	7.36	2.98	1.56	0.96	0.65	0.49	0.39	0.33
	0.7	45.26	10.32	4.21	2.21	1.34	0.90	0.65	0.51	0.42
	0.8	59.82	13.78	5.67	2.98	1.80	1.20	0.86	0.65	0.52
	0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.11	0.83	0.65
	1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.04	0.81
1.00	0.1	0.65	0.24	0.15	0.11	0.09	0.07	0.06	0.05	0.05
	0.2	2.98	0.65	0.33	0.24	0.18	0.15	0.13	0.11	0.10
	0.3	7.36	1.56	0.65	0.39	0.29	0.24	0.20	0.17	0.15
	0.4	13.78	2.98	1.20	0.65	0.43	0.33	0.27	0.24	0.21
	0.5	22.24	4.92	1.98	1.04	0.65	0.47	0.36	0.31	0.27
	0.6	32.73	7.36	2.98	1.56	0.96	0.65	0.49	0.39	0.33
	0.7	45.26	10.32	4.21	2.21	1.34	0.90	0.65	0.51	0.42
	0.8	59.82	13.78	5.67	2.98	1.80	1.20	0.86	0.65	0.52
	0.9	76.41	17.75	7.36	3.88	2.35	1.56	1.11	0.83	0.65
	1.0	95.04	22.24	9.27	4.92	2.98	1.98	1.40	1.04	0.81

		$C_s$ Values								
		$Q_s/Q_c$								
$A_s/A_c$		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1		0.13	0.24	0.57	0.74	0.74	0.70	0.65	0.60	0.56
0.2		0.20	0.13	0.15	0.16	0.28	0.57	0.69	0.74	0.75
0.3		0.90	0.14	0.13	0.14	0.15	0.16	0.20	0.42	0.57
0.4		2.88	0.20	0.14	0.13	0.14	0.15	0.15	0.16	0.34
0.5		6.25	0.38	0.17	0.14	0.13	0.14	0.14	0.15	0.15
0.6		11.88	0.90	0.20	0.14	0.14	0.13	0.14	0.14	0.15
0.7		18.62	1.72	0.33	0.18	0.16	0.14	0.13	0.15	0.14
0.8		26.88	2.88	0.50	0.20	0.15	0.14	0.13	0.13	0.14
0.9		36.45	4.46	0.90	0.30	0.19	0.16	0.15	0.14	0.13
1.0		45.00	6.25	1.44	0.38	0.20	0.17	0.12	0.13	0.14

For the other branch, subscripts 1 and 2 change places

## RECTANGULAR FITTINGS


## CR3-1 Elbow, Smooth Radius, Without Vanes

$r/W$	$C_p$ Values									
	$H/W$									
0.25	0.50	0.75	1.0	1.50	2.0	3.0	4.0	5.0	6.0	8.0
0.50	1.53	1.38	1.29	1.18	1.06	1.00	1.00	1.06	1.12	1.16
0.75	0.57	0.52	0.48	0.44	0.40	0.39	0.39	0.40	0.42	0.44
1.00	0.27	0.25	0.23	0.21	0.19	0.18	0.18	0.19	0.20	0.21
1.50	0.22	0.20	0.19	0.17	0.15	0.14	0.14	0.15	0.16	0.17
2.00	0.20	0.18	0.16	0.15	0.14	0.13	0.13	0.14	0.14	0.15


Angle Factor $K$											
0	20	30	45	60	75	90	110	130	150	180	
0.00	0.31	0.45	0.60	0.78	0.90	1.00	1.13	1.20	1.28	1.40	

$$C_o = KC_p \text{ where } K = \text{angle factor}$$



**CR3-3 Elbow, Smooth Radius, One Splitter Vane**

$r/W$	$C_p$ Values										
	$H/W$										
0.25	0.50	1.0	1.50	2.0	3.0	4.0	5.0	6.0	7.0	8.0	
0.55	0.52	0.40	0.43	0.49	0.55	0.66	0.75	0.84	0.93	1.01	1.09
0.60	0.36	0.27	0.25	0.28	0.30	0.35	0.39	0.42	0.46	0.49	0.52
0.65	0.28	0.21	0.18	0.19	0.20	0.22	0.25	0.26	0.28	0.30	0.32
0.70	0.22	0.16	0.14	0.14	0.15	0.16	0.17	0.18	0.19	0.20	0.21
0.75	0.18	0.13	0.11	0.11	0.11	0.12	0.13	0.14	0.14	0.15	0.15
0.80	0.15	0.11	0.09	0.09	0.09	0.09	0.10	0.10	0.11	0.11	0.12
0.85	0.13	0.09	0.08	0.07	0.07	0.08	0.08	0.08	0.08	0.09	0.09
0.90	0.11	0.08	0.07	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07
0.95	0.10	0.07	0.06	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06
1.00	0.09	0.06	0.05	0.05	0.04	0.04	0.04	0.05	0.05	0.05	0.05



$$C_o = KC_p$$

$$R_1 = R/CR$$

where

R = throat radius

R<sub>1</sub> = splitter vane radius

CR = curve ratio


K = angle factor

Angle Factor K					
θ	0	30	45	60	90
K	0.00	0.45	0.60	0.78	1.00


$r/W$	Curve Ratio CR									
	0.55	0.60	0.65	0.70	0.75	0.80	0.85	0.90	0.95	1.0
CR	0.218	0.302	0.361	0.408	0.447	0.480	0.509	0.535	0.557	0.577
Throat Radius/Width Ratio ( $R/W$ )										
$r/W$	0.55	0.60	0.65	0.70	0.75	0.80	0.85	0.90	0.95	1.0
$R/W$	0.05	0.10	0.15	0.20	0.25	0.30	0.35	0.40	0.45	0.50

**CR3-6 Elbow, Mitered**

θ	$C_o$ Values									
	$H/W$									
0.25	0.50	0.75	1.00	1.50	2.0	3.0	4.0	5.0	6.0	8.0
20	0.08	0.08	0.08	0.07	0.07	0.07	0.06	0.06	0.05	0.05
30	0.18	0.17	0.17	0.16	0.15	0.15	0.13	0.13	0.12	0.11
45	0.38	0.37	0.36	0.34	0.33	0.31	0.28	0.27	0.26	0.24
60	0.60	0.59	0.57	0.55	0.52	0.49	0.46	0.43	0.41	0.38
75	0.89	0.87	0.84	0.81	0.77	0.73	0.67	0.63	0.61	0.58
90	1.30	1.27	1.23	1.18	1.13	1.07	0.98	0.92	0.89	0.83


**CR3-9 Elbow, Mitered, 90 Degree, Single-Thickness Vanes (40 mm Vane Spacing)**

$$C_o = 0.11$$




**CR3-12 Elbow, Mitered, 90 Degree, Single-Thickness Vanes  
(80 mm Vane Spacing)**

$$C_o = 0.33$$




**CR3-15 Elbow, Mitered, 90 Degree, Double-Thickness  
Vanes (60 mm Vane Spacing)**

$$C_o = 0.25$$



**CR3-16 Elbow, Mitered, 90 Degree, Double-Thickness  
Vanes (80 mm Vane Spacing)**

$$C_o = 0.41$$




## CR3-17 Elbow, Z-Shaped

$H/W$	$C_p$ Values												
	$L/W$												
0.0	0.0	0.68	0.99	1.77	2.89	3.97	4.41	4.60	4.64	4.60	3.39	3.03	2.70
0.25	0.0	0.68	0.99	1.77	2.89	3.97	4.41	4.60	4.64	4.60	3.39	3.03	2.70
0.50	0.0	0.66	0.96	1.72	2.81	3.86	4.29	4.47	4.52	4.47	3.30	2.94	2.62
0.75	0.0	0.64	0.94	1.67	2.74	3.75	4.17	4.35	4.39	4.35	3.20	2.86	2.55
1.0	0.0	0.62	0.90	1.61	2.63	3.61	4.01	4.18	4.22	4.18	3.08	2.75	2.45
1.5	0.0	0.59	0.86	1.53	2.50	3.43	3.81	3.97	4.01	3.97	2.93	2.61	2.33
2.0	0.0	0.56	0.81	1.45	2.37	3.25	3.61	3.76	3.80	3.76	2.77	2.48	2.21
3.0	0.0	0.51	0.75	1.34	2.18	3.00	3.33	3.47	3.50	3.47	2.56	2.28	2.03
4.0	0.0	0.48	0.70	1.26	2.05	2.82	3.13	3.26	3.29	3.26	2.40	2.15	1.91
6.0	0.0	0.45	0.65	1.16	1.89	2.60	2.89	3.01	3.04	3.01	2.22	1.98	1.76
8.0	0.0	0.43	0.63	1.13	1.84	2.53	2.81	2.93	2.95	2.93	2.16	1.93	1.72

Reynolds Number Correction Factor $K_r$											
Re/1000	10	20	30	40	60	80	100	140	500		
$K_r$	1.40	1.26	1.19	1.14	1.09	1.06	1.04	1.00	1.00		




$$C_o = K_r C_p$$

where  $K_r$  = Reynolds number correction factor

## CR6-1 Screen (Only)


$A_1/A_o$	$C_o$ Values												
	$n$												
0.30	0.35	0.40	0.45	0.50	0.55	0.60	0.65	0.70	0.75	0.80	0.90	1.0	
0.2	155.0	103.0	75.00	55.00	41.25	31.50	24.25	18.75	14.50	11.00	8.00	3.50	0.0
0.3	68.89	45.56	33.33	24.44	18.33	14.00	10.78	8.33	6.44	4.89	3.56	1.56	0.0
0.4	38.75	25.63	18.75	13.75	10.31	7.88	6.06	4.69	3.63	2.75	2.00	0.88	0.0
0.5	24.80	16.40	12.00	8.80	6.60	5.04	3.88	3.00	2.32	1.76	1.28	0.56	0.0
0.6	17.22	11.39	8.33	6.11	4.58	3.50	2.69	2.08	1.61	1.22	0.89	0.39	0.0
0.7	12.65	8.37	6.12	4.49	3.37	2.57	1.98	1.53	1.18	0.90	0.65	0.29	0.0
0.8	9.69	6.40	4.69	3.44	2.58	1.97	1.52	1.17	0.91	0.69	0.50	0.22	0.0
0.9	7.65	5.06	3.70	2.72	2.04	1.56	1.20	0.93	0.72	0.54	0.40	0.17	0.0
1.0	6.20	4.10	3.00	2.20	1.65	1.26	0.97	0.75	0.58	0.44	0.32	0.14	0.0
1.2	4.31	2.85	2.08	1.53	1.15	0.88	0.67	0.52	0.40	0.31	0.22	0.10	0.0
1.4	3.16	2.09	1.53	1.12	0.84	0.64	0.49	0.38	0.30	0.22	0.16	0.07	0.0
1.6	2.42	1.60	1.17	0.86	0.64	0.49	0.38	0.29	0.23	0.17	0.13	0.05	0.0
1.8	1.91	1.27	0.93	0.68	0.51	0.39	0.30	0.23	0.18	0.14	0.10	0.04	0.0
2.0	1.55	1.03	0.75	0.55	0.41	0.32	0.24	0.19	0.15	0.11	0.08	0.04	0.0
2.5	0.99	0.66	0.48	0.35	0.26	0.20	0.16	0.12	0.09	0.07	0.05	0.02	0.0
3.0	0.69	0.46	0.33	0.24	0.18	0.14	0.11	0.08	0.06	0.05	0.04	0.02	0.0
4.0	0.39	0.26	0.19	0.14	0.10	0.08	0.06	0.05	0.04	0.03	0.02	0.01	0.0
6.0	0.17	0.11	0.08	0.06	0.05	0.04	0.03	0.02	0.02	0.01	0.01	0.00	0.0



$n$  = free area ratio of screen

$A_o$  = area of duct


$A_1$  = cross-sectional area of duct or fitting where screen is located

**CR6-4 Obstruction, Smooth Cylinder in Rectangular Duct**

$y/H$	Re/1000	$C_o$ Values					$y/H$	Re/1000	$C_o$ Values						
		$S_m/A_o$							$S_m/A_o$						
		0.0	0.05	0.10	0.15	0.20			0.0	0.05	0.10	0.15	0.20		
0.00	0.1	0.0	0.10	0.21	0.35	0.47	0.25	400	0.0	0.04	0.10	0.16	0.21		
	0.5	0.0	0.08	0.17	0.28	0.38		500	0.0	0.03	0.07	0.12	0.16		
	200	0.0	0.08	0.17	0.28	0.38		600	0.0	0.02	0.04	0.06	0.09		
	300	0.0	0.07	0.16	0.26	0.35		1000	0.0	0.02	0.04	0.07	0.09		
	400	0.0	0.05	0.11	0.19	0.25		200	0.0	0.06	0.14	0.22	0.30		
	500	0.0	0.04	0.09	0.14	0.19		300	0.0	0.06	0.12	0.20	0.28		
	600	0.0	0.02	0.05	0.07	0.10		400	0.0	0.04	0.09	0.15	0.20		
	1000	0.0	0.02	0.05	0.08	0.11		500	0.0	0.03	0.07	0.11	0.15		
	0.05	0.1	0.0	0.10	0.21	0.34		600	0.0	0.02	0.04	0.06	0.08		
	0.5	0.0	0.08	0.17	0.27	0.37		1000	0.0	0.02	0.04	0.06	0.09		
0.05	200	0.0	0.08	0.17	0.27	0.37	0.30	0.1	0.0	0.08	0.17	0.28	0.38		
	300	0.0	0.07	0.15	0.25	0.34		0.5	0.0	0.06	0.14	0.22	0.30		
	400	0.0	0.05	0.11	0.18	0.24		200	0.0	0.06	0.14	0.22	0.30		
	500	0.0	0.04	0.08	0.13	0.18		300	0.0	0.06	0.12	0.20	0.28		
	600	0.0	0.02	0.04	0.07	0.10		400	0.0	0.04	0.09	0.15	0.20		
	1000	0.0	0.02	0.05	0.08	0.11		500	0.0	0.03	0.07	0.11	0.15		
	0.10	0.1	0.0	0.09	0.20	0.32		600	0.0	0.02	0.03	0.05	0.07		
	0.5	0.0	0.07	0.16	0.26	0.35		1000	0.0	0.02	0.04	0.06	0.08		
	200	0.0	0.07	0.16	0.26	0.35		200	0.0	0.06	0.13	0.21	0.28		
	300	0.0	0.07	0.15	0.24	0.32		300	0.0	0.05	0.12	0.19	0.26		
0.10	400	0.0	0.05	0.11	0.17	0.23	0.35	400	0.0	0.04	0.08	0.14	0.19		
	500	0.0	0.04	0.08	0.13	0.18		500	0.0	0.03	0.06	0.10	0.14		
	600	0.0	0.02	0.04	0.07	0.09		600	0.0	0.02	0.03	0.05	0.07		
	1000	0.0	0.02	0.05	0.08	0.10		1000	0.0	0.02	0.04	0.06	0.08		
	0.15	0.1	0.0	0.09	0.19	0.31		200	0.0	0.05	0.11	0.19	0.25		
	0.5	0.0	0.07	0.15	0.25	0.34		300	0.0	0.05	0.11	0.17	0.23		
	200	0.0	0.07	0.15	0.25	0.34		400	0.0	0.04	0.08	0.12	0.17		
	300	0.0	0.06	0.14	0.23	0.31		500	0.0	0.03	0.06	0.09	0.13		
	400	0.0	0.05	0.10	0.17	0.22		600	0.0	0.01	0.03	0.05	0.07		
	500	0.0	0.04	0.08	0.12	0.17		1000	0.0	0.02	0.03	0.05	0.07		
0.15	600	0.0	0.02	0.04	0.07	0.09	0.40	0.1	0.0	0.07	0.14	0.23	0.32		
	1000	0.0	0.02	0.05	0.08	0.10		0.5	0.0	0.05	0.11	0.19	0.25		
	0.20	0.1	0.0	0.08	0.18	0.29		200	0.0	0.05	0.11	0.19	0.25		
	0.5	0.0	0.07	0.14	0.24	0.32		300	0.0	0.04	0.09	0.15	0.20		
	200	0.0	0.07	0.14	0.24	0.32		400	0.0	0.03	0.07	0.11	0.15		
	300	0.0	0.06	0.13	0.22	0.29		500	0.0	0.02	0.05	0.08	0.11		
	1000	0.0	0.02	0.04	0.07	0.10		600	0.0	0.01	0.03	0.04	0.06		
	0.20	0.1	0.0	0.08	0.18	0.29		1000	0.0	0.01	0.03	0.05	0.06		


**CR9-1 Damper, Butterfly**

$H/W$	$C_o$ Values									
	$\theta$									
0.10	0.04	0.30	1.10	3.0	8.0	23.0	60.	100.	190.	9999
0.50	0.04	0.30	1.10	3.0	8.0	23.0	60.	100.	190.	9999
1.0	0.04	0.30	1.10	3.0	8.0	23.0	60.	100.	190.	9999
1.5	0.04	0.35	1.25	3.6	10.0	29.0	80.	155.	230.	9999
2.0	0.04	0.35	1.25	3.6	10.0	29.0	80.	155.	230.	9999




**CR9-3 Damper, Parallel and Opposed 3V Blades, Open**


$$C_o = 0.37$$

**CR9-4 Damper, Parallel and Opposed Airfoil Blades, Open**

$$C_o = 0.18$$

**CR9-6 Fire Damper, Curtain Type, Type B, Horizontal Duct**


$$C_o = 0.19$$

**ER2-1 Bellmouth, Plenum to Round, Exhaust/Return Systems**


$$r/D_1 \quad 0.0 \quad 0.01 \quad 0.02 \quad 0.03 \quad 0.04 \quad 0.05 \quad 0.06 \quad 0.08 \quad 0.10 \quad 0.12 \quad 0.16 \quad 0.20 \quad 10.0$$

$$C_I \quad 0.50 \quad 0.44 \quad 0.37 \quad 0.31 \quad 0.26 \quad 0.22 \quad 0.20 \quad 0.15 \quad 0.12 \quad 0.09 \quad 0.06 \quad 0.03 \quad 0.03$$

$$C_o = C_I \left( \frac{A_o}{A_1} \right)^2$$


**ER3-1 Elbow, 90 Degree, Variable Inlet/Outlet Areas, Exhaust/Return Systems**

	C_o Values						
	W_1/W_o						
H/W_o	0.6	0.8	1.0	1.2	1.4	1.6	2.0
0.25	1.76	1.43	1.24	1.14	1.09	1.06	1.06
1.00	1.70	1.36	1.15	1.02	0.95	0.90	0.84
4.00	1.46	1.10	0.90	0.81	0.76	0.72	0.66
100.00	1.50	1.04	0.79	0.69	0.63	0.60	0.55




**ER4-1 Transition, Rectangular, Two Sides Parallel,  
Symmetrical, Exhaust/Return Systems**


$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.063	0.0	0.44	0.27	0.25	0.27	0.36	0.56	0.71	0.86	0.99	0.99	0.98	0.98
0.10	0.0	0.41	0.27	0.23	0.25	0.34	0.53	0.69	0.83	0.94	0.94	0.92	0.91
0.167	0.0	0.34	0.28	0.21	0.23	0.30	0.48	0.65	0.76	0.83	0.83	0.82	0.80
0.25	0.0	0.26	0.29	0.17	0.19	0.25	0.42	0.60	0.68	0.70	0.70	0.68	0.66
0.50	0.0	0.16	0.24	0.14	0.13	0.15	0.24	0.35	0.37	0.38	0.37	0.36	0.35
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.00	0.0	0.30	0.38	0.25	0.17	0.17	0.23	0.29	0.49	0.66	0.81	0.88	
4.00	0.0	1.66	1.25	0.77	0.70	0.70	0.70	0.90	1.09	2.84	4.36	5.69	6.57
6.00	0.0	4.05	3.14	1.76	1.58	1.58	2.12	2.66	6.71	10.11	13.13	15.20	
10.00	0.0	12.01	9.39	5.33	5.00	5.00	6.45	7.93	19.10	28.60	36.79	42.79	


**ER4-3 Transition, Rectangular to Round, Exhaust/Return Systems**


$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.063	0.0	0.17	0.19	0.30	0.46	0.53	0.64	0.77	0.88	0.95	0.95	0.94	0.93
0.10	0.0	0.17	0.19	0.30	0.45	0.53	0.64	0.75	0.84	0.89	0.89	0.89	0.88
0.167	0.0	0.18	0.19	0.30	0.44	0.53	0.63	0.72	0.78	0.79	0.79	0.79	0.79
0.25	0.0	0.16	0.18	0.25	0.36	0.45	0.52	0.58	0.62	0.64	0.64	0.64	0.64
0.50	0.0	0.14	0.14	0.15	0.22	0.25	0.30	0.33	0.33	0.33	0.32	0.31	0.30
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.00	0.0	0.30	0.27	0.26	0.28	0.25	0.19	0.23	0.27	0.52	0.75	0.91	0.95
4.00	0.0	1.60	1.14	0.84	0.85	0.86	0.76	0.90	1.09	2.78	4.30	5.65	6.55
6.00	0.0	3.89	3.04	1.84	1.77	1.78	1.73	2.18	2.67	6.67	10.07	13.09	15.18
10.00	0.0	11.80	9.31	5.40	5.18	5.15	5.05	6.44	7.94	19.06	28.55	36.75	42.75


**ER5-2 Tee, Round Tap to Rectangular Main, Converging**

$Q_b/Q_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
	$C_b$	-14.00	-2.38	0.50	0.65	1.03	1.17	1.19	1.33	1.51
$Q_s/Q_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
$C_s$	22.15	11.91	6.54	3.74	2.23	1.33	0.76	0.38	0.10	0.0



**ER5-3 Tee, 45 Degree Entry Branch, Converging**

$Q_b/Q_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
	$C_b$	-19.38	-3.75	-0.74	0.48	0.66	0.75	0.85	0.77	0.83
$Q_s/Q_c$	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
$C_s$	22.15	11.91	6.54	3.74	2.23	1.33	0.76	0.38	0.10	0.0




**ER7-1 Fan Inlet, Centrifugal, SWSI,  
90 Degree Smooth Radius Elbow (Square)**

<i>r/H</i>	<i>C<sub>o</sub></i> Values			
	0.0	2.0	5.0	10.0
0.50	2.50	1.60	0.80	0.80
0.75	2.00	1.20	0.67	0.67
1.00	1.20	0.67	0.33	0.33
1.50	1.00	0.57	0.30	0.30
2.00	0.80	0.47	0.26	0.26


**SR1-1 Conical Bellmouth/Sudden Contraction, Plenum to Rectangular,  
Supply Air Systems**

<i>L/D<sub>h</sub></i>	<i>C<sub>o</sub></i> Values							
	0	10	20	30	40	60	100	140
0.000	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
0.025	0.50	0.47	0.45	0.43	0.41	0.40	0.42	0.45
0.050	0.50	0.45	0.41	0.36	0.33	0.30	0.35	0.42
0.075	0.50	0.42	0.35	0.30	0.26	0.23	0.30	0.40
0.100	0.50	0.39	0.32	0.25	0.22	0.18	0.27	0.38
0.150	0.50	0.37	0.27	0.20	0.16	0.15	0.25	0.37
0.600	0.50	0.27	0.18	0.13	0.11	0.12	0.23	0.36




$$D_h = \frac{2 H_0 W_0}{(H_0 + W_0)}$$

$\Theta$  IS LARGER OF  $\Theta_1$  AND  $\Theta_2$



**SR2-1 Abrupt Exit**

Laminar Flow										
<i>H/W</i>	0.1	0.2	0.9	0.999	1.0	1.001	1.1	4.0	5.0	10.0
<i>C<sub>o</sub></i>	1.55	1.55	1.55	1.55	2.00	1.555	1.55	1.55	1.55	1.55
Turbulent Flow										
<i>C<sub>o</sub></i>	= 1.0									





**SR2-3 Plain Diffuser (Two Sides Parallel), Free Discharge**

$A_1/A_o$	Re/1000	$C_o$ Values									
		4	8	10	14	20	30	45	60	90	120
1	50	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	100	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	200	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	400	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	2000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	50	0.51	0.50	0.51	0.56	0.63	0.80	0.96	1.04	1.09	1.09
	100	0.48	0.48	0.50	0.56	0.63	0.80	0.96	1.04	1.09	1.09
	200	0.42	0.44	0.47	0.53	0.63	0.74	0.93	1.02	1.08	1.08
	400	0.38	0.40	0.42	0.50	0.62	0.74	0.93	1.02	1.08	1.08
	2000	0.38	0.40	0.42	0.50	0.62	0.74	0.93	1.02	1.08	1.08
4	50	0.35	0.34	0.38	0.48	0.63	0.76	0.91	1.03	1.07	1.07
	100	0.31	0.31	0.36	0.45	0.59	0.72	0.88	1.02	1.07	1.07
	200	0.27	0.26	0.31	0.41	0.53	0.67	0.83	0.96	1.06	1.06
	400	0.21	0.22	0.27	0.39	0.53	0.67	0.83	0.96	1.06	1.06
	2000	0.21	0.22	0.27	0.39	0.53	0.67	0.83	0.96	1.06	1.06
6	50	0.36	0.32	0.34	0.41	0.56	0.70	0.84	0.96	1.08	1.08
	100	0.32	0.27	0.30	0.41	0.56	0.70	0.84	0.96	1.08	1.08
	200	0.26	0.24	0.27	0.36	0.52	0.67	0.81	0.94	1.06	1.06
	400	0.21	0.20	0.24	0.36	0.52	0.67	0.81	0.94	1.06	1.06
	2000	9.21	0.18	0.24	0.34	0.50	0.67	0.81	0.94	1.05	1.05

**SR2-5 Pyramidal Diffuser, Free Discharge**

$A_1/A_o$	Re/1000	$C_o$ Values									
		4	8	10	14	20	30	45	60	90	120
1	50	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	100	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	200	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	400	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
	2000	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
2	50	0.55	0.65	0.68	0.74	0.82	0.92	1.05	1.10	1.08	1.08
	100	0.51	0.61	0.66	0.73	0.81	0.90	1.04	1.09	1.08	1.08
	200	0.47	0.57	0.61	0.70	0.79	0.89	1.04	1.09	1.08	1.08
	400	0.42	0.50	0.56	0.64	0.76	0.88	1.02	1.07	1.08	1.08
	2000	0.42	0.50	0.56	0.64	0.76	0.88	1.02	1.07	1.08	1.08
4	50	0.38	0.53	0.60	0.69	0.78	0.90	1.02	1.07	1.09	1.09
	100	0.33	0.49	0.55	0.66	0.78	0.90	1.02	1.07	1.09	1.09
	200	0.27	0.42	0.50	0.62	0.74	0.87	1.00	1.06	1.08	1.08
	400	0.22	0.36	0.44	0.56	0.70	0.84	0.99	1.06	1.08	1.08
	2000	0.22	0.36	0.44	0.56	0.70	0.84	0.99	1.06	1.08	1.08
6	50	0.34	0.50	0.57	0.66	0.77	0.91	1.02	1.07	1.08	1.08
	100	0.30	0.47	0.54	0.63	0.76	0.98	1.02	1.07	1.08	1.08
	200	0.24	0.42	0.48	0.60	0.73	0.88	1.00	1.06	1.08	1.08
	400	0.18	0.34	0.44	0.56	0.73	0.86	0.98	1.06	1.08	1.08
	2000	0.18	0.34	0.44	0.56	0.73	0.86	0.98	1.06	1.08	1.08
10	50	0.30	0.45	0.53	0.64	0.74	0.85	0.97	1.10	1.12	1.12
	100	0.25	0.40	0.48	0.62	0.73	0.85	0.97	1.10	1.12	1.12
	200	0.20	0.34	0.44	0.56	0.69	0.82	0.95	1.10	1.11	1.11
	400	0.16	0.28	0.40	0.55	0.67	0.80	0.93	1.09	1.11	1.11
	2000	0.16	0.28	0.40	0.55	0.67	0.80	0.93	1.09	1.11	1.11




PLAN  
θ



**SR2-6 Pyramidal Diffuser, with Wall**

$L/D_h$	0.5	1.0	2.0	3.0	4.0	5.0	6.0	8.0	10.0	12.0	14.0
$C_o$	0.49	0.40	0.30	0.26	0.23	0.21	0.19	0.17	0.16	0.15	0.14
0	26	19	13	11	9	8	7	6	6	5	5

$\theta$  is the optimum angle.

**SR3-1 Elbow, 90 Degree, Variable Inlet/Outlet Areas, Supply Air Systems**


$H/W_1$	$C_o$ Values							
	0.6	0.8	1.0	$W_o/W_1$	1.2	1.4	1.6	2.0
0.25	0.63	0.92	1.24	1.64	2.14	2.71	4.24	
1.00	0.61	0.87	1.15	1.47	1.86	2.30	3.36	
4.00	0.53	0.70	0.90	1.17	1.49	1.84	2.64	
100.	0.54	0.67	0.79	0.99	1.23	1.54	2.20	

**SR4-1 Transition, Rectangular, Two Sides Parallel, Symmetrical, Supply Air Systems**

$$A_o/A_1 < \text{ or } > 1$$

$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.10	0.0	0.12	0.09	0.05	0.05	0.05	0.05	0.06	0.08	0.19	0.29	0.37	0.43
0.167	0.0	0.11	0.09	0.05	0.04	0.04	0.04	0.06	0.07	0.19	0.28	0.36	0.42
0.25	0.0	0.10	0.08	0.05	0.04	0.04	0.04	0.06	0.07	0.18	0.27	0.36	0.41
0.50	0.0	0.08	0.09	0.06	0.04	0.04	0.04	0.06	0.07	0.12	0.17	0.20	0.27
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00
2.00	0.0	0.64	0.96	0.54	0.52	0.62	0.94	1.40	1.48	1.52	1.48	1.44	1.40
4.00	0.0	4.16	4.64	2.72	3.09	4.00	6.72	9.60	10.88	11.20	11.20	10.88	10.56
6.00	0.0	12.24	10.08	7.38	8.10	10.80	17.28	23.40	27.36	29.88	29.88	29.34	28.80
10.00	0.0	40.50	27.20	23.30	25.10	34.00	52.84	69.00	82.50	93.50	93.50	92.40	91.30
16.00	0.0	112.64	68.35	63.74	67.84	92.93	142.13	182.53	220.16	254.21	254.21	251.90	249.60

## SR4-3 Transition, Round to Rectangular, Supply Air Systems




$A_o/A_1$	$C_o$ Values												
	0	3	5	10	15	20	30	45	60	90	120	150	180
0.10	0.0	0.12	0.09	0.05	0.05	0.05	0.05	0.06	0.08	0.19	0.29	0.37	0.43
0.167	0.0	0.11	0.08	0.05	0.05	0.05	0.05	0.06	0.07	0.19	0.28	0.37	0.42
0.25	0.0	0.10	0.07	0.05	0.05	0.05	0.05	0.06	0.07	0.17	0.27	0.35	0.41
0.50	0.0	0.08	0.07	0.06	0.07	0.06	0.05	0.06	0.07	0.13	0.19	0.23	0.24
1.00	0.0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2.00	0.0	0.57	0.55	0.61	0.87	1.00	1.20	1.30	1.30	1.30	1.28	1.24	1.20
4.00	0.0	2.60	2.84	3.92	5.72	7.20	8.32	9.28	9.92	10.24	10.24	10.24	10.24
6.00	0.0	6.57	6.75	10.62	15.84	18.90	22.50	25.74	27.90	28.44	28.44	28.35	28.26
10.00	0.0	17.25	18.75	30.00	45.00	53.00	63.50	75.00	84.0	89.00	89.00	88.50	88.00
16.00	0.0	42.75	48.13	77.57	116.74	136.45	164.10	196.86	224.26	241.92	241.92	240.38	238.59

SR5-1 Smooth Wye of Type  $A_s + A_b \geq A_c$ , Branch 90° to Main, Diverging

$A_s/A_c$	$A_b/A_c$	$C_b$ Values									
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	
0.50	0.25	2.25	0.48	0.25	0.18	0.17	0.16	0.17	0.17	0.17	
	0.50	11.00	2.38	1.06	0.64	0.52	0.47	0.47	0.47	0.48	
	1.00	60.00	13.00	4.78	2.06	0.96	0.47	0.31	0.27	0.26	
0.75	0.25	2.19	0.55	0.35	0.31	0.33	0.35	0.36	0.37	0.39	
	0.50	13.00	2.50	0.89	0.47	0.34	0.31	0.32	0.36	0.43	
	1.00	70.00	15.00	5.67	2.63	1.36	0.78	0.53	0.41	0.36	
1.00	0.25	3.44	0.78	0.42	0.33	0.30	0.31	0.40	0.42	0.46	
	0.50	15.50	3.00	1.11	0.63	0.48	0.42	0.40	0.42	0.46	
	1.00	67.00	13.75	5.11	2.31	1.28	0.81	0.59	0.47	0.46	

$A_s/A_c$	$A_b/A_c$	$C_s$ Values									
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	
		$Q_s/Q_c$									
0.50	0.25	8.65	1.12	0.21	0.05	0.06	0.10	0.15	0.19	0.24	
	0.50	7.50	0.98	0.19	0.06	0.06	0.10	0.14	0.18	0.22	
	1.00	5.21	0.68	0.15	0.06	0.07	0.10	0.13	0.16	0.19	
0.75	0.25	19.62	3.25	0.86	0.23	0.05	0.02	0.00	0.00	0.05	
	0.50	20.62	3.24	0.76	0.14	-0.03	-0.07	-0.05	-0.01	0.03	
	1.00	17.01	2.55	0.55	0.07	-0.05	-0.05	-0.02	0.02	0.06	
1.00	0.25	46.00	9.50	3.22	1.31	0.52	0.14	-0.02	-0.05	-0.01	
	0.50	35.34	6.49	1.98	0.69	0.22	0.00	-0.04	-0.05	-0.05	
	1.00	38.95	7.10	2.15	0.74	0.23	0.03	-0.04	-0.05	-0.04	



$$A_s = A_b \geq A_c$$


$$r/W_b = 1.0$$

**SR5-3 Wye of the Type  $A_s + A_b > A_c, A_s = A_c$ , 45 Degree, Diverging**

$A_b/A_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.60	0.52	0.57	0.58	0.64	0.67	0.70	0.71	0.73
0.2	2.24	0.56	0.44	0.45	0.51	0.54	0.58	0.60	0.62
0.3	5.93	1.08	0.52	0.41	0.43	0.46	0.49	0.52	0.54
0.4	10.61	1.89	0.72	0.43	0.34	0.31	0.31	0.33	0.34
0.5	17.70	3.23	1.14	0.59	0.40	0.31	0.30	0.30	0.31
0.6	26.66	5.01	1.75	0.84	0.50	0.36	0.31	0.30	0.30
0.7	37.49	7.22	2.53	1.17	0.66	0.43	0.35	0.32	0.30
0.8	50.20	9.87	3.49	1.61	0.88	0.54	0.41	0.35	0.32
0.9	64.77	12.95	4.63	2.13	1.14	0.69	0.50	0.40	0.35


$Q_s/Q_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
$C_s$	32.40	6.40	2.18	0.90	0.40	0.18	0.07	0.03	0.00

**SR5-5 Tee of the Type  $A_s + A_b > A_c, A_s = A_c$ , Diverging**

$A_b/A_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	2.06	1.20	0.99	0.87	0.88	0.87	0.87	0.86	0.86
0.2	5.15	1.92	1.29	1.03	0.99	0.94	0.92	0.90	0.89
0.3	10.30	3.12	1.78	1.28	1.16	1.06	1.01	0.97	0.94
0.4	15.90	4.35	2.24	1.48	1.11	0.88	0.80	0.75	0.72
0.5	24.31	6.31	3.04	1.90	1.35	1.03	0.91	0.83	0.78
0.6	34.60	8.70	4.03	2.41	1.65	1.22	1.04	0.94	0.87
0.7	46.75	11.53	5.19	3.01	2.00	1.44	1.20	1.06	0.96
0.8	60.78	14.79	6.53	3.70	2.40	1.69	1.38	1.20	1.07
0.9	76.67	18.49	8.05	4.49	2.86	1.98	1.59	1.36	1.20


$Q_s/Q_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
$C_s$	32.40	6.40	2.18	0.90	0.40	0.18	0.07	0.03	0.00

**SR5-11 Tee, Rectangular Main to Round Tap, Diverging**

$A_b/A_c$	$C_b$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	1.58	0.94	0.83	0.79	0.77	0.76	0.76	0.76	0.75
0.2	4.20	1.58	1.10	0.94	0.87	0.83	0.80	0.79	0.78
0.3	8.63	2.67	1.58	1.20	1.03	0.91	0.88	0.85	0.83
0.4	14.85	4.20	2.25	1.58	1.27	1.10	1.00	0.94	0.90
0.5	22.87	6.19	3.13	2.07	1.58	1.32	1.16	1.06	0.99
0.6	32.68	8.63	4.20	2.67	1.96	1.58	1.35	1.20	1.10
0.7	44.30	11.51	5.48	3.38	2.41	1.89	1.58	1.38	1.24
0.8	57.71	14.85	6.95	4.20	2.94	2.25	1.84	1.58	1.40
0.9	72.92	18.63	8.63	5.14	3.53	2.67	2.14	1.81	1.58

$A_s/A_c$	$C_s$ Values								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
$Q_s/Q_c$	0.04	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
$A_s/A_c$	0.2	0.98	0.04	0.01	0.00	0.00	0.00	0.00	0.00
$Q_s/Q_c$	0.3	3.48	0.31	0.04	0.01	0.00	0.00	0.00	0.00
$A_s/A_c$	0.4	7.55	0.98	0.18	0.04	0.02	0.00	0.00	0.00
$Q_s/Q_c$	0.5	13.18	2.03	0.49	0.13	0.04	0.00	0.01	0.00
$A_s/A_c$	0.6	20.38	3.48	0.98	0.31	0.10	0.04	0.02	0.01
$Q_s/Q_c$	0.7	29.15	5.32	1.64	0.60	0.23	0.09	0.04	0.02
$A_s/A_c$	0.8	39.48	7.55	2.47	0.98	0.42	0.18	0.08	0.04
$Q_s/Q_c$	0.9	51.37	10.17	3.48	1.46	0.67	0.31	0.15	0.07




## SR5-13 Tee, 45 Degree Entry Branch, Diverging

$A_b/A_c$	$C_b$ Values								
	$Q_b/Q_c$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.32	0.33	0.32	0.34	0.32	0.37	0.38	0.39	0.40
0.2	0.31	0.32	0.41	0.34	0.32	0.32	0.33	0.34	0.35
0.3	1.86	1.65	0.73	0.47	0.37	0.34	0.32	0.32	0.32
0.4	3.56	3.10	1.28	0.73	0.51	0.41	0.36	0.34	0.32
0.5	5.74	4.93	2.07	1.12	0.73	0.54	0.44	0.38	0.35
0.6	8.48	7.24	3.10	1.65	1.03	0.73	0.56	0.47	0.41
0.7	11.75	10.00	4.32	3.31	1.42	0.98	0.73	0.58	0.49
0.8	15.57	13.22	5.74	3.10	1.90	1.28	0.94	0.73	0.60
0.9	19.92	16.90	7.38	4.02	2.46	1.65	1.19	0.91	0.73


$A_s/A_c$	$C_s$ Values								
	$Q_s/Q_c$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	0.04	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.2	0.98	0.04	0.01	0.00	0.00	0.00	0.00	0.00	0.00
0.3	3.48	0.31	0.04	0.01	0.00	0.00	0.00	0.00	0.00
0.4	7.55	0.98	0.18	0.04	0.02	0.00	0.00	0.00	0.00
0.5	13.18	2.03	0.49	0.13	0.04	0.00	0.01	0.00	0.00
0.6	20.38	3.48	0.98	0.31	0.10	0.04	0.02	0.01	0.00
0.7	29.15	5.32	1.64	0.60	0.23	0.09	0.04	0.02	0.01
0.8	39.48	7.55	2.47	0.98	0.42	0.18	0.08	0.04	0.02
0.9	51.37	10.17	3.48	1.46	0.67	0.31	0.15	0.07	0.04



## SR5-15 Bullhead Tee Without Vanes, Diverging


$A_{b1}/A_c$	$C_{b1}$ Values								
	$Q_{b1}/Q_c$								
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9
0.1	1.34	0.53	0.37	0.30	0.29	0.28	0.27	0.27	0.27
0.2	4.43	1.25	0.66	0.45	0.39	0.35	0.32	0.31	0.30
0.3	9.58	2.45	1.16	0.71	0.56	0.47	0.41	0.37	0.35
0.4	16.87	4.17	1.88	1.09	0.73	0.53	0.38	0.33	0.30
0.5	26.19	6.35	2.79	1.56	1.01	0.71	0.49	0.41	0.37
0.6	37.57	9.02	3.89	2.14	1.35	0.92	0.62	0.52	0.45
0.7	51.03	12.17	5.20	2.82	1.75	1.18	0.78	0.64	0.54
0.8	66.55	15.81	6.71	3.61	2.22	1.48	0.96	0.78	0.65
0.9	84.15	19.93	8.42	4.50	2.74	1.81	1.17	0.94	0.78

For other branch, subscripts 1 and 2 change places.



## SR7-1 Fan, Centrifugal, Without Outlet Diffuser, Free Discharge


$A_b/A_o$	0.4	0.5	0.6	0.7	0.8	0.9	1.0
$C_o$	2.00	2.00	1.00	0.80	0.47	0.22	0.00



**SR7-2 Plane Asymmetric Diffuser at Centrifugal Fan Outlet,  
Free Discharge**


<i>C<sub>o</sub></i> Values						
<i>A<sub>1</sub>/A<sub>o</sub></i>						
0	1.5	2.0	2.5	3.0	3.5	4.0
10	0.51	0.34	0.25	0.21	0.18	0.17
15	0.54	0.36	0.27	0.24	0.22	0.20
20	0.55	0.38	0.31	0.27	0.25	0.24
25	0.59	0.43	0.37	0.35	0.33	0.33
30	0.63	0.50	0.46	0.44	0.43	0.42
35	0.65	0.56	0.53	0.52	0.51	0.50

FREE DISCHARGE



**SR7-5 Fan Outlet, Centrifugal, SWSI, with Elbow (Position A)**

<i>C<sub>o</sub></i> Values						
<i>L/L<sub>e</sub></i>						
<i>A<sub>b</sub>/A<sub>o</sub></i>	0.00	0.12	0.25	0.50	1.0	10.0
0.4	3.20	2.50	1.80	0.80	0.0	0.0
0.5	2.20	1.80	1.20	0.53	0.0	0.0
0.6	1.60	1.40	0.80	0.40	0.0	0.0
0.7	1.00	0.80	0.53	0.26	0.0	0.0
0.8	0.80	0.67	0.47	0.18	0.0	0.0
0.9	0.53	0.47	0.33	0.18	0.0	0.0
1.0	0.53	0.47	0.33	0.18	0.0	0.0



$$V_o > 13 \text{ m/s: } L_e = \frac{V_o \sqrt{A_o}}{4500}$$

$$V_o \leq 13 \text{ m/s: } L_e = \frac{\sqrt{A_o}}{350}$$

where:


$V_o$  = duct velocity, m/s

$L_e$  = effective duct length, m

$A_o$  = duct area, mm<sup>2</sup>

**SR7-6 Fan Outlet, Centrifugal, SWSI, with Elbow (Position B)**


<i>C<sub>o</sub></i> Values						
<i>L/L<sub>e</sub></i>						
<i>A<sub>b</sub>/A<sub>o</sub></i>	0.00	0.12	0.25	0.50	1.0	10.0
0.4	3.80	3.20	2.20	1.00	0.0	0.0
0.5	2.90	2.20	1.60	0.67	0.0	0.0
0.6	2.00	1.60	1.20	0.53	0.0	0.0
0.7	1.40	1.00	0.67	0.33	0.0	0.0
0.8	1.00	0.80	0.53	0.26	0.0	0.0
0.9	0.80	0.67	0.47	0.18	0.0	0.0
1.0	0.67	0.53	0.40	0.18	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-7 Fan Outlet, Centrifugal, SWSI, with Elbow (Position C)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	5.50	4.50	3.20	1.60	0.0	0.0
0.5	3.80	3.20	2.20	1.00	0.0	0.0
0.6	2.90	2.50	1.60	0.80	0.0	0.0
0.7	2.00	1.60	1.00	0.53	0.0	0.0
0.8	1.40	1.20	0.80	0.33	0.0	0.0
0.9	1.20	0.80	0.67	0.26	0.0	0.0
1.0	1.00	0.80	0.53	0.26	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-8 Fan Outlet, Centrifugal, SWSI, with Elbow (Position D)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	5.50	4.50	3.20	1.60	0.0	0.0
0.5	3.80	3.20	2.20	1.00	0.0	0.0
0.6	2.90	2.50	1.60	0.80	0.0	0.0
0.7	2.00	1.60	1.00	0.53	0.0	0.0
0.8	1.40	1.20	0.80	0.33	0.0	0.0
0.9	1.20	0.80	0.67	0.26	0.0	0.0
1.0	1.00	0.80	0.53	0.26	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-9 Fan Outlet, Centrifugal, DWDI, with Elbow (Position A)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	3.20	2.50	1.80	0.80	0.0	0.0
0.5	2.20	1.80	1.20	0.53	0.0	0.0
0.6	1.60	1.40	0.80	0.40	0.0	0.0
0.7	1.00	0.80	0.53	0.26	0.0	0.0
0.8	0.80	0.67	0.47	0.18	0.0	0.0
0.9	0.53	0.47	0.33	0.18	0.0	0.0
1.0	0.53	0.47	0.33	0.18	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-10 Fan Outlet, Centrifugal, DWDI, with Elbow (Position B)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	4.80	4.00	2.90	1.30	0.0	0.0
0.5	3.60	2.90	2.00	0.84	0.0	0.0
0.6	2.50	2.00	1.50	0.66	0.0	0.0
0.7	1.80	1.30	0.84	0.41	0.0	0.0
0.8	1.25	1.00	0.66	0.33	0.0	0.0
0.9	1.00	0.84	0.59	0.23	0.0	0.0
1.0	0.84	0.66	0.50	0.23	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-11 Fan Outlet, Centrifugal, DWDI, with Elbow (Position C)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	5.50	4.50	3.20	1.60	0.0	0.0
0.5	3.80	3.20	2.20	1.00	0.0	0.0
0.6	2.90	2.50	1.60	0.80	0.0	0.0
0.7	2.00	1.60	1.00	0.53	0.0	0.0
0.8	1.40	1.20	0.80	0.33	0.0	0.0
0.9	1.20	0.80	0.67	0.26	0.0	0.0
1.0	1.00	0.80	0.53	0.26	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-12 Fan Outlet, Centrifugal, DWDI, with Elbow (Position D)**


$A_b/A_o$	$C_o$ Values					
	0.00	0.12	0.25	0.50	1.0	10.0
0.4	4.70	3.80	2.70	1.40	0.0	0.0
0.5	3.20	2.70	1.90	0.85	0.0	0.0
0.6	2.50	2.10	1.40	0.68	0.0	0.0
0.7	1.70	1.40	0.85	0.45	0.0	0.0
0.8	1.20	1.00	0.68	0.26	0.0	0.0
0.9	1.00	0.68	0.57	0.22	0.0	0.0
1.0	0.85	0.68	0.45	0.22	0.0	0.0



To calculate  $L_e$ , see Fitting SR7-5.

**SR7-17 Pyramidal Diffuser at Centrifugal Fan Outlet with Ductwork**

$\theta$	$C_1$ Values							
	1.0	1.5	2.0	2.5	3.0	3.5	4.0	$A_o/A_1$
0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
10	0.00	0.10	0.18	0.21	0.23	0.24	0.25	
15	0.00	0.23	0.33	0.38	0.40	0.42	0.44	
20	0.00	0.31	0.43	0.48	0.53	0.56	0.58	
25	0.00	0.36	0.49	0.55	0.58	0.62	0.64	
30	0.00	0.42	0.53	0.59	0.64	0.67	0.69	



$$C_o = C_1 \left( \frac{A_o}{A_1} \right)^2$$

$\theta$  is larger of  $\theta_1$  and  $\theta_2$